

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 02-12-2018

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
SURATGARH TPS	6	250.0	02/12/2018 21.55.00		RSD/LOW SCHEDULE
SURATGARH TPS	6		02/12/2018 13.48.00	02/12/2018 15.59.00	FURNACE FIRE OUT /FLAME FAILURE
SIKKA REP. TPS	3	250.0	02/12/2018 21.00.00	04/12/2018	RESERVE SHUT DOWN / STANDBY UNIT
UKAI TPS	3	200.0	02/12/2018 03.11.00		WATER WALL TUBE LEAKAGE
BHUSAWAL TPS	3	210.0	02/12/2018 00.00.00		RSD/LOW SCHEDULE
KORADI TPS	6	210.0	02/12/2018 22.01.00		TURBINE VIBRATIONS HIGH
TALCHER STPS	2	500.0	02/12/2018 13.05.00		WATER WALL TUBE LEAKAGE
MEJIA TPS	8	500.0	02/12/2018 23.53.00		COAL SHORTAGE
KOLAGHAT TPS	2	210.0	02/12/2018 15.25.00		P.R.D.S. FAILURE.
SANTALDIH TPS	6	250.0	02/12/2018 20.20.00	02/12/2018 21.29.00	FURNACE DRAFT ABNORMAL
SANTALDIH TPS	6		02/12/2018 15.47.00	02/12/2018 18.16.00	FURNACE FIRE OUT /FLAME FAILURE
HALDIA TPP	1	300.0	02/12/2018 01.53.35	02/12/2018 04.21.00	DRUM LEVEL LOW
LAKWA REPLACEMENT POWER PROJECT	2	9.965	02/12/2018 10.15.00	02/12/2018 11.20.35	CAPITAL MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	4	9.965	02/12/2018 00.00.00	02/12/2018 02.55.26	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	7	9.965	02/12/2018 10.49.00	02/12/2018 12.44.15	Fuel Shortage
Total		2909.8950000			