

CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION

**DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 01-05-2025**

Sub-Report-10

| State/System    | Power Station                 | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status              |
|-----------------|-------------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-------------------------------------|
| 1               | 2                             | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                  |
| <b>Northern</b> |                               |          |                          |                                 |                                 |                         |                                                    |                                                       |                                     |
| Haryana         | PANIPAT TPS                   | 8        | 250.00                   | 0.00                            | 0.00                            | 0.00                    | 06/04/2025 01:23                                   | 01/05/2025 21:36                                      | ANNUAL MAINTENANCE                  |
| Haryana         | RAJIV GANDHI TPS              | 1        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 23/02/2025 21:06                                   |                                                       | WATER WALL TUBE LEAKAGE             |
| Haryana         | MAHATMA GANDHI TPS            | 1        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 28/04/2025 16:30                                   |                                                       | WATER WALL TUBE LEAKAGE             |
| Punjab          | GH TPS (LEH.MOH.)             | 3        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 01/05/2025 22:31                                   |                                                       | RSD/LOW SCHEDULE                    |
| Punjab          | GOINDWAL SAHIB TPP            | 2        | 270.00                   | 0.00                            | 0.00                            | 0.00                    | 05/04/2025 22:15                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| Punjab          | ROPAR TPS                     | 4        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 01/05/2025 21:45                                   |                                                       | RSD/LOW SCHEDULE                    |
| Rajasthan       | BARSINGSAR LIGNITE            | 2        | 125.00                   | 0.00                            | 0.00                            | 0.00                    | 26/04/2025 22:43                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| Rajasthan       | DAE (RAJASTHAN)               | 1        | 0.00                     | 100.00                          | 0.00                            | 0.00                    | 09/10/2004 22:58                                   |                                                       | GENERATOR EARTH FAULT               |
| Rajasthan       | RAJASTHAN A.P.S.              | 2        | 200.00                   | 0.00                            | 0.00                            | 0.00                    | 31/12/2024 21:44                                   |                                                       | ANNUAL MAINTENANCE                  |
| Rajasthan       | CHHABRA-II TPP                | 6        | 0.00                     | 660.00                          | 0.00                            | 0.00                    | 13/04/2025 00:48                                   |                                                       | TURBINE BEARING PROBLEM             |
| Rajasthan       | CHHABRA-I PH-1 TPP            | 1        | 250.00                   | 0.00                            | 0.00                            | 0.00                    | 29/04/2025 06:00                                   | 01/05/2025 14:21                                      | BOILER INSPECTION/ RE-CERTIFICATION |
| Rajasthan       | GIRAL TPS                     | 1        | 125.00                   | 0.00                            | 0.00                            | 0.00                    | 11/07/2014 08:20                                   |                                                       | UNIT LIKELY TO BE SCRAPPED.         |
| Rajasthan       | GIRAL TPS                     | 2        | 125.00                   | 0.00                            | 0.00                            | 0.00                    | 27/01/2016 15:27                                   |                                                       | UNIT LIKELY TO BE SCRAPPED.         |
| Rajasthan       | SURATGARH TPS                 | 3        | 0.00                     | 250.00                          | 0.00                            | 0.00                    | 28/11/2024 13:48                                   |                                                       | GENERATOR STATOR DAMAGED            |
| Rajasthan       | ADANI POWER LIMITED KAWAI TPP | 1        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 29/04/2025 11:15                                   |                                                       | CONDENSER TUBE LEAKAGE/ CLEANING    |
| Rajasthan       | JALIPA KAPURDI TPP            | 1        | 0.00                     | 0.00                            | 135.00                          | 0.00                    | 01/05/2025 15:57                                   |                                                       | BOILER MISC. PROBLEM                |
| Rajasthan       | JALIPA KAPURDI TPP            | 2        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 28/04/2025 08:51                                   | 01/05/2025 01:47                                      | BOILER INSPECTION/ RE-CERTIFICATION |

## DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 01-05-2025

Sub-Report-10

| State/System          | Power Station                  | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status              |
|-----------------------|--------------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-------------------------------------|
| 1                     | 2                              | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                  |
| Rajasthan             | JALIPA KAPURDI TPP             | 3        | 0.00                     | 0.00                            | 135.00                          | 0.00                    | 28/04/2025 04:56                                   |                                                       | BOILER MISC. PROBLEM                |
| Uttar Pradesh         | MEJA STPP                      | 2        | 660.00                   | 0.00                            | 0.00                            | 0.00                    | 26/02/2025 22:27                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| Uttar Pradesh         | SINGRAULI STPS                 | 7        | 0.00                     | 0.00                            | 500.00                          | 0.00                    | 30/04/2025 17:06                                   |                                                       | STATOR WINDING TEMP. HIGH           |
| Uttar Pradesh         | NARORA A.P.S.                  | 1        | 0.00                     | 220.00                          | 0.00                            | 0.00                    | 14/04/2025 04:36                                   |                                                       | Turbine Misc                        |
| Uttar Pradesh         | OBRA TPS                       | 13       | 0.00                     | 0.00                            | 200.00                          | 0.00                    | 29/04/2025 23:15                                   |                                                       | I.D. FANS PROBLEM                   |
| <b>Total Northern</b> |                                |          | <b>2,005.00</b>          | <b>1,830.00</b>                 | <b>2,290.00</b>                 | <b>0.00</b>             |                                                    |                                                       |                                     |
| <b>Western</b>        |                                |          |                          |                                 |                                 |                         |                                                    |                                                       |                                     |
| Chhatisgarh           | KORBA STPS                     | 2        | 200.00                   | 0.00                            | 0.00                            | 0.00                    | 24/04/2025 00:55                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| Chhatisgarh           | ADANI POWER LIMITED RAIPUR TPP | 1        | 0.00                     | 0.00                            | 685.00                          | 0.00                    | 29/04/2025 15:28                                   |                                                       | BOILER MISC. PROBLEM                |
| Chhatisgarh           | ADANI POWER LIMITED RAIPUR TPP | 2        | 0.00                     | 0.00                            | 685.00                          | 0.00                    | 01/05/2025 16:44                                   |                                                       | TRANSMISSION CONSTRAINTS            |
| Chhatisgarh           | CHAKABURA TPP                  | 2        | 0.00                     | 0.00                            | 30.00                           | 0.00                    | 24/04/2025 11:35                                   |                                                       | ROTOR/ ROTOR EARTH FAULT            |
| Chhatisgarh           | KATGHORA TPP                   | 1        | 0.00                     | 0.00                            | 0.00                            | 35.00                   | 15/10/2012 00:28                                   |                                                       | NO Power purchase agreement         |
| Chhatisgarh           | OP JINDAL TPS                  | 4        | 0.00                     | 250.00                          | 0.00                            | 0.00                    | 09/02/2025 08:36                                   |                                                       | ELECTRICAL FAULT                    |
| Chhatisgarh           | SALORA TPP                     | 1        | 0.00                     | 0.00                            | 0.00                            | 135.00                  | 19/10/2014 04:30                                   |                                                       | NO Power purchase agreement         |
| Chhatisgarh           | SWASTIK KORBA TPP              | 1        | 0.00                     | 0.00                            | 0.00                            | 25.00                   | 01/04/2015 00:20                                   |                                                       | NO Power purchase agreement         |
| Chhatisgarh           | TAMNAR TPP                     | 1        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 29/04/2025 05:17                                   |                                                       | TURBINE MISC. PROBLEM               |
| Chhatisgarh           | UCHPINDA TPP                   | 1        | 0.00                     | 0.00                            | 360.00                          | 0.00                    | 23/04/2025 09:06                                   |                                                       | GENEARTOR MISC.                     |
| Gujarat               | AKRIMOTA LIG TPS               | 1        | 125.00                   | 0.00                            | 0.00                            | 0.00                    | 08/06/2024 19:30                                   |                                                       | CAPITAL MAINTENANCE                 |
| Gujarat               | AKRIMOTA LIG TPS               | 2        | 125.00                   | 0.00                            | 0.00                            | 0.00                    | 19/02/2024 18:45                                   |                                                       | CAPITAL MAINTENANCE                 |

## DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 01-05-2025

Sub-Report-10

| State/System   | Power Station                 | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status                       |
|----------------|-------------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|----------------------------------------------|
| 1              | 2                             | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                           |
| Gujarat        | BHAVNAGAR CFBC TPP            | 2        | 0.00                     | 0.00                            | 250.00                          | 0.00                    | 01/05/2025 19:45                                   |                                                       | WATER WALL TUBE LEAKAGE                      |
| Gujarat        | KUTCH LIG. TPS                | 4        | 0.00                     | 75.00                           | 0.00                            | 0.00                    | 05/07/2023 07:05                                   |                                                       | COOLING TOWER PROBLEM                        |
| Gujarat        | WANAKBORI TPS                 | 5        | 210.00                   | 0.00                            | 0.00                            | 0.00                    | 10/03/2025 00:22                                   |                                                       | CAPITAL MAINTENANCE                          |
| Gujarat        | SURAT LIG. TPS                | 2        | 0.00                     | 0.00                            | 125.00                          | 0.00                    | 26/04/2025 05:15                                   |                                                       | WATER WALL TUBE LEAKAGE                      |
| Madhya Pradesh | VINDHYACHAL STPS              | 11       | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 01/05/2025 00:04                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE          |
| Madhya Pradesh | SANJAY GANDHI TPS             | 1        | 210.00                   | 0.00                            | 0.00                            | 0.00                    | 04/08/2024 19:03                                   |                                                       | ANNUAL MAINTENANCE                           |
| Madhya Pradesh | SATPURA TPS                   | 6        | 200.00                   | 0.00                            | 0.00                            | 0.00                    | 05/03/2021 11:55                                   |                                                       | UNIT LIKELY TO BE SCRAPPED.                  |
| Madhya Pradesh | SATPURA TPS                   | 7        | 210.00                   | 0.00                            | 0.00                            | 0.00                    | 05/03/2021 10:09                                   |                                                       | UNIT LIKELY TO BE SCRAPPED.                  |
| Madhya Pradesh | SATPURA TPS                   | 8        | 210.00                   | 0.00                            | 0.00                            | 0.00                    | 29/02/2020 23:54                                   |                                                       | UNIT LIKELY TO BE SCRAPPED.                  |
| Madhya Pradesh | SATPURA TPS                   | 9        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 24/02/2020 07:20                                   |                                                       | RSD/LOW SCHEDULE                             |
| Madhya Pradesh | SHREE SINGAJI TPP             | 3        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 21/04/2025 15:32                                   | 01/05/2025 04:35                                      | BOILER MISC. PROBLEM                         |
| Madhya Pradesh | MAHAN TPP                     | 1        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 13/04/2025 06:18                                   |                                                       | GENEARTOR MISC.                              |
| Madhya Pradesh | NIWARI TPP                    | 2        | 0.00                     | 0.00                            | 45.00                           | 0.00                    | 24/04/2025 06:52                                   |                                                       | WATER WALL TUBE LEAKAGE                      |
| Maharashtra    | TARAPUR                       | 1        | 160.00                   | 0.00                            | 0.00                            | 0.00                    | 06/03/2024 00:00                                   |                                                       | RENOVATION/MODERNISATION WORKS               |
| Maharashtra    | TARAPUR                       | 2        | 160.00                   | 0.00                            | 0.00                            | 0.00                    | 13/07/2020 04:38                                   |                                                       | RENOVATION/MODERNISATION WORKS               |
| Maharashtra    | CHANDRAPUR (MAHARASHTRA) STPS | 6        | 0.00                     | 0.00                            | 500.00                          | 0.00                    | 26/04/2025 13:15                                   |                                                       | WATER WALL TUBE LEAKAGE                      |
| Maharashtra    | CHANDRAPUR (MAHARASHTRA) STPS | 9        | 0.00                     | 500.00                          | 0.00                            | 0.00                    | 11/01/2025 18:55                                   |                                                       | GENERATOR PROTECTION RELAY OPERATION PROBLEM |
| Maharashtra    | PARLI TPS                     | 8        | 0.00                     | 0.00                            | 250.00                          | 0.00                    | 30/04/2025 14:51                                   |                                                       | WATER WALL TUBE LEAKAGE                      |

## DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 01-05-2025

Sub-Report-10

| State/System         | Power Station             | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status           |
|----------------------|---------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|----------------------------------|
| 1                    | 2                         | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                               |
| Maharashtra          | BUTIBORI TPP              | 1        | 0.00                     | 300.00                          | 0.00                            | 0.00                    | 29/12/2018 00:30                                   |                                                       | COAL SHORTAGE                    |
| Maharashtra          | BUTIBORI TPP              | 2        | 0.00                     | 300.00                          | 0.00                            | 0.00                    | 17/01/2019 00:15                                   |                                                       | COAL SHORTAGE                    |
| Maharashtra          | GEPL TPP Ph-I             | 1        | 0.00                     | 0.00                            | 0.00                            | 60.00                   | 29/06/2013 00:00                                   |                                                       | NO Power purchase agreement      |
| Maharashtra          | GEPL TPP Ph-I             | 2        | 0.00                     | 0.00                            | 0.00                            | 60.00                   | 20/06/2013 20:27                                   |                                                       | NO Power purchase agreement      |
| Maharashtra          | MIHAN TPS                 | 1        | 0.00                     | 0.00                            | 0.00                            | 61.51                   | 10/01/2013 15:50                                   |                                                       | NO Power purchase agreement      |
| Maharashtra          | MIHAN TPS                 | 2        | 0.00                     | 0.00                            | 0.00                            | 61.50                   | 05/11/2013 11:53                                   |                                                       | NO Power purchase agreement      |
| Maharashtra          | MIHAN TPS                 | 3        | 0.00                     | 0.00                            | 0.00                            | 61.50                   | 10/06/2013 18:00                                   |                                                       | NO Power purchase agreement      |
| Maharashtra          | MIHAN TPS                 | 4        | 0.00                     | 0.00                            | 0.00                            | 61.50                   | 20/08/2013 10:00                                   |                                                       | NO Power purchase agreement      |
| Maharashtra          | NASIK (P) TPS             | 1        | 0.00                     | 0.00                            | 0.00                            | 270.00                  | 04/03/2014 18:10                                   |                                                       | NO Power purchase agreement      |
| Maharashtra          | NASIK (P) TPS             | 2        | 0.00                     | 0.00                            | 0.00                            | 270.00                  | 16/02/2017 00:46                                   |                                                       | NO Power purchase agreement      |
| Maharashtra          | NASIK (P) TPS             | 3        | 0.00                     | 0.00                            | 0.00                            | 270.00                  | 14/04/2017 01:45                                   |                                                       | NO Power purchase agreement      |
| Maharashtra          | NASIK (P) TPS             | 4        | 0.00                     | 0.00                            | 0.00                            | 270.00                  | 20/05/2017 00:25                                   |                                                       | NO Power purchase agreement      |
| Maharashtra          | NASIK (P) TPS             | 5        | 0.00                     | 0.00                            | 0.00                            | 270.00                  | 30/05/2017 15:24                                   |                                                       | NO Power purchase agreement      |
| <b>Total Western</b> |                           |          | <b>2,310.00</b>          | <b>2,235.00</b>                 | <b>3,530.00</b>                 | <b>1,911.01</b>         |                                                    |                                                       |                                  |
| <b>Southern</b>      |                           |          |                          |                                 |                                 |                         |                                                    |                                                       |                                  |
| Andhra Pradesh       | DAMODARAM SANJEEVAIAH TPS | 2        | 0.00                     | 0.00                            | 800.00                          | 0.00                    | 30/04/2025 11:23                                   |                                                       | BOILER MISC. PROBLEM             |
| Andhra Pradesh       | THAMMINAPATNAM TPS        | 1        | 0.00                     | 0.00                            | 150.00                          | 0.00                    | 27/04/2025 06:06                                   |                                                       | BOILER MISC. PROBLEM             |
| Andhra Pradesh       | VIZAG TPP                 | 2        | 0.00                     | 520.00                          | 0.00                            | 0.00                    | 01/04/2025 23:12                                   |                                                       | GEN. TRANSORMER PROTECTION RELAY |

## DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 01-05-2025

Sub-Report-10

| State/System   | Power Station      | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status            |
|----------------|--------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-----------------------------------|
| 1              | 2                  | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                |
| Andhra Pradesh | VIZAG TPP          | 2        | 0.00                     | 520.00                          | 0.00                            | 0.00                    | 01/04/2025 23:12                                   |                                                       | OPERATION PROBLEM                 |
| Karnataka      | KAIGA              | 1        | 220.00                   | 0.00                            | 0.00                            | 0.00                    | 31/03/2025 23:11                                   |                                                       | MISCELLANEOUS PLANNED MAINTENANCE |
| Karnataka      | RAICHUR TPS        | 1        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 15/03/2024 00:00                                   |                                                       | COAL FEEDING SYSTEM FAILURE.      |
| Karnataka      | RAICHUR TPS        | 3        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 10/04/2025 15:53                                   |                                                       | WATER WALL TUBE LEAKAGE           |
| Karnataka      | RAICHUR TPS        | 4        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 09/11/2024 15:57                                   |                                                       | REHEATER TUBE LEAKAGE             |
| Karnataka      | RAICHUR TPS        | 7        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 01/05/2025 19:05                                   |                                                       | WATER WALL TUBE LEAKAGE           |
| Karnataka      | YERMARUS TPP       | 2        | 0.00                     | 0.00                            | 800.00                          | 0.00                    | 28/04/2025 05:30                                   |                                                       | ABNORMAL SOUND                    |
| Tamil Nadu     | NEYVELI NEW TPP    | 1        | 0.00                     | 0.00                            | 500.00                          | 0.00                    | 01/05/2025 20:31                                   |                                                       | BOILER AUX. MISC. PROMLEMS        |
| Tamil Nadu     | NEYVELI TPS-II     | 1        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 28/04/2025 14:33                                   |                                                       | MILLING SYSTEM /RC FEEDER PROBLEM |
| Tamil Nadu     | NEYVELI TPS-II     | 3        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 16/03/2025 02:38                                   |                                                       | ELECTRICAL MISCELLANEOUS PROBLEMS |
| Tamil Nadu     | NEYVELI TPS-II     | 4        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 18/04/2025 12:14                                   |                                                       | AIR PREHEATERS PROBLEM            |
| Tamil Nadu     | NEYVELI TPS-II     | 7        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 24/04/2025 09:09                                   |                                                       | MILLING SYSTEM /RC FEEDER PROBLEM |
| Tamil Nadu     | NEYVELI TPS-II EXP | 1        | 250.00                   | 0.00                            | 0.00                            | 0.00                    | 14/09/2024 23:59                                   |                                                       | CAPITAL MAINTENANCE               |
| Tamil Nadu     | MADRAS A.P.S.      | 1        | 0.00                     | 220.00                          | 0.00                            | 0.00                    | 30/01/2018 16:30                                   |                                                       | REACTOR MAINTENANCE WORKS.        |
| Tamil Nadu     | METTUR TPS         | 3        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 19/12/2024 16:33                                   |                                                       | COLLAPSE OF R.C. BUNKER           |
| Tamil Nadu     | NORTH CHENNAI TPS  | 1        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 26/04/2025 11:44                                   |                                                       | GENERATOR PROTECTION              |
| Tamil Nadu     | NORTH CHENNAI TPS  | 4        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 01/03/2025 11:14                                   |                                                       | TURBINE MISC. PROBLEM             |
| Tamil Nadu     | TUTICORIN TPS      | 1        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 15/03/2025 21:50                                   |                                                       | FIRE IN CABLE GALLERY.            |
| Tamil Nadu     | TUTICORIN TPS      | 2        | 0.00                     | 210.00                          | 0.00                            | 0.00                    | 15/03/2025 22:01                                   |                                                       | FIRE IN CABLE GALLERY             |

## DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 01-05-2025

Sub-Report-10

| State/System          | Power Station            | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status              |
|-----------------------|--------------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-------------------------------------|
| 1                     | 2                        | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                  |
| Tamil Nadu            | TUTICORIN TPS            | 5        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 01/05/2025 00:07                                   |                                                       | BOILER AUX. MISC. PROMLEMS          |
| Tamil Nadu            | MUTHIARA TPP             | 2        | 0.00                     | 600.00                          | 0.00                            | 0.00                    | 13/04/2025 12:15                                   |                                                       | TURBINE BEARING PROBLEM             |
| Tamil Nadu            | TCP Limited              | 1        | 63.50                    | 0.00                            | 0.00                            | 0.00                    | 16/07/2021 05:21                                   |                                                       | MISCELLANEOUS PLANNED MAINTENANCE   |
| Tamil Nadu            | TUTICORIN (P) TPP        | 1        | 0.00                     | 0.00                            | 0.00                            | 150.00                  | 03/04/2016 00:31                                   |                                                       | NO Power purchase agreement         |
| Tamil Nadu            | TUTICORIN (P) TPP        | 2        | 0.00                     | 0.00                            | 0.00                            | 150.00                  | 16/04/2016 01:42                                   |                                                       | NO Power purchase agreement         |
| Telangana             | RAMAGUNDEM-B TPS         | 1        | 0.00                     | 62.50                           | 0.00                            | 0.00                    | 04/06/2024 20:24                                   |                                                       | COAL FEEDING PROBLEM IN PLANT       |
| Telangana             | SINGARENI TPP            | 2        | 0.00                     | 0.00                            | 600.00                          | 0.00                    | 30/04/2025 19:34                                   |                                                       | WATER WALL TUBE LEAKAGE             |
| <b>Total Southern</b> |                          |          | <b>533.50</b>            | <b>3,472.50</b>                 | <b>4,110.00</b>                 | <b>300.00</b>           |                                                    |                                                       |                                     |
| <b>Eastern</b>        |                          |          |                          |                                 |                                 |                         |                                                    |                                                       |                                     |
| Bihar                 | BARAUNI TPS              | 6        | 105.00                   | 0.00                            | 0.00                            | 0.00                    | 22/07/2023 12:05                                   |                                                       | UNIT LIKELY TO BE SCRAPPED.         |
| Bihar                 | BARAUNI TPS              | 7        | 105.00                   | 0.00                            | 0.00                            | 0.00                    | 19/07/2023 15:30                                   |                                                       | UNIT LIKELY TO BE SCRAPPED.         |
| Bihar                 | BARH STPS                | 5        | 0.00                     | 0.00                            | 660.00                          | 0.00                    | 27/04/2025 23:30                                   |                                                       | WATER WALL TUBE LEAKAGE             |
| Jharkhand             | BOKARO TPS `A` EXP       | 1        | 500.00                   | 0.00                            | 0.00                            | 0.00                    | 25/03/2025 00:00                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| Jharkhand             | CHANDRAPURA (DVC) TPS    | 8        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 28/04/2025 23:39                                   | 01/05/2025 04:50                                      | WATER WALL TUBE LEAKAGE             |
| Jharkhand             | TENUGHAT TPS             | 2        | 210.00                   | 0.00                            | 0.00                            | 0.00                    | 20/04/2025 22:46                                   |                                                       | CAPITAL MAINTENANCE                 |
| Odisha                | JSW Energy Utkal Limited | 2        | 0.00                     | 0.00                            | 350.00                          | 0.00                    | 26/04/2025 04:29                                   |                                                       | P.A. FANS PROBLEM                   |
| Odisha                | KAMALANGA TPS            | 1        | 0.00                     | 0.00                            | 350.00                          | 0.00                    | 01/05/2025 00:14                                   |                                                       | P.A. FANS PROBLEM                   |
| West Bengal           | MEJIA TPS                | 3        | 0.00                     | 0.00                            | 210.00                          | 0.00                    | 01/05/2025 17:49                                   | 01/05/2025 18:45                                      | ELECTRICAL MISCELLANEOUS PROBLEMS   |
| West Bengal           | MEJIA TPS                | 5        | 0.00                     | 0.00                            | 250.00                          | 0.00                    | 30/04/2025 12:48                                   |                                                       | WATER WALL TUBE LEAKAGE             |

| State/System  | Power Station      | Unit No. | Planned Maintenance (MW) | Forced Maintenance (Major) (MW) | Forced Maintenance (Minor) (MW) | Others Maintenance (MW) | Date& Time of Maintenance<br>DD/MM/YYYY<br>HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY<br>HH24:MM | Reasons/Present Status              |
|---------------|--------------------|----------|--------------------------|---------------------------------|---------------------------------|-------------------------|----------------------------------------------------|-------------------------------------------------------|-------------------------------------|
| 1             | 2                  | 3        | 4                        | 5                               | 6                               | 7                       | 8                                                  | 9                                                     | 10                                  |
| West Bengal   | RAGHUNATHPUR TPP   | 1        | 0.00                     | 0.00                            | 0.00                            | 0.00                    | 01/05/2025 07:59                                   | 01/05/2025 13:37                                      | F.D. FANS PROBLEM                   |
| West Bengal   | DISHERGARH TPP     | 1        | 12.00                    | 0.00                            | 0.00                            | 0.00                    | 11/12/2024 12:13                                   |                                                       | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| West Bengal   | HIRANMAYE TPP      | 1        | 0.00                     | 0.00                            | 150.00                          | 0.00                    | 26/04/2025 00:23                                   |                                                       | GENRATOR VIBRATIONS                 |
| West Bengal   | SOUTHERN REPL. TPS | 1        | 0.00                     | 0.00                            | 67.50                           | 0.00                    | 01/05/2025 01:08                                   |                                                       | RESERVE SHUT DOWN /<br>STANDBY UNIT |
| West Bengal   | SOUTHERN REPL. TPS | 2        | 0.00                     | 0.00                            | 67.50                           | 0.00                    | 30/04/2025 12:05                                   |                                                       | RESERVE SHUT DOWN /<br>STANDBY UNIT |
| West Bengal   | TITAGARH TPS       | 1        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 10/10/2016 04:57                                   |                                                       | RESERVE SHUT DOWN /<br>STANDBY UNIT |
| West Bengal   | TITAGARH TPS       | 2        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 09/10/2016 04:57                                   |                                                       | RESERVE SHUT DOWN /<br>STANDBY UNIT |
| West Bengal   | TITAGARH TPS       | 3        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 10/10/2016 04:18                                   |                                                       | RESERVE SHUT DOWN /<br>STANDBY UNIT |
| West Bengal   | TITAGARH TPS       | 4        | 0.00                     | 60.00                           | 0.00                            | 0.00                    | 09/10/2016 05:36                                   |                                                       | RESERVE SHUT DOWN /<br>STANDBY UNIT |
| Total Eastern |                    |          | 932.00                   | 240.00                          | 2,105.00                        | 0.00                    |                                                    |                                                       |                                     |
| Total         |                    |          | 5,780.50                 | 7,777.50                        | 12,035.00                       | 2,211.01                |                                                    |                                                       |                                     |

Remarks:-

Report Version :-