

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 01-05-2025

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
GH TPS (LEH.MOH.)	3	250.00	01/05/2025 22:31		RSD/LOW SCHEDULE
ROPAR TPS	4	210.00	01/05/2025 21:45		RSD/LOW SCHEDULE
ANTA CCPP	2	88.71	01/05/2025 00:12	01/05/2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	01/05/2025 11:30	01/05/2025	NO/REDUCED IRRIGATION DEMAND
ANTA CCPP	4	153.20	01/05/2025 00:43	01/05/2025	CONSERVATION OF MAIN FUEL/RSD
RAMGARH CCPP	2	35.50	01/05/2025 17:48		GRID FAILURE
RAMGARH CCPP	3	37.50	01/05/2025 18:13		STATION TRANSFORMER PROBLEM
RAMGARH CCPP	4	37.50	01/05/2025 09:12		TURBINE BEARING TEMP. HIGH
RAMGARH CCPP	4		01/05/2025 17:48		GRID FAILURE
JALIPA KAPURDI TPP	1	135.00	01/05/2025 15:57		BOILER MISC. PROBLEM
JALIPA KAPURDI TPP	1		01/05/2025 04:11		P.A. FANS PROBLEM
DADRI CCPP	3	130.19	01/05/2025 00:18	01/05/2025	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	6	154.51	01/05/2025 00:08	01/05/2025	CONSERVATION OF MAIN FUEL/RSD
ADANI POWER LIMITED RAIPUR TPP	2	685.00	01/05/2025 16:44		TRANSMISSION CONSTRAINTS
GANDHAR CCPP	1	144.30	01/05/2025 00:16	01/05/2025	CONSERVATION OF MAIN FUEL/RSD
BHAVNAGAR CFBC TPP	2	250.00	01/05/2025 19:45		WATER WALL TUBE LEAKAGE
UTRAN CCPP	5	240.00	01/05/2025 16:30		RESERVE SHUT DOWN
UTRAN CCPP	6	134.00	01/05/2025 16:27		RESERVE SHUT DOWN
VINDHYACHAL STPS	11	500.00	01/05/2025 00:04		BOILER OVERHAUL/ ANNUAL MAINTENANCE
RATNAGIRI CCPP	5	213.00	01/05/2025 12:15		GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	6	237.54	01/05/2025 12:14		GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	7	213.00	01/05/2025 00:41		GT-MISCELLANEOUS PROBLEMS
URAN CCPP	5	108.00	01/05/2025 04:28		BOILER AUX. MISC. PROMLEMS
URAN CCPP	5		01/05/2025 22:36	02/05/2025	BEARING
URAN CCPP	6	108.00	01/05/2025 04:25		BOILER MISC. PROBLEM
URAN CCPP	9	120.00	01/05/2025 00:56		ROTOR EARTH FAULT
RAICHUR TPS	7	210.00	01/05/2025 19:05		WATER WALL TUBE LEAKAGE
NEYVELI NEW TPP	1	500.00	01/05/2025 20:31		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	5	210.00	01/05/2025 00:07		BOILER AUX. MISC. PROMLEMS
KAMALANGA TPS	1	350.00	01/05/2025 00:14		P.A. FANS PROBLEM
MEJIA TPS	3	210.00	01/05/2025 17:49		ELECTRICAL MISCELLANEOUS PROBLEMS
RAGHUNATHPUR TPP	1	600.00	01/05/2025 07:59		F.D. FANS PROBLEM

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
SOUTHERN REPL. TPS	1	67.50	01/05/2025 01:08	02/05/2025	RESERVE SHUT DOWN / STANDBY UNIT
KATHALGURI CCPP	4	33.50	01/05/2025 00:00		MISCELLANEOUS
KATHALGURI CCPP	8	30.00	01/05/2025 00:00		MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	6	9.96	01/05/2025 00:30		GRID DISTURBANCES MISC.
AGARTALA GT	3	21.00	01/05/2025 00:00		Fuel Shortage
AGARTALA GT	4	21.00	01/05/2025 00:00		Fuel Shortage
AGARTALA GT	6	25.50	01/05/2025 00:00		Fuel Shortage
Total		6562.12			