

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: null

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
BALCO TPS	1	300.0	01/11/2018 20.18.00		I.D. FANS PROBLEM
MUNDRA UMTTP	3	800.0	01/11/2018 01.10.00		ELECTRICAL MISCELLANEOUS PROBLEMS
SATPURA TPS	9	210.0	01/11/2018 12.35.00		AIR PREHEATERS PROBLEM
SASAN UMTTP	2	660.0	01/11/2018 12.00.00	04/11/2018 00.00.00	ECONOMISER TUBE LEAKAGE
PARLI TPS	6	250.0	01/11/2018 11.24.00		GENERATOR PROTECTION RELAY OPERATION PROBLEM
WARDHA WARORA TPP	3	135.0	01/11/2018 00.28.00		WATER WALL TUBE LEAKAGE
NORTH CHENNAI TPS	3	210.0	01/11/2018 12.03.00		ECONOMISER TUBE LEAKAGE
TUTICORIN TPS	2	210.0	01/11/2018 22.28.00	06/11/2018 00.00.00	RSD/LOW SCHEDULE
VALANTARVY CCPP	2	14.8	01/11/2018 14.26.00	01/11/2018 00.00.00	INSTRUMENTATION PROBLEM
KAKATIYA TPS	2	600.0	01/11/2018 04.27.00		FURNACE FIRE OUT /FLAME FAILURE
KAHALGAON TPS	7	500.0	01/11/2018 06.07.00		DRUM LEVEL LOW
BOKARO `B` TPS	3	210.0	01/11/2018 06.50.00		FURNACE FIRE OUT /FLAME FAILURE
TALCHER (OLD) TPS	4	60.0	01/11/2018 00.48.00		TURBINE MISC. PROBLEM
KOLAGHAT TPS	4	210.0	01/11/2018 21.19.00		COAL SHORTAGE
LAKWA REPLACEMENT POWER PROJECT	1	9.965	01/11/2018 03.54.00	02/11/2018 00.00.00	L.T.SUPPLY FAILURE.
LAKWA REPLACEMENT POWER PROJECT	3	9.965	01/11/2018 03.54.00		L.T.SUPPLY FAILURE.
LAKWA REPLACEMENT POWER PROJECT	4	9.965	01/11/2018 03.54.00		L.T.SUPPLY FAILURE.
LAKWA REPLACEMENT POWER PROJECT	5	9.965	01/11/2018 03.54.00		L.T.SUPPLY FAILURE.
LAKWA REPLACEMENT POWER PROJECT	6	9.965	01/11/2018 03.54.00		L.T.SUPPLY FAILURE.
LAKWA REPLACEMENT POWER PROJECT	7	9.965	01/11/2018 03.54.00		L.T.SUPPLY FAILURE.
Total		4429.5900000			