

CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION

**THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2026-27 as on: 02-Jun-2026**

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
PRAGATI CCPP	1		7/9/25, 5:36 PM	09-07-2025	GRID DISTURBENCE
PRAGATI CCPP	1	104.60	6/29/25, 4:39 AM	29-06-2025	GRID DISTURBENCE
PRAGATI CCPP	1		7/25/25, 10:15 AM	26-07-2025	GT- LUB OIL SYSTEM PROB.
PRAGATI CCPP	1		7/28/25, 4:31 PM	28-07-2025	MISCELLANOUS
PRAGATI CCPP	1		7/17/25, 10:45 PM	25-07-2025	Low system demand/ costly fuel
PRAGATI CCPP	1		12/31/25, 3:02 AM	01-01-2026	GT-MISCELLANEOUS PROBLEMS
PRAGATI CCPP	2		5/12/26, 10:45 PM	15-05-2026	GT-MISCELLANEOUS PROBLEMS
PRAGATI CCPP	2		12/14/25, 7:35 AM	14-12-2025	MINOR MAINTENANCE WORKS
PRAGATI CCPP	2	104.60	5/15/26, 7:44 PM	18-05-2026	Low system demand/ costly fuel
PRAGATI CCPP	2		6/15/25, 3:53 AM	15-06-2025	GRID DISTURBENCE
RAJIV GANDHI TPS	2	600.00	10/6/25, 10:33 PM		Turbine Misc
MAHATMA GANDHI TPS	2	660.00	10/16/25, 11:52 PM		WATER WALL TUBE LEAKAGE
FARIDABAD CCPP	1		3/2/26, 8:04 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	1		5/8/26, 11:44 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	1		4/28/26, 11:21 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	1	137.76	5/15/26, 11:42 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2		5/15/26, 11:42 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2		3/2/26, 8:04 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2		4/28/26, 11:21 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	5/8/26, 11:44 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3		2/24/26, 8:35 PM	23-04-2026	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3	156.07	4/26/26, 2:35 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
ROPAR TPS	4	210.00	10/17/25, 10:35 AM		FURNACE DRAFT ABNORMAL
ROPAR TPS	4		3/14/26, 10:56 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
ROPAR TPS	5	210.00	10/17/25, 3:22 PM		REHEATER TUBE LEAKAGE
ROPAR TPS	6	210.00	8/10/25, 7:25 AM		REHEATER TUBE LEAKAGE
KOTA TPS	2	110.00	10/28/25, 5:55 AM		BOILER AUX. MISC. PROMLEMS
SURATGARH TPS	6	250.00	6/2/25, 7:48 AM		RSD/LOW SCHEDULE
JALIPA KAPURDI TPP	8	135.00	4/26/26, 2:11 AM		BOILER MISC. PROBLEM

**THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2026-27 as on: 02-Jun-2026**

Sub - Report 12

<b>Station</b>	<b>Unit No.</b>	<b>Capacity(MW)</b>	<b>Date&amp; Time of Maintenance DD/MM/YYYY HH24:MM</b>	<b>Expected/sync Date of Return DD/MM/YYYY HH24:MM</b>	<b>Reasons/Present Status</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6</b>
ANTA CCPP	1		5/8/26, 11:45 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	1		3/2/26, 8:05 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	1		4/28/26, 11:27 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	1	88.71	5/15/26, 11:40 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2		3/2/26, 8:05 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2		5/8/26, 11:46 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	4/28/26, 11:28 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2		5/15/26, 11:41 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3		5/8/26, 11:46 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3		3/2/26, 8:05 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3		5/15/26, 11:41 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	4/28/26, 11:28 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	4	153.20	4/26/26, 3:03 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	4		4/13/26, 12:00 AM	23-04-2026	CONSERVATION OF MAIN FUEL/RSD
SHREE CEMENT LTD TPS	2	150.00	4/25/26, 4:20 PM		P.A. FANS PROBLEM
JAWAHARPUR STPP	2	660.00	3/18/26, 11:03 PM		MAIN STEAM LINE PROBLEM
PANKI TPS EXT	1	660.00	7/9/25, 3:30 PM		ELECTRICAL MISCELLANEOUS PROBLEMS
GHATAMPUR TPP	2	660.00	1/29/26, 7:00 AM	07-02-2026	COAL FEEDING PROBLEM IN PLANT
TANDA TPS	1	110.00	6/30/25, 11:05 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	2	110.00	6/30/25, 11:17 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	3	110.00	8/31/25, 11:58 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	4	110.00	8/31/25, 11:58 PM		RESERVE SHUT DOWN / STANDBY UNIT
AURAIYA CCPP	1		5/8/26, 11:59 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	1		3/24/26, 12:00 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	1		4/28/26, 11:34 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	1	111.19	5/15/26, 11:52 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2		4/28/26, 11:26 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	3/2/26, 8:03 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2		5/15/26, 11:49 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2		5/8/26, 11:57 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	5/8/26, 11:59 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD

**THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2026-27 as on: 02-Jun-2026**

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
AURAIYA CCPP	3		3/2/26, 8:04 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3		5/15/26, 11:50 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3		4/28/26, 11:31 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	4/28/26, 11:26 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4		5/15/26, 11:48 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4		5/8/26, 11:56 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4		3/2/26, 8:03 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5		2/22/26, 12:00 AM	23-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5	109.30	9/20/25, 10:33 PM	15-04-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6		4/26/26, 1:29 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6	109.30	2/2/26, 8:29 AM	23-04-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1		3/2/26, 8:08 AM	18-04-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1		4/28/26, 11:21 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1		5/8/26, 11:37 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	5/15/26, 11:38 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	4/28/26, 11:21 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2		3/2/26, 8:08 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2		5/8/26, 11:41 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2		5/15/26, 11:38 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3		4/28/26, 11:21 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3		3/2/26, 8:09 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	5/15/26, 11:39 PM	16-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3		5/8/26, 11:39 PM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4		3/13/26, 8:00 PM	21-04-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4		5/15/26, 11:37 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4		5/8/26, 11:43 PM	09-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	4/28/26, 11:21 PM	06-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5		4/26/26, 3:15 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	12/27/25, 11:15 AM	22-04-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6	154.51	4/26/26, 2:34 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6		3/13/26, 10:00 AM	23-04-2026	CONSERVATION OF MAIN FUEL/RSD

<b>Station</b>	<b>Unit No.</b>	<b>Capacity(MW)</b>	<b>Date&amp; Time of Maintenance DD/MM/YYYY HH24:MM</b>	<b>Expected/sync Date of Return DD/MM/YYYY HH24:MM</b>	<b>Reasons/Present Status</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6</b>
KUNDARKI TPS	1	45.00	10/11/25, 11:41 PM		RSD/LOW SCHEDULE
KUNDARKI TPS	2	45.00	2/6/26, 4:13 PM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
UTRAULA TPS	1		2/16/26, 12:00 AM		ESP PROBLEM
UTRAULA TPS	1		2/7/26, 10:11 PM		RSD/LOW SCHEDULE
UTRAULA TPS	1	45.00	10/11/25, 11:43 PM		RSD/LOW SCHEDULE
UTRAULA TPS	2	45.00	4/7/26, 8:00 PM		RSD/LOW SCHEDULE
UKAI TPS	3		11/15/25, 3:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
UKAI TPS	3		11/20/25, 12:00 AM		R AND M / REFURBISHMENT works
UKAI TPS	3	200.00	6/26/25, 1:57 PM		TURBINE MISC.
UKAI TPS	3		11/13/25, 10:10 PM		WATER WALL TUBE LEAKAGE
GANDHI NAGAR TPS	3	210.00	7/23/25, 11:28 AM		BOILER MISC. PROBLEM
GANDHI NAGAR TPS	4		7/23/25, 11:53 AM		BOILER MISC. PROBLEM
GANDHI NAGAR TPS	4		11/14/25, 6:54 PM		RSD/LOW SCHEDULE
GANDHI NAGAR TPS	4	210.00	12/20/25, 12:00 AM		SCHEDULED ANNUAL MAINTENANCE
GANDHI NAGAR TPS	5	210.00	11/15/25, 12:02 AM		SCHEDULED ANNUAL MAINTENANCE
UTRAN CCPP	5		3/23/26, 8:00 AM		GT-NO SCHEDULE FROM BENEFICIARIES
UTRAN CCPP	5	240.00	3/23/26, 11:59 PM		BOILER MISC. PROBLEM
UTRAN CCPP	6		3/19/26, 8:00 AM		BOILER INSPECTION/ RE-CERTIFICATION
UTRAN CCPP	6		3/17/26, 7:25 PM		GT-NO SCHEDULE FROM BENEFICIARIES
UTRAN CCPP	6		3/24/26, 12:00 AM		BOILER MISC. PROBLEM
UTRAN CCPP	6	134.00	3/23/26, 8:00 AM		GT-NO SCHEDULE FROM BENEFICIARIES
HAZIRA CCPP EXT	1	351.00	6/15/25, 1:22 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4	40.00	8/26/25, 10:18 PM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	5	376.10	9/11/25, 7:20 PM		RESERVE SHUT DOWN
DHUVARAN CCPP	5		8/12/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
KUTCH LIG. TPS	3		7/29/25, 10:06 AM		WATER WALL TUBE LEAKAGE
KUTCH LIG. TPS	3		1/13/26, 6:00 PM		RSD/LOW SCHEDULE
KUTCH LIG. TPS	3	75.00	1/11/26, 11:32 AM		AIR PREHEATERS PROBLEM
SUGEN CCPP	1	382.50	4/5/26, 12:00 AM	13-04-2026	RSD/LOW SCHEDULE
SUGEN CCPP	2		7/27/25, 12:00 AM		RSD/LOW SCHEDULE
SUGEN CCPP	2	382.50	3/4/26, 12:00 AM	05-03-2026	RSD/LOW SCHEDULE

**THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2026-27 as on: 02-Jun-2026**

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
DGEN MEGA CCPP	3		5/1/26, 1:05 PM	14-01-2025	GT-NO SCHEDULE FROM BENEFICIARIES
DGEN MEGA CCPP	3	400.00	5/3/26, 12:10 AM	01-04-2025	GT-NO SCHEDULE FROM BENEFICIARIES
SURAT LIG. TPS	2	125.00	7/28/25, 4:27 AM		WATER WALL TUBE LEAKAGE
KAWAS CCPP	1	106.00	5/16/26, 12:27 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1		5/9/26, 12:13 AM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1		4/1/26, 12:00 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1		4/28/26, 11:59 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2		4/28/26, 11:57 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2		5/16/26, 12:28 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2		4/1/26, 12:00 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	5/9/26, 12:03 AM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3		5/9/26, 12:00 AM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3		4/28/26, 11:54 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3		4/1/26, 12:00 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.00	5/16/26, 12:26 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	4/1/26, 12:00 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4		5/16/26, 12:31 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4		5/9/26, 12:07 AM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4		4/28/26, 11:56 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	5		4/21/26, 12:00 AM	23-04-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	5	116.10	4/26/26, 2:21 AM	12-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	5		5/13/26, 11:11 PM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6		4/21/26, 12:00 AM	23-04-2026	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6	116.10	4/26/26, 2:22 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1		5/16/26, 12:38 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1		4/1/26, 12:00 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1	144.30	5/9/26, 12:06 AM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1		4/28/26, 11:58 PM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2		5/4/26, 12:00 AM	07-05-2026	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	4/1/26, 12:00 AM	20-04-2026	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2		5/9/26, 12:08 AM	10-05-2026	CONSERVATION OF MAIN FUEL/RSD

**THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2026-27 as on: 02-Jun-2026**

Sub - Report 12

<b>Station</b>	<b>Unit No.</b>	<b>Capacity(MW)</b>	<b>Date&amp; Time of Maintenance DD/MM/YYYY HH24:MM</b>	<b>Expected/sync Date of Return DD/MM/YYYY HH24:MM</b>	<b>Reasons/Present Status</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6</b>
GANDHAR CCPP	2		5/16/26, 12:28 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4	224.49	4/13/26, 12:00 AM	13-04-2026	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4		4/1/26, 12:00 AM	23-04-2026	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4		4/26/26, 2:11 AM	17-05-2026	CONSERVATION OF MAIN FUEL/RSD
KORBA-WEST TPS	3	210.00	4/18/26, 10:59 AM		INSTRUMENT AIR SYSTEM FAILURE
KORBA-WEST TPS	4	210.00	4/22/26, 2:07 PM		ASH HANDLING SYSTEM PROBLEM
KORBA-WEST TPS	5	500.00	4/10/26, 12:36 PM	10-04-2026	WATER WALL TUBE LEAKAGE
SANJAY GANDHI TPS	4	210.00	4/16/26, 1:13 PM		STATOR/ STATOR EARTH FAULT
KORBA STPS	5	500.00	5/15/26, 12:07 PM	02-06-2026	OVERHAULING WORKS
VINDHYACHAL STPS	1	210.00	5/7/26, 1:04 AM	02-06-2026	OVERHAULING WORKS
PATHADI TPP	2	300.00	12/7/25, 3:30 AM		BOILER MISC. PROBLEM
JSW Mahanadi Power Company Limited	2	600.00	10/11/25, 9:00 PM		RESERVE SHUT DOWN / STANDBY UNIT
Vedanta Ltd Chhattisgarh TPP	1	600.00	4/14/26, 2:33 PM		P.A. FANS PROBLEM
URAN CCPP	5	108.00	2/18/26, 3:09 PM	18-02-2026	INSTRUMENTATION PROBLEM
URAN CCPP	6	108.00	4/6/26, 6:10 AM		BOILER AUX. MISC. PROMLEMS
URAN CCPP	9	120.00	4/21/26, 9:37 PM		TURBINE VIBRATIONS HIGH
KOTHAGUDEM TPS (NEW)	10	250.00	1/25/26, 6:30 AM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	2	210.00	7/22/25, 7:05 PM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	2		8/26/25, 1:12 PM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	3		8/31/25, 2:00 PM		ECONOMISER TUBE LEAKAGE
RAYALASEEMA TPS	3	210.00	8/27/25, 2:57 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAYALASEEMA TPS	4	210.00	8/12/25, 4:49 AM		ECONOMISER TUBE LEAKAGE
RAYALASEEMA TPS	5	210.00	10/1/25, 9:35 AM		TURBINE VIBRATIONS HIGH
RAYALASEEMA TPS	5		3/17/26, 1:41 AM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
RAYALASEEMA TPS	5		1/13/26, 12:18 PM		AIR PREHEATERS PROBLEM
SIMHAPURI TPS	3	150.00	10/19/25, 12:06 AM		P.A. FANS PROBLEM
MEENAKSHI ENERGY LTD	1	150.00	5/15/26, 12:02 AM		MAIN STEAM LINE PROBLEM
MEENAKSHI ENERGY LTD	1		9/1/25, 3:01 PM	08-02-2026	BOILER MISC. PROBLEM
VIZAG TPP	2	520.00	9/27/25, 11:31 PM		MISCELLANEOUS
VIZAG TPP	2		10/18/25, 2:31 AM		GEN.PROTECTION RELAY OPERATION
RAMAGUNDEM STPS	1	200.00	3/22/26, 10:29 AM		RSD/LOW SCHEDULE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RAMAGUNDEM STPS	6	500.00	3/5/26, 1:12 AM	11-03-2026	SUPER HEATER TUBE LEAKAGE
TELANGANA STPP PH-1	1	800.00	3/21/26, 10:51 AM		RSD/LOW SCHEDULE
TELANGANA STPP PH-1	2	800.00	3/28/26, 10:20 AM		RSD/LOW SCHEDULE
YADADRI TPS	2	800.00	10/20/25, 9:05 PM		BREAKER/ISOLATOR PROBLEM
YADADRI TPS	4	800.00	4/30/26, 4:48 PM		ECONOMISER TUBE LEAKAGE
RAICHUR TPS	5	210.00	8/31/25, 9:12 AM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	5		8/14/25, 9:34 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	6	210.00	2/14/26, 12:44 AM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
RAICHUR TPS	7	210.00	7/27/25, 8:07 AM		RSD/LOW SCHEDULE
RAICHUR TPS	8	250.00	8/7/25, 8:45 AM	08-08-2025	ECONOMISER TUBE LEAKAGE
TUTICORIN TPS	3		11/2/25, 10:55 AM	03-11-2025	TURBINE PIPES AND VALVES PROBLEM
TUTICORIN TPS	3	210.00	8/15/25, 11:29 AM		DRUM LEVEL HIGH/ low
TUTICORIN TPS	4		10/31/25, 3:04 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	4		7/15/25, 8:02 PM		CONDENSER LOW VACCUM
TUTICORIN TPS	4	210.00	9/18/25, 7:16 PM		CONDENSER TUBE LEAKAGE/ CLEANING
TUTICORIN TPS	5		9/14/25, 10:48 AM		CONDENSER TUBE LEAKAGE/ CLEANING
TUTICORIN TPS	5	210.00	4/25/26, 3:08 PM		WATER WALL TUBE LEAKAGE
BASIN BRIDGE GT (Liq.)	3	30.00	4/21/26, 9:37 AM	22-04-2026	TURBINE OIL SYSTEM PROBLEM
VALUTHUR CCPP	3	59.80	3/18/26, 9:52 AM		MISCELLANEOUS PLANNED MAINTENANCE
VALUTHUR CCPP	4	32.40	3/18/26, 9:34 AM		MISCELLANEOUS PLANNED MAINTENANCE
TUTICORIN (P) TPP	2	150.00	5/9/26, 5:14 AM		TURBINE VIBRATIONS HIGH
MUTHIARA TPP	1	600.00	10/10/25, 1:20 AM		MILLING SYSTEM /RC FEEDER PROBLEM
NEYVELI TPS-II	1		5/12/26, 4:30 PM		BOILER MISC. PROBLEM
NEYVELI TPS-II	1		12/2/25, 7:59 AM		I.D. FANS PROBLEM
NEYVELI TPS-II	1		5/14/26, 12:00 AM		SCHEDULED ANNUAL MAINTENANCE
NEYVELI TPS-II	1	210.00	5/7/26, 3:00 PM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	2	210.00	8/18/25, 5:20 PM		MILLING SYSTEM /RC FEEDER PROBLEM
NEYVELI TPS-II	3	210.00	11/24/25, 9:20 AM		COAL FEEDING PROBLEM IN PLANT
NEYVELI TPS-II	4	210.00	11/15/25, 10:22 AM		WATER WALL TUBE LEAKAGE
NEYVELI TPS-II	5	210.00	10/19/25, 11:38 AM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	6		12/1/25, 3:30 PM		BOILER AUX. MISC. PROMLEMS

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
NEYVELI TPS-II	6	210.00	11/28/25, 11:58 PM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	7	210.00	1/4/26, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II EXP	2	250.00	5/17/26, 12:00 AM		RSD/LOW SCHEDULE
KUDANKULAM	1		8/3/25, 12:00 AM	30-09-2025	ANNUAL MAINTENANCE
KUDANKULAM	1		10/3/25, 12:30 AM	07-10-2025	MISC. SHORT DURATION PLANNED MAINTENANCE
KUDANKULAM	1	1,000.00	8/1/25, 4:30 AM		RSD/LOW SCHEDULE
ITPCL TPP	1	600.00	5/5/26, 10:27 PM		RESERVE SHUT DOWN / STANDBY UNIT
NABINAGAR TPP	1	250.00	12/4/25, 10:25 AM		STATOR/ STATOR EARTH FAULT
NABINAGAR TPP	2	250.00	12/31/25, 1:30 AM	10-01-2026	GENERATOR STATOR DAMAGED
PATRATU STPP	2	800.00	5/13/26, 12:23 PM		MISCELLANEOUS PLANNED MAINTENANCE
RAGHUNATHPUR TPP	2	600.00	4/14/26, 5:51 PM		TURBINE VIBRATIONS HIGH
FARAKKA STPS	2	200.00	5/8/26, 11:51 PM	09-05-2026	WATER WALL TUBE LEAKAGE
NAMRUP CCPP	2	17.00	8/6/25, 9:14 AM		GENERATOR TRANSFORMER MISC.
NAMRUP CCPP	6	9.00	8/6/25, 9:10 AM		GT-MISCELLANEOUS PROBLEMS
NAMRUP CCPP	8	36.15	4/17/26, 12:01 AM		MISCELLANEOUS PLANNED MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	3	9.96	10/14/25, 8:59 PM		GRID DISTURBENCE
KATHALGURI CCPP	2	33.50	7/16/25, 11:59 PM		LOW SYSTEM DEMAND
KATHALGURI CCPP	2		7/16/25, 12:00 AM		LOW SYSTEM DEMAND
TRIPURA CCPP	2	363.30	3/14/26, 9:10 AM		GENERATOR MISCELLANEOUS MAINTENANCE
MONARCHAK CCPP	2	35.60	7/18/25, 12:14 AM		ROTOR EARTH FAULT
<b>Total</b>		29,986.36			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.

2.Data published in this report is for operational purpose only and not for commercial purpose.

3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

**Remarks:-**

**Report Version :-**