

DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 02-10-2026

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Haryana	INDIRA GANDHI STPP	2	0.00	0.00	500.00	0.00	02/10/2026 09:55		WET / POOR QUALITY COAL
Rajasthan	KALISINDH TPS	1	0.00	600.00	0.00	0.00	27/08/2026 16:33		FURNACE DRAFT ABNORMAL
Rajasthan	ADANI POWER LIMITED KAWAI TPP	2	0.00	0.00	660.00	0.00	02/10/2026 10:49		TURBINE MISC. PROBLEM
Uttar Pradesh	GHATAMPUR TPP	3	0.00	0.00	660.00	0.00	26/09/2026 17:32		COAL FEEDING PROBLEM IN PLANT
Uttar Pradesh	MEJA STPP	1	0.00	660.00	0.00	0.00	22/08/2026 08:08	02/10/2026 17:18	TURBINE MISC.
Uttar Pradesh	RIHAND STPS	3	500.00	0.00	0.00	0.00	31/08/2026 18:25		OVERHAULING WORKS
Uttar Pradesh	ANPARA TPS	6	0.00	0.00	0.00	0.00	29/09/2026 06:45	02/10/2026 05:59	ECONOMISER TUBE LEAKAGE
Uttar Pradesh	JAWAHARPUR STPP	1	0.00	0.00	660.00	0.00	30/09/2026 14:14		WATER WALL TUBE LEAKAGE
Uttar Pradesh	OBRA TPS	14	0.00	660.00	0.00	0.00	10/07/2026 09:11	02/10/2026 21:27	C&I PROBLEM
Uttar Pradesh	OBRA TPS	15	0.00	660.00	0.00	0.00	12/08/2026 22:36		P.A. FANS PROBLEM
Chhatisgarh	ADANI POWER LIMITED RAIPUR TPP	1	0.00	0.00	685.00	0.00	29/09/2026 13:42	02/10/2026 14:27	CONDENSER TUBE LEAKAGE/ CLEANING
Chhatisgarh	JSW Mahanadi Power Company Limited	2	0.00	0.00	600.00	0.00	02/10/2026 19:10		TURBINE VIBRATIONS HIGH
Chhatisgarh	Vedanta Ltd Chhattisgarh TPP	1	0.00	600.00	0.00	0.00	14/04/2026 14:33		P.A. FANS PROBLEM
Gujarat	UKAI TPS	6	0.00	0.00	500.00	0.00	29/09/2026 12:38		AIR PREHEATERS PROBLEM
Madhya Pradesh	GADARWARA TPP	2	800.00	0.00	0.00	0.00	16/09/2026 00:00		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Madhya Pradesh	VINDHYACHAL STPS	7	0.00	0.00	500.00	0.00	02/10/2026 09:33		WATER WALL TUBE LEAKAGE
Madhya Pradesh	VINDHYACHAL STPS	12	0.00	0.00	500.00	0.00	27/09/2026 00:35		VARIOUS STEAM LEAKAGES

DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 02-10-2026

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Madhya Pradesh	SHREE SINGAJI TPP	1	600.00	0.00	0.00	0.00	25/08/2026 00:56		SCHEDULED ANNUAL MAINTENANCE
Madhya Pradesh	NIGRI TPP	1	0.00	0.00	660.00	0.00	27/09/2026 16:52		ABNORMAL BOILER OPERATIONAL PARAMETER
Madhya Pradesh	SASAN UMTTP	3	0.00	0.00	660.00	0.00	01/10/2026 01:04	02/10/2026 18:49	REHEATER TUBE LEAKAGE
Madhya Pradesh	SASAN UMTTP	5	0.00	0.00	0.00	0.00	02/10/2026 22:30		WATER WALL TUBE LEAKAGE
Maharashtra	KORADI TPS	10	660.00	0.00	0.00	0.00	21/08/2026 01:07		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Andhra Pradesh	SIMHADRI	3	0.00	0.00	0.00	0.00	29/09/2026 00:00	02/10/2026 09:28	VARIOUS STEAM LEAKAGES
Karnataka	KUDGI STPP	1	800.00	0.00	0.00	0.00	22/08/2026 00:00		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Karnataka	BELLARY TPS	3	0.00	0.00	0.00	0.00	01/10/2026 23:16	02/10/2026 06:31	ELECTRICAL FAULT
Karnataka	YERMARUS TPP	2	0.00	0.00	800.00	0.00	02/10/2026 08:47		WATER WALL TUBE LEAKAGE
Karnataka	ADANI POWER LIMITED UDUPI TPP	2	600.00	0.00	0.00	0.00	20/09/2026 23:59		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Tamil Nadu	NORTH CHENNAI TPS STAGE 2	4	0.00	0.00	600.00	0.00	02/10/2026 10:10		WATER WALL TUBE LEAKAGE
Tamil Nadu	NORTH CHENNAI TPS STAGE 3	6	0.00	0.00	0.00	0.00	02/10/2026 03:48	02/10/2026 11:22	CONDENSER LOW VACCUM
Tamil Nadu	UDANGUDI TPP	1	0.00	0.00	660.00	0.00	17/09/2026 14:38		TURB. AXIAL SHIFT/ THRUST PAD
Tamil Nadu	MUTHIARA TPP	2	600.00	0.00	0.00	0.00	07/09/2026 23:50		SCHEDULED ANNUAL MAINTENANCE
Telangana	KOTHAGUDEM TPS (STAGE-7)	12	0.00	0.00	0.00	0.00	02/10/2026 23:10		BOILER AUX. MISC. PROMLEMS
Bihar	KAHALGAON TPS	6	500.00	0.00	0.00	0.00	25/09/2026 00:09		OVERHAULING WORKS
Bihar	NABINAGAR STPP	2	0.00	0.00	660.00	0.00	01/10/2026 19:09		REHEATER TUBE LEAKAGE
Jharkhand	MAITHON RB TPP	1	0.00	0.00	0.00	0.00	02/10/2026 11:26	02/10/2026 15:25	FURNACE FIRE OUT /FLAME FAILURE
Odisha	IB VALLEY TPS	4	660.00	0.00	0.00	0.00	14/09/2026 23:24		SCHEDULED ANNUAL MAINTENANCE

Total	5,720.00	3,180.00	9,305.00	0.00			
-------	----------	----------	----------	------	--	--	--

Remarks:-

Report Version :-