

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 02-Oct-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
FARIDABAD CCPP	1	137.76	10/2/26, 3:03AM		CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	10/2/26, 4:55AM		CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3	156.07	10/2/26, 4:45AM		CONSERVATION OF MAIN FUEL/RSD
SURATGARH TPS	5		10/2/26, 9:40AM		DRUM LEVEL HIGH/ low
SURATGARH TPS	5	250.0	10/1/26, 9:00PM		DRUM LEVEL LOW
JALIPA KAPURDI TPP	6	135.0	9/30/26, 8:56AM		BOILER MISC. PROBLEM
DHOLPUR CCPP	1	110.0	10/2/26, 12:17AM		Low system demand/ costly fuel
DHOLPUR CCPP	2	110.0	10/2/26, 12:17AM		Low system demand/ costly fuel
OBRA TPS	14	660.0	7/10/26, 9:11AM		C&I PROBLEM
ANPARA TPS	6	500.0	9/29/26, 6:45AM		ECONOMISER TUBE LEAKAGE
MEJA STPP	1	660.0	8/22/26, 8:08AM		TURBINE MISC.
AURAIYA CCPP	1	111.19	10/2/26, 1:53AM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	10/2/26, 1:30AM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5	109.3	10/2/26, 1:47AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	10/2/26, 1:40AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	10/2/26, 3:17AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	10/2/26, 1:57AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	10/2/26, 3:11AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6	154.51	10/2/26, 1:50AM		CONSERVATION OF MAIN FUEL/RSD
ADANI POWER LIMITED RAIPUR TPP	1	685.0	9/29/26, 1:42PM		CONDENSER TUBE LEAKAGE/ CLEANING
SASAN UMTTP	3	660.0	10/1/26, 1:04AM		REHEATER TUBE LEAKAGE
UKAI TPS	5	210.0	10/2/26, 8:42AM		FURNACE FIRE OUT /FLAME FAILURE
KAWAS CCPP	1	106.0	10/2/26, 1:38AM		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.0	10/2/26, 1:28AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.3	10/2/26, 2:27AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.3	10/2/26, 2:34AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4	224.49	10/2/26, 2:29AM		CONSERVATION OF MAIN FUEL/RSD
NASIK TPS	5	210.0	9/30/26, 11:46PM		BOILER INSPECTION/ RE-CERTIFICATION
RATNAGIRI CCPP	4	213.0	10/2/26, 7:29AM		GT- LOW SYSTEM DAMAND

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RATNAGIRI CCPP	5	213.0	10/2/26, 8:28AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	6	237.54	10/2/26, 8:28AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	7	213.0	10/2/26, 7:52AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.0	10/2/26, 7:27AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	9	237.54	10/2/26, 7:49AM		GT- LOW SYSTEM DAMAND
BELLARY TPS	3	700.0	10/1/26, 11:16PM		ELECTRICAL FAULT
TUTICORIN TPS	4	210.0	9/30/26, 11:39PM		BOILER AUX. MISC. PROMLEMS
NORTH CHENNAI TPS STAGE 3	6	800.0	10/2/26, 3:48AM		CONDENSER LOW VACCUM
Tulsyan NEC Limited	1	35.0	10/2/26, 6:20AM		TURBINE MISC. PROBLEMS
SIMHADRI	3	500.0	9/29/26, 12:00AM		VARIOUS STEAM LEAKAGES
KAHALGAON TPS	4	210.0	10/1/26, 11:22AM		GEN. COOLING SYSTEM FAILURE
BANDEL TPS	5	210.0	10/1/26, 11:13PM		TURBINE THRUST PAD FAILURE
MAITHON RB TPP	1	525.0	10/2/26, 11:26AM		FURNACE FIRE OUT /FLAME FAILURE
LAKWA REPLACEMENT POWER PROJECT	4	9.965	10/2/26, 12:00AM		SCHEDULED ANNUAL MAINTENANCE
Total		10905.00			

Remarks:-

Report Version :-