

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 02-Oct-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
INDIRA GANDHI STPP	2	500.00	10/2/26, 9:55AM		WET / POOR QUALITY COAL
FARIDABAD CCPP	1	137.76	10/2/26, 3:03AM	2026-10-02 16:42:00	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	10/2/26, 4:55AM	2026-10-02 16:08:00	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3	156.07	10/2/26, 4:45AM	2026-10-02 17:10:00	CONSERVATION OF MAIN FUEL/RSD
SURATGARH TPS	5	250.00	10/2/26, 9:40AM	2026-10-02 12:56:00	DRUM LEVEL HIGH/ low
JALIPA KAPURDI TPP	3	135.00	10/2/26, 4:53PM		BOILER MISC. PROBLEM
ADANI POWER LIMITED KAWAI TPP	2	660.00	10/2/26, 10:49AM	2026-10-06	TURBINE MISC. PROBLEM
RAMGARH CCPP	5	110.00	10/2/26, 10:20PM		FUEL SUPPLY & OTHER MISC. PROBLEMS
DHOLPUR CCPP	1	110.00	10/2/26, 8:14PM	2026-10-03	Low system demand/ costly fuel
DHOLPUR CCPP	1		10/2/26, 12:17AM	2026-10-02 17:51:24	Low system demand/ costly fuel
DHOLPUR CCPP	2	110.00	10/2/26, 8:14PM	2026-10-03	Low system demand/ costly fuel
DHOLPUR CCPP	2		10/2/26, 12:17AM	2026-10-02 17:27:27	Low system demand/ costly fuel
AURAIYA CCPP	1	111.19	10/2/26, 1:53AM	2026-10-02 15:44:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	10/2/26, 1:30AM	2026-10-02 17:21:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5	109.30	10/2/26, 1:47AM	2026-10-02 18:03:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	10/2/26, 1:40AM	2026-10-02 16:43:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	10/2/26, 3:17AM	2026-10-02 14:37:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	10/2/26, 1:57AM	2026-10-02 15:15:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	10/2/26, 3:11AM	2026-10-02 16:42:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6	154.51	10/2/26, 1:50AM	2026-10-02 16:47:00	CONSERVATION OF MAIN FUEL/RSD
RATIJA TPS	2	50.00	10/2/26, 12:35AM		BOILER AUX. MISC. PROMLEMS
JSW Mahanadi Power Company Limited	2	600.00	10/2/26, 7:10PM	2026-10-03	TURBINE VIBRATIONS HIGH
SASAN UMTTP	5	660.00	10/2/26, 10:30PM		WATER WALL TUBE LEAKAGE
VINDHYACHAL STPS	7	500.00	10/2/26, 9:33AM	2026-10-03	WATER WALL TUBE LEAKAGE
UKAI TPS	5	210.00	10/2/26, 8:42AM	2026-10-02 11:07:00	FURNACE FIRE OUT /FLAME FAILURE
SUGEN CCPP	1	382.50	10/2/26, 12:00AM		RSD/LOW SCHEDULE
UNOSUGEN CCPP	1	382.50	10/2/26, 12:00AM		RSD/LOW SCHEDULE
KAWAS CCPP	1	106.00	10/2/26, 1:38AM	2026-10-02 15:53:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	10/2/26, 1:28AM	2026-10-02 14:31:00	CONSERVATION OF MAIN FUEL/RSD

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KAWAS CCPP	6	116.10	10/2/26, 4:50AM	2026-10-03	GT/WHRB/ST PLANNED OVERHAUL
GANDHAR CCPP	1	144.30	10/2/26, 11:30PM	2026-10-02	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	10/2/26, 2:27AM	2026-10-02 14:06:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	10/2/26, 2:34AM	2026-10-02 15:16:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4	224.49	10/2/26, 2:29AM	2026-10-02 16:23:00	CONSERVATION OF MAIN FUEL/RSD
BHUSAWAL TPS	3	210.00	10/2/26, 2:10PM		GRID DISTURBANCE
CHANDRAPUR(MAHARASHTRA) STPS	3	210.00	10/2/26, 5:54AM		WATER WALL TUBE LEAKAGE
RATNAGIRI CCPP	4	213.00	10/2/26, 7:29AM	2026-10-02 13:05:00	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	5	213.00	10/2/26, 8:28AM	2026-10-02 15:53:00	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	6	237.54	10/2/26, 8:28AM	2026-10-02 14:46:00	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	7	213.00	10/2/26, 7:52AM	2026-10-02 15:16:00	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.00	10/2/26, 7:27AM	2026-10-02 13:20:00	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	9	237.54	10/2/26, 7:49AM	2026-10-02 14:28:00	GT- LOW SYSTEM DAMAND
YERMARUS TPP	2	800.00	10/2/26, 8:47AM		WATER WALL TUBE LEAKAGE
NORTH CHENNAI TPS STAGE 2	4	600.00	10/2/26, 10:10AM		WATER WALL TUBE LEAKAGE
NORTH CHENNAI TPS STAGE 3	6	800.00	10/2/26, 3:48AM	2026-10-02 11:22:00	CONDENSER LOW VACCUM
Tulsyan NEC Limited	1	35.00	10/2/26, 6:20AM	2026-10-02 10:37:00	TURBINE MISC. PROBLEMS
NEYVELI TPS-II	5	210.00	10/2/26, 10:03PM		BOILER AUX. MISC. PROMLEMS
NEYVELI (EXT) TPS	2	210.00	10/2/26, 12:00AM		I.D. FANS PROBLEM
NEYVELI TPS-II EXP	2	250.00	10/2/26, 12:52AM		BOILER AUX. MISC. PROMLEMS
KOTHAGUDEM TPS (STAGE-7)	12	800.00	10/2/26, 11:10PM		WATER WALL TUBE LEAKAGE
BHADRADRI TPP	4	270.00	10/2/26, 9:59AM		BOILER AUX. MISC. PROMLEMS
Dr. N.TATA RAO TPS	6	210.00	10/2/26, 11:59PM		P.A. FANS PROBLEM
MEENAKSHI ENERGY LTD	3	350.00	10/2/26, 11:45PM		BOILER AUX. MISC. PROMLEMS
NABINAGAR TPP	2	250.00	10/2/26, 10:09AM		WATER WALL TUBE LEAKAGE
MAITHON RB TPP	1	525.00	10/2/26, 11:26AM	2026-10-02 15:25:00	FURNACE FIRE OUT /FLAME FAILURE
KAMALANGA TPS	3	350.00	10/2/26, 11:24PM		TURBINE OIL SYSTEM PROBLEM
LAKWA REPLACEMENT POWER PROJECT	4	9.96	10/2/26, 12:00AM	2026-10-02 23:59:59	SCHEDULED ANNUAL MAINTENANCE

Total	14525.40			
-------	----------	--	--	--

Remarks:-

Report Version :-