

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 03-07-2025

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PANIPAT TPS	6	210.00	01/07/2025 11:18	03/07/2025 12:42	RSD/LOW SCHEDULE
PANIPAT TPS	7	250.00	01/07/2025 11:12	03/07/2025 14:31	RSD/LOW SCHEDULE
RAJIV GANDHI TPS	2	600.00	02/07/2025 19:33	03/07/2025 15:41	STATION TRANSFORMER PROBLEM
GOINDWAL SAHIB TPP	1	270.00	03/07/2025 12:41	03/07/2025 17:30	GENERATOR PROTECTION RELAY OPERATION PROBLEM
ANTA CCPP	1	88.71	03/07/2025 00:44	03/07/2025 19:37	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	03/07/2025 00:44	03/07/2025 14:01	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	4	153.20	15/06/2025 03:27	03/07/2025 18:54	CONSERVATION OF MAIN FUEL/RSD
DADRI (NCTPP)	1	210.00	20/06/2025 01:06	03/07/2025 17:38	CONSERVATION OF MAIN FUEL/RSD
DADRI (NCTPP)	3	210.00	20/06/2025 00:06	03/07/2025 14:51	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	1	111.19	03/07/2025 00:46	03/07/2025 21:08	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	03/07/2025 00:46	03/07/2025 17:06	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	28/06/2025 22:40	03/07/2025 17:40	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5	109.30	15/06/2025 00:19	03/07/2025 21:03	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6	109.30	15/06/2025 00:13	03/07/2025 18:05	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	03/07/2025 00:47	03/07/2025 15:19	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	03/07/2025 00:47	03/07/2025 20:20	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	15/06/2025 02:30	03/07/2025 18:32	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6	154.51	15/06/2025 03:03	03/07/2025 19:15	CONSERVATION OF MAIN FUEL/RSD
DSPM TPS	1	250.00	02/07/2025 11:00	03/07/2025 09:38	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
KORBA-WEST TPS	2	210.00	03/07/2025 15:18	03/07/2025 18:39	FURNACE FIRE OUT /FLAME FAILURE
KORBA-WEST TPS	4	210.00	03/07/2025 03:04	03/07/2025 06:55	GENERATOR PROTECTION
MARWA TPS	2	500.00	03/07/2025 12:54	03/07/2025 16:34	ELECTRICAL MISCELLANEOUS PROBLEMS
GANDHAR CCPP	1	144.30	03/07/2025 00:34	03/07/2025 11:20	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	03/07/2025 00:45	03/07/2025 15:00	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	03/07/2025 00:41	03/07/2025 16:26	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4	224.49	15/06/2025 02:50	03/07/2025 16:04	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1	106.00	03/07/2025 00:39	03/07/2025 12:29	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	03/07/2025 00:43	03/07/2025 16:31	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	03/07/2025 00:29	03/07/2025 13:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	5	116.10	17/06/2025 10:00	03/07/2025 16:59	CONSERVATION OF MAIN FUEL/RSD
KUTCH LIG. TPS	3	75.00	03/07/2025 16:23	03/07/2025 18:16	FURNACE DRAFT ABNORMAL
KUTCH LIG. TPS	3		30/06/2025 10:59	03/07/2025 12:58	RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
WANAKBORI TPS	3	210.00	17/06/2025 14:36	03/07/2025 19:46	RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	7	210.00	17/06/2025 13:15	03/07/2025 17:25	RESERVE SHUT DOWN / STANDBY UNIT
ADANI POWER LIMITED MUNDRA TPP - I & II	1	330.00	18/06/2025 18:12	03/07/2025 14:11	RESERVE SHUT DOWN / STANDBY UNIT
ADANI POWER LIMITED MUNDRA TPP - I & II	2	330.00	18/06/2025 10:02	03/07/2025 15:27	RESERVE SHUT DOWN / STANDBY UNIT
ADANI POWER LIMITED MUNDRA TPP - I & II	4	330.00	19/06/2025 09:11	03/07/2025 14:00	RESERVE SHUT DOWN / STANDBY UNIT
BINA TPS	2	250.00	29/06/2025 14:08	03/07/2025 04:08	WATER WALL TUBE LEAKAGE
SASAN UMTTP	5	660.00	02/07/2025 03:00	03/07/2025 04:04	ECONOMISER TUBE LEAKAGE
RATNAGIRI CCPP	4	213.00	15/06/2025 03:08	03/07/2025 17:33	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	5	213.00	15/06/2025 03:39	03/07/2025 13:28	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	6	237.54	15/06/2025 03:37	03/07/2025 16:38	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	7	213.00	15/06/2025 03:50	03/07/2025 13:04	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	8	213.00	15/06/2025 02:53	03/07/2025 16:49	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	9	237.54	15/06/2025 03:47	03/07/2025 15:25	GT-MISCELLANEOUS PROBLEMS
PARAS TPS	3	250.00	03/07/2025 08:53	03/07/2025 12:46	FURNACE DRAFT ABNORMAL
PARLI TPS	8	250.00	21/05/2025 11:08	03/07/2025 17:08	RSD/LOW SCHEDULE
URAN CCPP	8	108.00	03/07/2025 12:40	03/07/2025 19:42	COMPRESSED AIR SYSTEM PROBLEM
NEYVELI TPS-II	3	210.00	02/07/2025 04:05	03/07/2025 09:42	ELECTRICAL MISCELLANEOUS PROBLEMS
DERANG TPP	2	600.00	30/06/2025 18:45	03/07/2025 06:33	ASH HANDLING SYSTEM PROBLEM
JSW Energy Utkal Limited	1	350.00	03/07/2025 12:49	03/07/2025 16:23	TURBINE BEARING TEMP. HIGH
SAGARDIGHI TPS	2	300.00	01/07/2025 12:40	03/07/2025 19:58	WATER WALL TUBE LEAKAGE
KATHALGURI CCPP	2	33.50	03/07/2025 00:00	03/07/2025 23:59	LOW SYSTEM DEMAND
LAKWA REPLACEMENT POWER PROJECT	3	9.96	03/07/2025 12:45	03/07/2025 18:24	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	5	9.96	02/07/2025 21:30	03/07/2025 11:58	MISC. SHORT DURATION MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	5		03/07/2025 12:03	03/07/2025 12:30	MISC. SHORT DURATION MAINTENANCE
Total		11,307.19			