

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 03-07-2025

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
GOINDWAL SAHIB TPP	1	270.00	03/07/2025 12:41		GENERATOR PROTECTION RELAY OPERATION PROBLEM
ANTA CCPP	1	88.71	03/07/2025 00:44	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	03/07/2025 00:44	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	1	111.19	03/07/2025 00:46	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	03/07/2025 00:46	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	03/07/2025 00:47	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	03/07/2025 00:47	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
ANPARA TPS	3	210.00	03/07/2025 14:45		ECONOMISER TUBE LEAKAGE
KORBA-WEST TPS	2	210.00	03/07/2025 15:18	03/07/2025	FURNACE FIRE OUT /FLAME FAILURE
KORBA-WEST TPS	4	210.00	03/07/2025 03:04	03/07/2025	GENERATOR PROTECTION
MARWA TPS	2	500.00	03/07/2025 12:54		ELECTRICAL MISCELLANEOUS PROBLEMS
ADANI POWER LIMITED RAIPUR TPP	2	685.00	03/07/2025 23:25		AIR PREHEATERS PROBLEM
BINJKOTE TPP	2	300.00	03/07/2025 09:10		TURBINE MISC.
CHAKABURA TPP	2	30.00	03/07/2025 01:27		FURNACE DRAFT ABNORMAL
GANDHAR CCPP	1	144.30	03/07/2025 00:34	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	03/07/2025 22:21	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2		03/07/2025 00:45	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	03/07/2025 00:41	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1	106.00	03/07/2025 00:39	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	03/07/2025 00:43	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	03/07/2025 00:29	03/07/2025	CONSERVATION OF MAIN FUEL/RSD
KUTCH LIG. TPS	3	75.00	03/07/2025 16:23		FURNACE DRAFT ABNORMAL
MUNDRA UMTTPP	1	800.00	03/07/2025 11:54		AIR PREHEATERS PROBLEM
SANJAY GANDHI TPS	1	210.00	03/07/2025 22:10		FURNACE DRAFT ABNORMAL
PARAS TPS	3	250.00	03/07/2025 08:53		FURNACE DRAFT ABNORMAL
URAN CCPP	8	108.00	03/07/2025 12:40		COMPRESSED AIR SYSTEM PROBLEM
Dr. N.TATA RAO TPS	8	800.00	03/07/2025 11:17		GENEARTOR MISC.
SIMHAPURI TPS	4	150.00	03/07/2025 01:00		ELECTRICAL MISCELLANEOUS PROBLEMS
YERMARUS TPP	1	800.00	03/07/2025 17:06		COAL FEEDING SYSTEM FAILURE.
RAMAGUNDEM STPS	3	200.00	03/07/2025 23:30	03/07/2025	MAINT./REPLACEMENT OF BRUSHES/SLIP RINGS
JSW Energy Utkal Limited	1	350.00	03/07/2025 12:49	03/07/2025	TURBINE BEARING TEMP. HIGH
KATHALGURI CCPP	2	33.50	03/07/2025 00:00		LOW SYSTEM DEMAND

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
LAKWA REPLACEMENT POWER PROJECT	3	9.96	03/07/2025 12:45		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	5	9.96	03/07/2025 12:03		MISC. SHORT DURATION MAINTENANCE
Total		7622.51			