CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 03-Nov-2026 **Sub - Report 14**

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SURATGARH STPS	7	660.0	10/31/26, 9:55PM	11/3/26, 3:09PM	BOILER AUX. MISC. PROMLEMS
SHREE CEMENT LTD TPS	4	19.0	11/3/26, 8:00AM	11/3/26, 3:53PM	RSD/LOW SCHEDULE
OBRA TPS	14	660.0	10/29/26, 3:30PM	11/3/26, 1:54AM	WATER WALL TUBE LEAKAGE
PARICHHA TPS	3	210.0	10/27/26, 9:31PM	11/3/26, 2:34AM	RSD/LOW SCHEDULE
PARICHHA TPS	4	210.0	10/27/26, 9:23PM	11/3/26, 1:18AM	RSD/LOW SCHEDULE
PARICHHA TPS	5	250.0	10/27/26, 9:37PM	11/3/26, 3:19AM	RSD/LOW SCHEDULE
PARICHHA TPS	6	250.0	10/27/26, 9:28PM	11/3/26, 1:52AM	RSD/LOW SCHEDULE
PANKI TPS EXT	1	660.0	10/27/26, 9:33PM	11/3/26, 8:10AM	RSD/LOW SCHEDULE
ADANI POWER LIMITED RAIPUR TPP	2	685.0	11/2/26, 4:49PM	11/3/26, 2:50AM	FURNACE FIRE OUT /FLAME FAILURE
GADARWARA TPP	2	800.0	10/28/26, 11:20PM	11/3/26, 7:37AM	WATER WALL TUBE LEAKAGE
SIKKA REP. TPS	3	250.0	10/28/26, 11:52AM	11/3/26, 1:30PM	RESERVE SHUT DOWN / STANDBY UNIT
SIKKA REP. TPS	4	250.0	10/28/26, 11:52AM	11/3/26, 12:00PM	RESERVE SHUT DOWN / STANDBY UNIT
KOTHAGUDEM TPS (NEW)	9	250.0	11/2/26, 10:58PM	11/3/26, 3:02PM	WATER WALL TUBE LEAKAGE
TELANGANA STPP PH-1	1	800.0	10/31/26, 7:36AM	11/3/26, 10:12AM	WATER WALL TUBE LEAKAGE
NABINAGAR TPP	2	250.0	10/31/26, 3:27PM	11/3/26, 10:23AM	ELECTRICAL MISCELLANEOUS PROBLEMS
SAGARDIGHI TPS	3	500.0	11/2/26, 10:01PM	11/3/26, 12:26AM	CONDENSER LOW VACCUM
Maadurga Thermal Power Company Ltd.	1	30.0	11/2/26, 12:32PM	11/3/26, 5:04AM	GENERATOR MISCLLANEOUS MAINTENANCE
NAMRUP CCPP	7	62.25	10/30/26, 1:00AM	11/3/26, 12:00AM	MISCELLANEOUS PLANNED MAINTENANCE
NAMRUP CCPP	8	36.15	10/30/26, 12:37AM	11/3/26, 4:25AM	MISCELLANEOUS PLANNED MAINTENANCE
Total		6832.40			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities.

Remarks:-

Report Version :-