CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 03-Nov-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
YAMUNA NAGAR TPS	2	300.00	11/3/26, 4:03PM		WATER WALL TUBE LEAKAGE
SURATGARH STPS	8	660.00	11/3/26, 6:32AM		BOILER MISC. PROBLEM
SHREE CEMENT LTD TPS	3	19.00	11/3/26, 8:00AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	11/3/26, 8:00AM	2026-11-03 15:53:19	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	11/3/26, 8:00AM		RSD/LOW SCHEDULE
OP JINDAL TPS	3	250.00	11/3/26, 9:28AM		STATOR/ STATOR EARTH FAULT
SASAN UMTPP	4	660.00	11/3/26, 3:57PM		REHEATER TUBE LEAKAGE
UKAI TPS	3	200.00	11/3/26, 9:58AM		P.A. FANS PROBLEM
AKRIMOTA LIG TPS	1	125.00	11/3/26, 2:08PM		ECONOMISER TUBE LEAKAGE
BHADRADRI TPP	1	270.00	11/3/26, 9:02AM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	2	210.00	11/3/26, 5:46PM		SUPER HEATER TUBE LEAKAGE
RAYALASEEMA TPS	5	210.00	11/3/26, 12:40AM		SCHEDULED ANNUAL MAINTENANCE
SIMHAPURI TPS	1	150.00	11/3/26, 10:34AM		WATER WALL TUBE LEAKAGE
TALCHER STPS	1	500.00	11/3/26, 7:36AM	2026-11-03	REHEATER TUBE LEAKAGE
AGARTALA GT	5	25.50	11/3/26, 12:00AM		Fuel Shortage
Total		3604.50			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities.

Remarks:-

Report Version :-