

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS: 04-Mar-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KOTA TPS	5	210.0	3/4/26, 1:44 AM		ELECTRICAL MISCELLANEOUS PROBLEMS
KOTA TPS	7	195.0	3/4/26, 1:43 AM		ELECTRICAL MISCELLANEOUS PROBLEMS
SHREE CEMENT LTD TPS	3	19.0	3/4/26, 12:00 AM		RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	3/4/26, 12:00 AM		RSD/LOW SCHEDULE
OBRA TPS	13	200.0	2/26/26, 7:51 AM		BOILER MISC. PROBLEM
OP JINDAL TPS	3	250.0	3/4/26, 2:40 PM		FURNACE DRAFT ABNORMAL
BARADARHA TPS	1	600.0	3/3/26, 12:52 PM		AIR PREHEATERS PROBLEM
PARAS TPS	4	250.0	3/4/26, 10:33 AM		FURNACE DRAFT ABNORMAL
NORTH CHENNAI TPS STAGE 1	1	210.0	3/3/26, 2:07 AM		ECONOMISER TUBE LEAKAGE
NEYVELI TPS-II	4	210.0	2/27/26, 5:42 PM		WATER WALL TUBE LEAKAGE
KAKATIYA TPS	1	500.0	3/2/26, 7:19 AM		BOILER MISC. PROBLEM
BHADRADRI TPP	3	270.0	3/4/26, 3:13 AM		COAL FEEDING PROBLEM IN PLANT
YADADRI TPS	4	800.0	2/27/26, 6:34 PM		BOILER MISC. PROBLEM
Dr. N.TATA RAO TPS	5	210.0	3/3/26, 10:43 AM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
VIZAG TPP	2	520.0	3/2/26, 9:37 AM		WATER WALL TUBE LEAKAGE
AGARTALA GT	1	21.0	3/4/26, 12:00 AM		Fuel Shortage
AGARTALA GT	5	25.5	3/4/26, 12:00 AM		MISCELLANEOUS PLANNED MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	1	9.965	3/3/26, 8:40 PM		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	2		3/4/26, 12:00 AM		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	2	9.965	3/4/26, 8:17 AM		GRID DISTURBENCE
KATHALGURI CCPP	1	33.5	3/4/26, 12:00 AM		Low system demand/ costly fuel

Total	4562.93			
--------------	---------	--	--	--

" ** " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

- Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-