

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 04-Mar-2026

Sub - Report 15

| Station | Unit No. | Capacity(MW) | Date& Time of Maintenance DD/MM/YYYY HH24:MM | Expected/sync Date of Return DD/MM/YYYY HH24:MM | Reasons/Present Status |
|---------------------------------|----------|--------------|---|--|-----------------------------------|
| 1 | 2 | 3 | 4 | 5 | 6 |
| KOTA TPS | 5 | 210.00 | 3/4/26, 1:44 AM | 2026-03-04 05:08:00 | ELECTRICAL MISCELLANEOUS PROBLEMS |
| KOTA TPS | 7 | 195.00 | 3/4/26, 1:43 AM | 2026-03-04 05:14:00 | ELECTRICAL MISCELLANEOUS PROBLEMS |
| SURATGARH TPS | 1 | 250.00 | 3/4/26, 7:30 AM | | ELECTRICAL MISCELLANEOUS PROBLEMS |
| SHREE CEMENT LTD TPS | 3 | 19.00 | 3/4/26, 12:00 AM | 2026-03-04 17:30:00 | RSD/LOW SCHEDULE |
| SHREE CEMENT LTD TPS | 4 | 19.00 | 3/4/26, 12:00 AM | 2026-03-04 17:29:00 | RSD/LOW SCHEDULE |
| PANKI TPS EXT | 1 | 660.00 | 3/4/26, 9:00 PM | | RSD/LOW SCHEDULE |
| ROSA TPP Ph-I | 4 | 300.00 | 3/4/26, 9:00 PM | 2026-03-06 | RSD/LOW SCHEDULE |
| OP JINDAL TPS | 3 | 250.00 | 3/4/26, 2:40 PM | 2026-03-04 17:38:00 | FURNACE DRAFT ABNORMAL |
| KUTCH LIG. TPS | 3 | 75.00 | 3/4/26, 10:25 AM | | RSD/LOW SCHEDULE |
| SUGEN CCPP | 2 | 382.50 | 3/4/26, 12:00 AM | 2026-03-05 | RSD/LOW SCHEDULE |
| PARAS TPS | 4 | 250.00 | 3/4/26, 10:33 AM | 2026-03-04 12:58:00 | FURNACE DRAFT ABNORMAL |
| CHANDRAPUR(MAHARASHTRA) STPS | 3 | 210.00 | 3/4/26, 6:56 PM | | WATER WALL TUBE LEAKAGE |
| MUTHIARA TPP | 2 | 600.00 | 3/4/26, 12:29 AM | | BOILER MISC. PROBLEM |
| NEYVELI TPS-II EXP | 2 | 250.00 | 3/4/26, 5:33 AM | | BOILER MISC. PROBLEM |
| NEYVELI NEW TPP | 1 | 500.00 | 3/4/26, 4:51 AM | | BOILER AUX. MISC. PROMLEMS |
| SINGARENI TPP | 2 | 600.00 | 3/4/26, 11:52 PM | | REHEATER TUBE LEAKAGE |
| BHADRADRI TPP | 3 | 270.00 | 3/4/26, 3:13 AM | 2026-03-04 06:58:00 | COAL FEEDING PROBLEM IN PLANT |
| YADADRI TPS | 2 | 800.00 | 3/4/26, 1:18 AM | | WATER WALL TUBE LEAKAGE |
| KAHALGAON TPS | 3 | 210.00 | 3/4/26, 7:45 AM | 2026-03-04 | BOILER AUX. MISC. PROMLEMS |
| AGARTALA GT | 1 | 21.00 | 3/4/26, 12:00 AM | 2026-03-04 23:59:59 | Fuel Shortage |
| AGARTALA GT | 5 | 25.50 | 3/4/26, 12:00 AM | 2026-03-04 23:59:59 | MISCELLANEOUS PLANNED MAINTENANCE |
| MONARCHAK CCPP | 2 | 35.60 | 3/4/26, 12:00 AM | | FUEL OIL PROBLEM |
| LAKWA REPLACEMENT POWER PROJECT | 2 | 9.96 | 3/4/26, 8:17 AM | 2026-03-04 08:30:18 | GRID DISTURBENCE |
| LAKWA REPLACEMENT POWER PROJECT | 2 | | 3/4/26, 12:00 AM | 2026-03-04 06:29:40 | GRID DISTURBENCE |
| KATHALGURI CCPP | 1 | 33.50 | 3/4/26, 12:00 AM | 2026-03-04 23:59:59 | Low system demand/ costly fuel |

| | | | | |
|--------------|---------|--|--|--|
| Total | 6176.07 | | | |
|--------------|---------|--|--|--|

" ** " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

- Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-