

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 04-09-2024

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
SURATGARH TPS	1	250.00	04/09/2024 11:52	04/09/2024 16:01	FURNACE FIRE OUT /FLAME FAILURE
BARADARHA TPS	2	600.00	02/09/2024 17:42	04/09/2024 14:14	AIR PREHEATERS PROBLEM
RATIJA TPS	1	50.00	02/09/2024 00:14	04/09/2024 08:25	BOILER AUX. MISC. PROMLEMS
GANDHAR CCPP	1	144.30	03/09/2024 23:57	04/09/2024 18:56	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	03/09/2024 23:39	04/09/2024 18:45	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1	106.00	03/09/2024 23:52	04/09/2024 18:45	CONSERVATION OF MAIN FUEL/RSD
ADANI POWER LIMITED MUNDRA TPP - III	7	660.00	29/08/2024 21:46	04/09/2024 21:15	ACCIDENT/STRIKE/OTHERS
ADANI POWER LIMITED MUNDRA TPP - I & II	6	660.00	29/08/2024 14:39	04/09/2024 06:17	ACCIDENT/STRIKE/OTHERS
SALAYA TPP	2	600.00	04/09/2024 04:38	04/09/2024 16:59	GEN.TRANSFORMER OIL LEAKAGE.
SALAYA TPP	2		04/09/2024 17:33	04/09/2024 18:31	GEN.TRANSFORMER OIL LEAKAGE.
BHUSAWAL TPS	5	500.00	04/09/2024 14:10	04/09/2024 15:53	DRUM LEVEL LOW
BHUSAWAL TPS	5		03/09/2024 20:58	04/09/2024 14:01	BOILER INSPECTION/ RE-CERTIFICATION
TROMBAY TPS	8	250.00	04/09/2024 08:35	04/09/2024 17:10	DRUM LEVEL LOW
Dr. N.TATA RAO TPS	4	210.00	31/08/2024 15:35	04/09/2024 01:28	GENEATOR PROTECTION MISC/BACK UP PROT
Dr. N.TATA RAO TPS	4		04/09/2024 13:14	04/09/2024 14:13	GENEATOR PROTECTION MISC/BACK UP PROT
Dr. N.TATA RAO TPS	6	210.00	04/09/2024 05:04	04/09/2024 14:13	FURNACE FIRE OUT /FLAME FAILURE
THAMMINAPATNAM TPS	1	150.00	29/08/2024 19:38	04/09/2024 15:05	TURBINE VIBRATION HIGH
NEYVELI TPS-II	2	210.00	27/07/2024 00:00	04/09/2024 20:22	ANNUAL MAINTENANCE
VALLUR TPP	1	500.00	03/09/2024 08:02	04/09/2024 03:21	INSTRUMENT AIR SYSTEM FAILURE
NORTH CHENNAI TPS	4	600.00	28/08/2024 23:44	04/09/2024 04:38	WATER WALL TUBE LEAKAGE
NEYVELI TPS(Z)	1	250.00	02/09/2024 12:08	04/09/2024 22:08	WATER WALL TUBE LEAKAGE
KOTHAGUDEM TPS (STAGE-7)	12	800.00	04/09/2024 07:05	04/09/2024 12:21	C&I PROBLEM
SINGARENI TPP	2	600.00	15/06/2024 20:26	04/09/2024 10:35	CAPITAL MAINTENANCE
KAMALANGA TPS	2	350.00	01/09/2024 02:30	04/09/2024 10:07	AIR PREHEATERS PROBLEM
UTKAL TPP (IND BARATH)	1	350.00	03/09/2024 22:25	04/09/2024 17:55	TURBINE MISC.
RAGHUNATHPUR TPP	2	600.00	31/08/2024 23:45	04/09/2024 10:06	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
KATHALGURI CCPP	1	33.50	04/09/2024 00:00	04/09/2024 23:59	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	4	9.96	04/09/2024 19:30	04/09/2024 22:30	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	4		04/09/2024 00:19	04/09/2024 19:30	GRID DISTURBANCES MISC.
AGARTALA GT	3	21.00	04/09/2024 03:01	04/09/2024 18:13	Fuel Shortage
AGARTALA GT	4	21.00	04/09/2024 00:00	04/09/2024 23:59	Fuel Shortage

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
AGARTALA GT	6	25.50	04/09/2024 00:00	04/09/2024 23:59	Fuel Shortage
Total		8,905.57			