

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 04-10-2025

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
KORBA-WEST TPS	2	210.00	04/10/2025 17:56	04/10/2025 21:57	GENEARTOR MISC.
ADANI POWER LIMITED MUNDRA TPP - I & II	6	660.00	01/10/2025 13:54	04/10/2025 18:45	RSD/LOW SCHEDULE
SASAN UMTTP	6	660.00	03/10/2025 23:04	04/10/2025 03:19	TURBINE MISC. PROBLEM
CHANDRAPUR(MAHARASHTRA) STPS	6	500.00	04/10/2025 15:22	04/10/2025 18:15	DRUM LEVEL LOW
AMRAVATI TPS	4	270.00	23/08/2025 00:00	04/10/2025 10:32	CAPITAL MAINTENANCE
NEYVELI NEW TPP	1	500.00	04/10/2025 11:30	04/10/2025 13:45	MISCELLANEOUS
METTUR TPS - II	1	600.00	03/10/2025 22:45	04/10/2025 23:59	BOILER MISC. PROBLEM
OPG Power Generation Private Limited	2	77.00	03/10/2025 23:59	04/10/2025 17:00	RSD/LOW SCHEDULE
TALCHER STPS	6	500.00	29/09/2025 17:53	04/10/2025 11:09	WATER WALL TUBE LEAKAGE
KATHALGURI CCPP	4	33.50	04/10/2025 00:00	04/10/2025 23:59	LOW SYSTEM DEMAND
LAKWA REPLACEMENT POWER PROJECT	1	9.96	03/10/2025 20:30	04/10/2025 18:45	GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER PROJECT	1		04/10/2025 18:45	04/10/2025 20:45	Fuel Shortage
AGARTALA GT	2	21.00	04/10/2025 00:00	04/10/2025 23:59	Fuel Shortage
Total		4,041.47			