

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 04-10-2025

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
INDIRA GANDHI STPP	3	500.00	04/10/2025 00:04		RSD/LOW SCHEDULE
RAJASTHAN A.P.S.	7	700.00	04/10/2025 16:34	10/10/2025	TURBINE VIBRATION HIGH
SURATGARH TPS	5	250.00	04/10/2025 20:27		RSD/LOW SCHEDULE
KORBA-WEST TPS	2	210.00	04/10/2025 17:56	04/10/2025	GENEARTOR MISC.
KORBA-WEST TPS	3	210.00	04/10/2025 10:30	05/10/2025	ECONOMISER TUBE LEAKAGE
TAMNAR TPP	2	600.00	04/10/2025 10:11		TURBINE MISC.
CHANDRAPUR(MAHARASHTRA) STPS	6	500.00	04/10/2025 15:22		DRUM LEVEL LOW
AMRAVATI TPS	3	270.00	04/10/2025 09:30		ASH HANDLING SYSTEM PROBLEM
NEYVELI NEW TPP	1	500.00	04/10/2025 11:30		MISCELLANEOUS
OPG Power Generation Private Limited	2	77.00	04/10/2025 23:59		RSD/LOW SCHEDULE
BARH STPS	4	660.00	04/10/2025 17:07	05/10/2025	C&I PROBLEM
KAHALGAON TPS	7	500.00	04/10/2025 08:30	05/10/2025	WATER WALL TUBE LEAKAGE
RAGHUNATHPUR TPP	1	600.00	04/10/2025 06:57		LUB.OIL SYSTEM PROBLEM
KOLAGHAT TPS	6	210.00	04/10/2025 11:31		BOILER MISC. PROBLEM
KATHALGURI CCPP	4	33.50	04/10/2025 00:00		LOW SYSTEM DEMAND
LAKWA REPLACEMENT POWER PROJECT	1	9.96	04/10/2025 20:45		GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER PROJECT	1		04/10/2025 18:45		Fuel Shortage
AGARTALA GT	2	21.00	04/10/2025 00:00		Fuel Shortage
Total		5851.47			