

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 04-Oct-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
GH TPS (LEH.MOH.)	2	210.0	10/4/26, 5:41AM		FURNACE FIRE OUT /FLAME FAILURE
FARIDABAD CCPP	1	137.76	10/4/26, 3:19AM		CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	10/4/26, 4:00AM		CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3	156.07	10/4/26, 3:52AM		CONSERVATION OF MAIN FUEL/RSD
RAMGARH CCPP	5	110.0	10/3/26, 9:05PM		FUEL SUPPLY & OTHER MISC. PROBLEMS
DHOLPUR CCPP	1	110.0	10/3/26, 11:59PM		Low system demand/ costly fuel
DHOLPUR CCPP	2	110.0	10/3/26, 11:59PM		Low system demand/ costly fuel
UNCHAHAH TPS	6	500.0	10/3/26, 8:31AM		ASH HANDLING SYSTEM PROBLEM
AURAIYA CCPP	4	111.19	10/4/26, 6:48AM		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6	109.3	10/4/26, 6:38AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	10/4/26, 2:11AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	10/4/26, 6:15AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	10/4/26, 1:33AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	10/4/26, 6:31AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	10/4/26, 6:06AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6	154.51	10/4/26, 6:16AM		CONSERVATION OF MAIN FUEL/RSD
RATIJA TPS	2	50.0	10/2/26, 12:35AM		BOILER AUX. MISC. PROMLEMS
SVPL TPP	1	63.0	10/4/26, 2:10PM		P.A. FANS PROBLEM
JSW Mahanadi Power Company Limited	2	600.0	10/2/26, 7:10PM		TURBINE VIBRATIONS HIGH
BINJKOTE TPP	1	300.0	10/4/26, 2:27PM		ROTOR/ ROTOR EARTH FAULT
SASAN UMTPP	5	660.0	10/2/26, 10:30PM		WATER WALL TUBE LEAKAGE
VINDHYACHAL STPS	12	500.0	9/27/26, 12:35AM		VARIOUS STEAM LEAKAGES
WANAKBORI TPS	1	210.0	10/4/26, 4:20PM		FURNACE FIRE OUT /FLAME FAILURE
KAWAS CCPP	1	106.0	10/4/26, 2:30AM		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.0	10/4/26, 2:16AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.3	10/4/26, 7:32AM		CONSERVATION OF MAIN FUEL/RSD
PARLI TPS	6	250.0	10/4/26, 12:37PM		TURBINE MISC.
CHANDRAPUR(MAHARASHTRA) STPS	3	210.0	10/2/26, 5:54AM		WATER WALL TUBE LEAKAGE
CHANDRAPUR(MAHARASHTRA) STPS	6	500.0	10/3/26, 2:49AM		DRUM LEVEL LOW

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 04-Oct-2026					Sub - Report 14
Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TROMBAY TPS	5	500.0	9/29/26, 1:58AM		WATER WALL TUBE LEAKAGE
RATNAGIRI CCPP	4	213.0	10/4/26, 4:48AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	5	213.0	10/4/26, 7:49AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	6	237.54	10/4/26, 7:48AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	7	213.0	10/4/26, 7:33AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.0	10/4/26, 6:27AM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	9	237.54	10/4/26, 7:30AM		GT- LOW SYSTEM DAMAND
NEYVELI TPS-II	3	210.0	10/1/26, 10:55AM		WATER WALL TUBE LEAKAGE
NEYVELI TPS-II	6	210.0	10/4/26, 7:41AM		GOVERNING SYSTEM PROBLEM
KOTHAGUDEM TPS (STAGE-7)	12	800.0	10/2/26, 11:10PM		WATER WALL TUBE LEAKAGE
MEENAKSHI ENERGY LTD	2	150.0	10/4/26, 3:10PM		MAL-FUNCTION OF RELAY
MEENAKSHI ENERGY LTD	4	350.0	10/3/26, 11:08PM		BOILER FEED PUMP/MOTOR PROBLEM
KAHALGAON TPS	7	500.0	10/3/26, 12:52AM		WATER WALL TUBE LEAKAGE
SAGARDIGHI TPS	2		9/4/26, 4:17AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
SAGARDIGHI TPS	2		10/4/26, 1:54PM		DRUM LEVEL HIGH/ low
SAGARDIGHI TPS	2	300.0	10/4/26, 4:17AM		BOILER AUX. MISC. PROMLEMS
LAKWA REPLACEMENT POWER PROJECT	4	9.965	10/4/26, 12:00AM		SCHEDULED ANNUAL MAINTENANCE
Total		10578.21			

Remarks:-

Report Version :-