

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 04-Oct-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
GH TPS (LEH.MOH.)	2	210.00	10/4/26, 5:41AM	2026-10-04 12:35:00	FURNACE FIRE OUT /FLAME FAILURE
PANIPAT TPS	7	250.00	10/4/26, 4:41AM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
FARIDABAD CCPP	1	137.76	10/4/26, 3:19AM	2026-10-04 15:35:00	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	10/4/26, 4:00AM	2026-10-04 16:42:00	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3	156.07	10/4/26, 3:52AM	2026-10-04 16:35:00	CONSERVATION OF MAIN FUEL/RSD
RAMGARH CCPP	5	110.00	10/4/26, 10:20PM		FUEL SUPPLY & OTHER MISC. PROBLEMS
DHOLPUR CCPP	1	110.00	10/4/26, 7:00AM		Low system demand/ costly fuel
DHOLPUR CCPP	2	110.00	10/4/26, 7:00AM		Low system demand/ costly fuel
AURAIYA CCPP	4	111.19	10/4/26, 6:48AM	2026-10-04 17:40:00	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6	109.30	10/4/26, 6:38AM	2026-10-04 17:54:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	10/4/26, 2:11AM	2026-10-04 16:37:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	10/4/26, 6:15AM	2026-10-04 14:36:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	10/4/26, 1:33AM	2026-10-04 19:05:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	10/4/26, 6:31AM	2026-10-04 17:44:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	5	154.51	10/4/26, 6:06AM	2026-10-04 16:35:00	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6	154.51	10/4/26, 6:16AM	2026-10-04 19:32:00	CONSERVATION OF MAIN FUEL/RSD
SVPL TPP	1	63.00	10/4/26, 2:10PM	2026-10-04 14:37:00	P.A. FANS PROBLEM
BINJKOTE TPP	1	300.00	10/4/26, 2:27PM	2026-10-04 19:58:00	ROTOR/ ROTOR EARTH FAULT
UCHPINDA TPP	2	360.00	10/4/26, 10:47AM		AIR PREHEATERS PROBLEM
SANJAY GANDHI TPS	4	210.00	10/4/26, 8:43PM		ELECTRICAL FAULT
WANAKBORI TPS	1	210.00	10/4/26, 4:20PM	2026-10-04 18:09:00	FURNACE FIRE OUT /FLAME FAILURE
UNOSUGEN CCPP	1	382.50	10/4/26, 12:00AM		RSD/LOW SCHEDULE
KAWAS CCPP	1	106.00	10/4/26, 2:30AM	2026-10-04 14:00:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	10/4/26, 2:16AM	2026-10-04 16:20:00	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6	116.10	10/4/26, 2:10AM	2026-10-05	GT/WHRB/ST PLANNED OVERHAUL
GANDHAR CCPP	2	144.30	10/4/26, 7:32AM	2026-10-04 14:13:00	CONSERVATION OF MAIN FUEL/RSD
MAUDA TPS	1	500.00	10/4/26, 1:42PM	2026-10-05	ECONOMISER TUBE LEAKAGE
PARLI TPS	6	250.00	10/4/26, 12:37PM	2026-10-04 17:28:00	TURBINE MISC.
RATNAGIRI CCPP	4	213.00	10/4/26, 4:48AM	2026-10-04 12:41:00	GT- LOW SYSTEM DAMAND

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
RATNAGIRI CCPP	5	213.00	10/4/26, 7:49AM	2026-10-04 15:09:00	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	6	237.54	10/4/26, 7:48AM	2026-10-04 14:38:00	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	7	213.00	10/4/26, 7:33AM	2026-10-04 15:52:00	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.00	10/4/26, 6:27AM	2026-10-04 13:24:00	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	9	237.54	10/4/26, 7:30AM	2026-10-04 14:54:00	GT- LOW SYSTEM DAMAND
NEYVELI TPS-II	6	210.00	10/4/26, 7:41AM	2026-10-04 14:59:00	GOVERNING SYSTEM PROBLEM
VALLUR TPP	3	500.00	10/4/26, 4:00AM		WATER WALL TUBE LEAKAGE
RAMAGUNDEM STPS	5	500.00	10/4/26, 6:00PM	2026-10-05	SUPER HEATER TUBE LEAKAGE
Dr. N.TATA RAO TPS	1	210.00	10/4/26, 2:40PM		AIR PREHEATERS PROBLEM
MEENAKSHI ENERGY LTD	2	150.00	10/4/26, 3:10PM	2026-10-04 16:54:00	MAL-FUNCTION OF RELAY
DURGAPUR STEEL TPS	2	500.00	10/4/26, 1:34PM		WATER WALL TUBE LEAKAGE
SAGARDIGHI TPS	2		10/4/26, 4:17AM	2026-10-04 09:19:00	BOILER AUX. MISC. PROMLEMS
SAGARDIGHI TPS	2	300.00	10/4/26, 1:54PM	2026-10-04 16:10:00	DRUM LEVEL HIGH/ low
LAKWA REPLACEMENT POWER PROJECT	4	9.96	10/4/26, 12:00AM	2026-10-04 13:58:00	SCHEDULED ANNUAL MAINTENANCE
Total		8726.81			

Remarks:-

Report Version :-