

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 04-12-2019

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
RAJASTHAN A.P.S.	6	220.00	01/12/2019 15:47	04/12/2019 18:48	REACTOR MAINTENANCE WORKS.
BHAVNAGAR CFBC TPP	2	250.00	02/12/2019 21:54	04/12/2019 02:06	GENERATOR PROTECTION RELAY OPERATION PROBLEM
BHUSAWAL TPS	5	500.00	04/12/2019 07:02	04/12/2019 10:02	CONDENSER LOW VACCUM
BHUSAWAL TPS	5		02/12/2019 01:26	04/12/2019 00:20	GT-MISCELLANEOUS PROBLEMS
SIMHADRI	4	500.00	04/12/2019 16:48	04/12/2019 19:25	I.D. FANS PROBLEM
PAINAMPURAM TPP	2	660.00	04/12/2019 16:32	04/12/2019 20:23	FUEL OIL PROBLEM
RAICHUR TPS	1	210.00	31/08/2019 12:42	04/12/2019 00:43	Low system demand/ costly fuel
NEYVELI TPS- I	3	50.00	01/12/2019 21:05	04/12/2019 18:36	LIGNITE FEEDING MISC.
NEYVELI TPS- I	4	50.00	01/12/2019 14:05	04/12/2019 11:00	LIGNITE FEEDING MISC.
NEYVELI TPS-II	4	210.00	04/12/2019 08:29	04/12/2019 10:22	GENERATOR MISCLLANEOUS MAINTENANCE
NEYVELI TPS-II	4		04/12/2019 00:46	04/12/2019 07:24	C&I PROBLEM
RAMAGUNDEM STPS	1	200.00	04/12/2019 11:54	04/12/2019 15:33	TURBINE MISC. PROBLEMS
SINGARENI TPP	2	600.00	02/12/2019 16:11	04/12/2019 06:43	WATER WALL TUBE LEAKAGE
MAHADEV PRASAD STPP	2	270.00	04/11/2019 23:39	04/12/2019 15:46	SCHEDULED ANNUAL MAINTENANCE
MEJIA TPS	3	210.00	10/11/2019 00:00	04/12/2019 12:08	GENERATOR MISCLLANEOUS MAINTENANCE
AGARTALA GT	4	21.00	04/12/2019 11:03	04/12/2019 13:14	GT-MISCELLANEOUS PROBLEMS
AGARTALA GT	6	25.50	04/12/2019 06:57	04/12/2019 08:05	GT-MISCELLANEOUS PROBLEMS
AGARTALA GT	6		04/12/2019 04:55	04/12/2019 06:51	GT-MISCELLANEOUS PROBLEMS
AGARTALA GT	6		04/12/2019 11:02	04/12/2019 16:32	GT-MISCELLANEOUS PROBLEMS
Total		3,976.50			