

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 04-12-2019

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
DADRI (NCTPP)	4	210.00	04/12/2019 00:00		BOILER OVERHAUL/ ANNUAL MAINTENANCE
LARA TPP	1	800.00	04/12/2019 17:17		ELECTRICAL MISCELLANEOUS PROBLEMS
KORBA-WEST TPS	5	500.00	04/12/2019 05:07		FUEL SUPPLY & OTHER MISC. PROBLEMS
KUTCH LIG. TPS	4	75.00	04/12/2019 17:44		WATER WALL TUBE LEAKAGE
BHUSAWAL TPS	5	500.00	04/12/2019 07:02		CONDENSER LOW VACCUM
SIMHADRI	4	500.00	04/12/2019 16:48		I.D. FANS PROBLEM
PAINAMPURAM TPP	2	660.00	04/12/2019 16:32		FUEL OIL PROBLEM
RAICHUR TPS	6	210.00	04/12/2019 14:39		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	4	210.00	04/12/2019 00:46		C&I PROBLEM
NEYVELI TPS-II	4		04/12/2019 08:29		GENERATOR MISCELLANEOUS MAINTENANCE
VALLUR TPP	2	500.00	04/12/2019 00:30		RESERVE SHUT DOWN / STANDBY UNIT
TUTICORIN TPS	1	210.00	04/12/2019 18:15	06/12/2019	BOILER AUX. MISC. PROMLEMS
RAMAGUNDEM STPS	1	200.00	04/12/2019 11:54		TURBINE MISC. PROBLEMS
KOTHAGUNDEM TPS	7	120.00	04/12/2019 15:18		WATER WALL TUBE LEAKAGE
DURGAPUR TPS	4	210.00	04/12/2019 00:10		WATER WALL TUBE LEAKAGE
BUDGE BUDGE TPS	3	250.00	04/12/2019 23:12	15/12/2019	SCHEDULED ANNUAL MAINTENANCE
KATHALGURI CCPP	6	33.50	04/12/2019 00:00		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	1	9.96	04/12/2019 22:31		Fuel Shortage
AGARTALA GT	3	21.00	04/12/2019 16:29		GT- GAS/FUEL LEAKAGE
AGARTALA GT	4	21.00	04/12/2019 11:03		GT-MISCELLANEOUS PROBLEMS
AGARTALA GT	6	25.50	04/12/2019 06:57		GT-MISCELLANEOUS PROBLEMS
AGARTALA GT	6		04/12/2019 04:55		GT-MISCELLANEOUS PROBLEMS
AGARTALA GT	6		04/12/2019 11:02		GT-MISCELLANEOUS PROBLEMS
Total		5265.97			