

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS: 05-May-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date of Maintanance DD/MM/YYYY HH24:MM	Sync Date DD/MM/YYYY HH24:MM	remarks
1	2	3	4	5	6
SHREE CEMENT LTD TPS	3	19.0	5/5/26, 5:10 AM	5/5/26, 6:31 PM	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	5/5/26, 5:10 AM	5/5/26, 6:28 PM	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.0	5/5/26, 5:00 AM	5/5/26, 6:34 PM	RSD/LOW SCHEDULE
OP JINDAL TPS	4	250.0	5/3/26, 1:16 AM	5/5/26, 4:16 PM	AIR PREHEATERS PROBLEM
BINA TPS	1	250.0	5/4/26, 7:54 PM	5/5/26, 12:10 AM	TRANSMISSION CONSTRAINTS
MAHAN TPP	2	600.0	5/5/26, 2:27 PM	5/5/26, 7:31 PM	CONDENSER LOW VACCUM
WANAKBORI TPS	8	800.0	5/3/26, 3:09 AM	5/5/26, 8:55 PM	MAIN STEAM LINE PROBLEM
PARAS TPS	3	250.0	5/5/26, 8:17 PM	5/5/26, 10:33 PM	TURBINE BEARING PROBLEM
METTUR TPS	1	210.0	5/3/26, 1:38 AM	5/5/26, 1:12 PM	BOILER MISC. PROBLEM
METTUR TPS-II	1	600.0	5/5/26, 12:00 AM	5/5/26, 2:16 PM	RESERVE SHUT DOWN / STANDBY UNIT
NORTH CHENNAI TPS STAGE 2	4	600.0	4/29/26, 3:35 AM	5/5/26, 3:33 PM	DRUM LEVEL LOW
NEYVELI TPS-II	4	210.0	5/1/26, 12:00 AM	5/5/26, 3:39 AM	RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	4		5/5/26, 3:41 AM	5/5/26, 4:26 AM	TURBINE OIL SYSTEM PROBLEM
SINGARENI TPP	1	600.0	5/3/26, 7:52 AM	5/5/26, 2:22 AM	WATER WALL TUBE LEAKAGE
RAMAGUNDEM STPS	1	200.0	5/3/26, 8:59 AM	5/5/26, 3:15 PM	RSD/LOW SCHEDULE
RAMAGUNDEM STPS	1		5/5/26, 3:15 PM	5/5/26, 8:08 PM	TURBINE MISC.
RAMAGUNDEM STPS	4	500.0	5/3/26, 9:30 AM	5/5/26, 2:14 PM	RSD/LOW SCHEDULE
RAMAGUNDEM STPS	6	500.0	5/3/26, 5:00 AM	5/5/26, 3:26 PM	TURBINE MISC.
YADADRI TPS	1	800.0	5/3/26, 8:03 PM	5/5/26, 2:55 AM	COAL FEEDING PROBLEM IN PLANT
KAHALGAON TPS	4	210.0	5/1/26, 2:00 PM	5/5/26, 2:56 PM	RSD/LOW SCHEDULE
BUXAR TPP	1	660.0	5/5/26, 9:12 AM	5/5/26, 5:21 PM	F.D. FANS PROBLEM
KAMALANGA TPS	3	350.0	5/5/26, 3:37 AM	5/5/26, 8:53 AM	GRID DISTURBANCE
DERANG TPP	1	600.0	5/5/26, 3:20 PM	5/5/26, 5:26 PM	GENERATOR MISCLLANEOUS MAINTENANCE
JSW Energy Utkal Limited	2	350.0	4/27/26, 12:46 PM	5/5/26, 5:04 AM	AIR PREHEATERS PROBLEM
JSW Energy Utkal Limited	2		5/5/26, 4:22 PM	5/5/26, 6:21 PM	P.A. FANS PROBLEM
AGARTALA GT	2	21.0	5/5/26, 12:00 AM	5/5/26, 11:59 PM	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	3	9.965	5/4/26, 12:00 PM	5/5/26, 12:09 PM	GRID DISTURBENCE
KATHALGURI CCPP	1	33.5	5/5/26, 1:21 PM	5/5/26, 3:53 PM	MISC. SHORT DURATION MAINTENANCE
KATHALGURI CCPP	3	33.5	5/5/26, 12:00 AM	5/5/26, 11:59 PM	Low system demand/ costly fuel

Total	8681.97			
--------------	---------	--	--	--

" ** " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

- Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-