

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 05-May-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
GH TPS (LEH.MOH.)	1	210.00	5/5/26, 1:26 PM		BOILER MISC. PROBLEM
JALIPA KAPURDI TPP	3	135.00	5/5/26, 12:43 PM		BOILER MISC. PROBLEM
CHHABRA-II TPP	5	660.00	5/5/26, 12:34 PM		ABNORMAL SOUND
SHREE CEMENT LTD TPS	3	19.00	5/5/26, 5:10 AM	2026-05-05 18:31:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	5/5/26, 5:10 AM	2026-05-05 18:28:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	5/5/26, 5:00 AM	2026-05-05 18:34:00	RSD/LOW SCHEDULE
BINJKOTE TPP	1	300.00	5/5/26, 4:06 PM		AIR PREHEATERS PROBLEM
MAHAN TPP	2	600.00	5/5/26, 2:27 PM	2026-05-05 19:31:00	CONDENSER LOW VACCUM
WANAKBORI TPS	8	800.00	5/5/26, 11:58 PM		TURBINE CONTROL VALVE PROBLEM
PARAS TPS	3	250.00	5/5/26, 8:17 PM	2026-05-05 22:33:00	TURBINE BEARING PROBLEM
AMRAVATI TPS	5	270.00	5/5/26, 7:00 AM		TURBINE VIBRATIONS HIGH
METTUR TPS-II	1	600.00	5/5/26, 12:00 AM	2026-05-05 14:16:00	RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	4	210.00	5/5/26, 3:41 AM	2026-05-05 04:26:00	TURBINE OIL SYSTEM PROBLEM
ITPCL TPP	1	600.00	5/5/26, 10:27 PM		AIR PREHEATERS PROBLEM
RAMAGUNDEM STPS	1	200.00	5/5/26, 3:15 PM	2026-05-05 20:08:00	TURBINE MISC.
BUXAR TPP	1	660.00	5/5/26, 9:12 AM	2026-05-05 17:21:00	F.D. FANS PROBLEM
KAMALANGA TPS	3	350.00	5/5/26, 3:37 AM	2026-05-05 08:53:00	GRID DISTURBANCE
DERANG TPP	1	600.00	5/5/26, 3:20 PM	2026-05-05 17:26:00	GENERATOR MISCELLANEOUS MAINTENANCE
JSW Energy Utkal Limited	2	350.00	5/5/26, 4:22 PM	2026-05-05 18:21:00	P.A. FANS PROBLEM
AGARTALA GT	2	21.00	5/5/26, 12:00 AM	2026-05-05 23:59:59	Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	6	9.96	5/5/26, 12:32 PM		GRID DISTURBENCE
KATHALGURI CCPP	1	33.50	5/5/26, 1:21 PM	2026-05-05 15:53:00	MISC. SHORT DURATION MAINTENANCE
KATHALGURI CCPP	3	33.50	5/5/26, 12:00 AM	2026-05-05 23:59:59	Low system demand/ costly fuel

Total	6936.97			
--------------	---------	--	--	--

" ** " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

- Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-