

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 05-09-2024

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
RAJIV GANDHI TPS	2	600.00	05/09/2024 20:08		ECONOMISER TUBE LEAKAGE
ANTA CCPP	2	88.71	05/09/2024 20:45	05/09/2024	NO/REDUCED IRRIGATION DEMAND
ANTA CCPP	3	88.71	05/09/2024 20:45	05/09/2024	NO/REDUCED IRRIGATION DEMAND
RAMGARH CCPP	2	35.50	05/09/2024 15:35		OIL LEAKAGE PROBLEM OPU/SUM/SYSTEM
RAMGARH CCPP	4	37.50	05/09/2024 15:38		MISCELLANEOUS
JALIPA KAPURDI TPP	7	135.00	05/09/2024 06:43		BOILER MISC. PROBLEM
SHREE CEMENT LTD TPS	1	150.00	05/09/2024 04:08		GENERATOR EARTH FAULT
UNCHA HAR TPS	5	210.00	05/09/2024 14:49		FURNACE FIRE OUT /FLAME FAILURE
AURAIYA CCPP	1	111.19	05/09/2024 20:17	05/09/2024	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	2	111.19	05/09/2024 20:17	05/09/2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	05/09/2024 20:16	05/09/2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	05/09/2024 20:18	05/09/2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	05/09/2024 20:27	05/09/2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	05/09/2024 20:30	05/09/2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	05/09/2024 20:28	05/09/2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	05/09/2024 20:28	05/09/2024	CONSERVATION OF MAIN FUEL/RSD
OBRA TPS	10	200.00	05/09/2024 16:39		DRUM LEVEL LOW
BINJKOTE TPP	2	300.00	05/09/2024 12:17		P.A. FANS PROBLEM
GANDHAR CCPP	1	144.30	05/09/2024 20:24	05/09/2024	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	2	144.30	05/09/2024 20:19	05/09/2024	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	3	144.30	05/09/2024 20:31	05/09/2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	1	106.00	05/09/2024 20:25	05/09/2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	2	106.00	05/09/2024 20:23	05/09/2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	3	106.00	05/09/2024 20:34	05/09/2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	4	106.00	05/09/2024 20:04	05/09/2024	NO/REDUCED IRRIGATION DEMAND
SIKKA REP. TPS	3	250.00	05/09/2024 15:48		RESERVE SHUT DOWN
SIKKA REP. TPS	4	250.00	05/09/2024 17:21		RESERVE SHUT DOWN
DHUVARAN CCPP	1	67.85	05/09/2024 17:17		NO Power purchase agreement
DHUVARAN CCPP	3	72.00	05/09/2024 00:00		RESERVE SHUT DOWN
DHUVARAN CCPP	5	376.10	05/09/2024 00:00		RESERVE SHUT DOWN
UTRAN CCPP	5	240.00	05/09/2024 00:00	05/09/2024	RESERVE SHUT DOWN/ STANDBY.
UTRAN CCPP	6	134.00	05/09/2024 00:00	05/09/2024	RESERVE SHUT DOWN/ STANDBY.

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
GADARWARA TPP	1	800.00	05/09/2024 20:24		NO/REDUCED IRRIGATION DEMAND
RATNAGIRI CCPP	8	213.00	05/09/2024 23:39		GT-MISCELLANEOUS PROBLEMS
BHUSAWAL TPS	5	500.00	05/09/2024 10:49		ECONOMISER TUBE LEAKAGE
KHAPARKHEDA TPS	3	210.00	05/09/2024 07:33		FURNACE DRAFT ABNORMAL
SIMHADRI	2	500.00	05/09/2024 09:16	05/09/2024	SUPER HEATER TUBE LEAKAGE
DAMODARAM SANJEEVAIAH TPS	3	800.00	05/09/2024 21:24		BOILER MISC. PROBLEM
THAMMINAPATNAM TPS	1	150.00	05/09/2024 10:59	06/09/2024	TURBINE VIBRATION HIGH
RAICHUR TPS	8	250.00	05/09/2024 10:11		WATER WALL TUBE LEAKAGE
TUTICORIN TPS	1	210.00	05/09/2024 21:13		BOILER MISC. PROBLEM
TUTICORIN TPS	5	210.00	05/09/2024 08:10		SUPER HEATER TUBE LEAKAGE
OPG Power Generation Private Limited	1	77.00	05/09/2024 10:14		GRID DISTURBANCE
BAKRESWAR TPS	5	210.00	05/09/2024 11:53		TURBINE VIBRATION HIGH
KATHALGURI CCPP	1	33.50	05/09/2024 00:00		Fuel Shortage
KATHALGURI CCPP	4	33.50	05/09/2024 21:10		Fuel Shortage
LAKWA REPLACEMENT POWER PROJECT	2	9.96	05/09/2024 09:33		GRID DISTURBANCES MISC.
LAKWA REPLACEMENT POWER PROJECT	6	9.96	05/09/2024 16:58		Fuel Shortage
AGARTALA GT	1	21.00	05/09/2024 20:36		MISCELLANEOUS
AGARTALA GT	4	21.00	05/09/2024 10:17		LOW SYSTEM DEMAND
AGARTALA GT	4		05/09/2024 00:00		Fuel Shortage
AGARTALA GT	6	25.50	05/09/2024 00:00		Fuel Shortage
Total		9342.22			