CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS: 05-Nov-2026 **Sub - Report 14**

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
PANIPAT TPS	6	210.0	11/4/26, 10:32PM	11/5/26, 12:31AM	FURNACE FIRE OUT /FLAME FAILURE
PANIPAT TPS	8		11/5/26, 8:35AM	11/5/26, 10:50AM	FURNACE FIRE OUT /FLAME FAILURE
PANIPAT TPS	8	250.0	11/5/26, 12:31PM	11/5/26, 2:27PM	DRUM LEVEL LOW
JALIPA KAPURDI TPP	3	135.0	11/5/26, 4:30AM	11/5/26, 7:33PM	BOILER MISC. PROBLEM
JALIPA KAPURDI TPP	7	135.0	11/2/26, 7:08AM	11/5/26, 9:58AM	BOILER MISC. PROBLEM
JALIPA KAPURDI TPP	8	135.0	11/4/26, 2:32AM	11/5/26, 3:09PM	BOILER MISC. PROBLEM
SHREE CEMENT LTD TPS	3	19.0	11/5/26, 8:00AM	11/5/26, 3:52PM	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	11/5/26, 7:55AM	11/5/26, 3:46PM	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.0	11/5/26, 6:20AM	11/5/26, 3:58PM	RSD/LOW SCHEDULE
LALITPUR TPS	3	660.0	11/2/26, 3:00AM	11/5/26, 8:52AM	BOILER MISC. PROBLEM
ROSA TPP Ph-I	2	300.0	10/30/26, 9:01PM	11/5/26, 11:26PM	REHEATER TUBE LEAKAGE
OP JINDAL TPS	2	250.0	11/5/26, 5:35PM	11/5/26, 10:06PM	FURNACE DRAFT ABNORMAL
OP JINDAL TPS	3	250.0	11/3/26, 9:28AM	11/5/26, 3:40AM	STATOR/ STATOR EARTH FAULT
SASAN UMTPP	4	660.0	11/3/26, 3:57PM	11/5/26, 1:40AM	REHEATER TUBE LEAKAGE
NIGRI TPP	1	660.0	11/4/26, 10:57PM	11/5/26, 1:55AM	GENERATOR PROTECTION RELAY OPERATION PROBLEM
SUGEN CCPP	1	382.5	10/23/26, 12:00AM	11/5/26, 11:29AM	RSD/LOW SCHEDULE
SOLAPUR STPS	1	660.0	11/2/26, 6:38PM	11/5/26, 10:49PM	SUPER HEATER TUBE LEAKAGE
URAN CCPP	10	120.0	11/4/26, 7:31PM	11/5/26, 1:33AM	Fuel Shortage
MUTHIARA TPP	1	600.0	11/4/26, 11:26PM	11/5/26, 6:44AM	GENERATOR PROTECTION RELAY OPERATION PROBLEM
NEYVELI (EXT) TPS	2	210.0	11/5/26, 5:48PM	11/5/26, 10:23PM	BOILER AUX. MISC. PROMLEMS
OPG Power Generation Private Limited	3	80.0	11/5/26, 7:30AM	11/5/26, 8:45AM	MILLING SYSTEM /RC FEEDER PROBLEM
RAYALASEEMA TPS	2	210.0	11/3/26, 5:46PM	11/5/26, 5:33AM	SUPER HEATER TUBE LEAKAGE
BARH STPS	1	660.0	11/2/26, 11:24AM	11/5/26, 7:34PM	REHEATER TUBE LEAKAGE
NORTH KARANPURA TPP	1	660.0	11/2/26, 8:25PM	11/5/26, 5:40PM	AIR PREHEATERS PROBLEM
AGARTALA GT	2	21.0	11/5/26, 12:00AM	11/5/26, 9:15AM	Fuel Shortage
KATHALGURI CCPP	6	33.5	11/5/26, 12:00AM	11/5/26, 9:08AM	Fuel Shortage

Total	7326.00			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities.

Remarks:-

Report Version :-