**CENTRAL ELECTRICITY AUTHORITY**
**G O & D WING**
**OPERATION PERFORMANCE MONITORING DIVISION**

**THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 05-Nov-2026**

**Sub - Report 15**

| Station | Unit No. | Capacity(MW) | Date& Time of Maintenance<br>DD/MM/YYYY HH24:MM | Expected/sync Date of Return<br>DD/MM/YYYY HH24:MM | Reasons/Present Status |
|---|---|---|---|---|---|
| 1 | 2 | 3 | 4 | 5 | 6 |
| PANIPAT TPS | 8 | 250.00 | 11/5/26, 12:31PM | 2026-11-05 14:27:00 | DRUM LEVEL LOW |
| PANIPAT TPS | 8 | | 11/5/26, 8:35AM | 2026-11-05 10:50:00 | FURNACE FIRE OUT /FLAME FAILURE |
| JALIPA KAPURDI TPP | 3 | 135.00 | 11/5/26, 4:30AM | 2026-11-05 19:33:00 | BOILER MISC. PROBLEM |
| SHREE CEMENT LTD TPS | 3 | 19.00 | 11/5/26, 8:00AM | 2026-11-05 15:52:00 | RSD/LOW SCHEDULE |
| SHREE CEMENT LTD TPS | 4 | 19.00 | 11/5/26, 7:55AM | 2026-11-05 15:46:00 | RSD/LOW SCHEDULE |
| SHREE CEMENT LTD TPS | 5 | 6.00 | 11/5/26, 6:20AM | 2026-11-05 15:58:00 | RSD/LOW SCHEDULE |
| PANKI TPS EXT | 1 | 660.00 | 11/5/26, 9:14PM | | H.T./L.T. SUPPLY PROBLEM |
| OP JINDAL TPS | 2 | 250.00 | 11/5/26, 5:35PM | 2026-11-05 22:06:00 | FURNACE DRAFT ABNORMAL |
| MAHAN TPP | 2 | 600.00 | 11/5/26, 2:00AM | | AIR PREHEATERS PROBLEM |
| WANAKBORI TPS | 1 | 210.00 | 11/5/26, 8:28AM | | P.A. FANS PROBLEM |
| SUGEN CCPP | 1 | 382.50 | 11/5/26, 12:00AM | | RSD/LOW SCHEDULE |
| SUGEN CCPP | 2 | 382.50 | 11/5/26, 12:00AM | | RSD/LOW SCHEDULE |
| KAWAS CCPP | 6 | 116.10 | 11/5/26, 12:00PM | 2026-11-05 | CONSERVATION OF MAIN FUEL/RSD |
| BHUSAWAL TPS | 3 | 210.00 | 11/5/26, 7:40PM | | MISCELLANEOUS |
| MUTHIARA TPP | 1 | 600.00 | 11/5/26, 6:27PM | | TURBINE MISC. PROBLEM |
| NEYVELI ( EXT) TPS | 2 | 210.00 | 11/5/26, 5:48PM | 2026-11-05 22:23:00 | BOILER AUX. MISC. PROMLEMS |
| OPG Power Generation Private Limited | 3 | 80.00 | 11/5/26, 7:30AM | 2026-11-05 08:45:00 | MILLING SYSTEM /RC FEEDER PROBLEM |
| DARLIPALI STPS | 2 | 800.00 | 11/5/26, 12:14PM | | WATER WALL TUBE LEAKAGE |
| AGARTALA GT | 2 | 21.00 | 11/5/26, 12:00AM | 2026-11-05 09:15:31 | Fuel Shortage |
| KATHALGURI CCPP | 6 | 33.50 | 11/5/26, 12:00AM | 2026-11-05 09:08:35 | Fuel Shortage |
| **Total** | | 4984.60 | | | |

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities.

**Remarks:-**

**Report Version :-**