

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 06-06-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date & Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Northern									
Punjab	ROPAR TPS	4	210.00	0.00	0.00	0.00	14/03/2026 10:56		BOILER OVERHAUL/ ANNUAL MAINTENANCE
Rajasthan	BARSINGSAR LIGNITE	2	0.00	0.00	125.00	0.00	01/06/2026 09:29		BOILER MISC. PROBLEM
Rajasthan	DAE (RAJASTHAN)	1	0.00	0.00	0.00	0.00	09/10/2004 22:58		GENERATOR EARTH FAULT
Rajasthan	GIRAL TPS	1	125.00	0.00	0.00	0.00	11/07/2014 08:20		UNIT LIKELY TO BE SCRAPPED.
Rajasthan	GIRAL TPS	2	125.00	0.00	0.00	0.00	27/01/2016 15:27		UNIT LIKELY TO BE SCRAPPED.
Rajasthan	KALISINDH TPS	1	0.00	0.00	600.00	0.00	05/06/2026 19:23		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
Rajasthan	SURATGARH TPS	4	0.00	0.00	250.00	0.00	05/06/2026 16:58		BOILER MISC. PROBLEM
Rajasthan	ADANI POWER LIMITED KAWAI TPP	1	0.00	0.00	0.00	0.00	06/06/2026 10:27	06/06/2026 11:03	GEN. TRANS DAMAGED
Rajasthan	JALIPA KAPURDI TPP	2	0.00	0.00	135.00	0.00	04/06/2026 06:14		BOILER MISC. PROBLEM
Rajasthan	JALIPA KAPURDI TPP	8	0.00	135.00	0.00	0.00	26/04/2026 02:11		BOILER MISC. PROBLEM
Rajasthan	SHREE CEMENT LTD TPS	2	0.00	150.00	0.00	0.00	25/04/2026 16:20		P.A. FANS PROBLEM
Rajasthan	SHREE CEMENT LTD TPS	3	0.00	0.00	0.00	0.00	06/06/2026 05:10	06/06/2026 16:31	RSD/LOW SCHEDULE
Rajasthan	SHREE CEMENT LTD TPS	4	0.00	0.00	0.00	0.00	06/06/2026 05:10	06/06/2026 16:29	RSD/LOW SCHEDULE
Rajasthan	SHREE CEMENT LTD TPS	5	0.00	0.00	0.00	0.00	06/06/2026 05:00	06/06/2026 16:35	RSD/LOW SCHEDULE
Uttar Pradesh	GHATAMPUR TPP	1	0.00	0.00	0.00	0.00	05/06/2026 23:11	06/06/2026 01:38	C&I PROBLEM
Uttar Pradesh	GHATAMPUR TPP	2	0.00	0.00	660.00	0.00	24/05/2026 23:30		H.P. AND L.P. bypass system
Uttar Pradesh	KHURJA TPP	1	0.00	0.00	660.00	0.00	06/06/2026 01:42		ABNORMAL BOILER OPERATIONAL PARAMETER
Uttar Pradesh	RIHAND STPS	4	0.00	0.00	500.00	0.00	04/06/2026 00:00		C&I PROBLEM

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 06-06-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Uttar Pradesh	TANDA TPS	1	0.00	110.00	0.00	0.00	30/06/2025 23:05		CONSERVATION OF MAIN FUEL/RSD
Uttar Pradesh	TANDA TPS	2	0.00	110.00	0.00	0.00	30/06/2025 23:17		CONSERVATION OF MAIN FUEL/RSD
Uttar Pradesh	TANDA TPS	3	0.00	110.00	0.00	0.00	31/08/2025 23:58		CONSERVATION OF MAIN FUEL/RSD
Uttar Pradesh	TANDA TPS	4	0.00	110.00	0.00	0.00	31/08/2025 23:58		RESERVE SHUT DOWN / STANDBY UNIT
Uttar Pradesh	HARDUAGANJ TPS	8	0.00	0.00	0.00	0.00	14/01/2026 22:17		RESERVE SHUT DOWN / STANDBY UNIT
Uttar Pradesh	HARDUAGANJ TPS	10	0.00	0.00	660.00	0.00	05/06/2026 12:31		WATER WALL TUBE LEAKAGE
Uttar Pradesh	OBRA TPS	10	0.00	0.00	200.00	0.00	04/06/2026 11:13		WATER WALL TUBE LEAKAGE
Uttar Pradesh	PRAYAGRAJ TPP	3	0.00	0.00	0.00	0.00	04/06/2026 21:38	06/06/2026 09:27	ELECTRICAL MISCELLANEOUS PROBLEMS
Total Northern			460.00	725.00	3,790.00	0.00			
Western									
Chhatisgarh	KORBA STPS	5	500.00	0.00	0.00	0.00	15/05/2026 12:07		OVERHAULING WORKS
Chhatisgarh	KORBA-WEST TPS	3	0.00	210.00	0.00	0.00	18/04/2026 10:59		INSTRUMENT AIR SYSTEM FAILURE
Chhatisgarh	KORBA-WEST TPS	4	0.00	210.00	0.00	0.00	22/04/2026 14:07		ASH HANDLING SYSTEM PROBLEM
Chhatisgarh	KORBA-WEST TPS	5	0.00	0.00	0.00	0.00	04/06/2026 05:45	06/06/2026 03:10	WATER WALL TUBE LEAKAGE
Chhatisgarh	BINJKOTE TPP	2	0.00	0.00	0.00	0.00	06/06/2026 12:11	06/06/2026 16:26	FURNACE DRAFT ABNORMAL
Chhatisgarh	KATGHORA TPP	1	0.00	0.00	0.00	0.00	15/10/2012 00:28		No Fuel Supply Agreement
Chhatisgarh	PATHADI TPP	1	0.00	0.00	0.00	0.00	06/06/2026 23:30		H.P. AND L.P. bypass system
Chhatisgarh	SALORA TPP	1	0.00	0.00	0.00	0.00	19/10/2014 04:30		No Fuel Supply Agreement
Chhatisgarh	SVPL TPP	1	0.00	0.00	0.00	0.00	06/06/2026 23:59		I.D. FANS PROBLEM
Chhatisgarh	SWASTIK KORBA TPP	1	0.00	0.00	0.00	0.00	01/04/2015 00:20		No Fuel Supply Agreement
Chhatisgarh	Vedanta Ltd	1	0.00	600.00	0.00	0.00	14/04/2026 14:33		P.A. FANS PROBLEM

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 06-06-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Chhattisgarh	Chhattisgarh TPP	1	0.00	600.00	0.00	0.00	14/04/2026 14:33		P.A. FANS PROBLEM
Gujarat	KAKRAPARA	1	0.00	0.00	0.00	0.00	06/06/2026 21:52		BOILER MISC. PROBLEM
Gujarat	AKRIMOTA LIG TPS	2	125.00	0.00	0.00	0.00	04/06/2026 23:15		BOILER INSPECTION/ RE-CERTIFICATION
Gujarat	GANDHI NAGAR TPS	3	0.00	0.00	210.00	0.00	06/06/2026 00:25		MILLING SYSTEM /RC FEEDER PROBLEM
Gujarat	GANDHI NAGAR TPS	5	0.00	0.00	210.00	0.00	06/06/2026 00:25		MILLING SYSTEM /RC FEEDER PROBLEM
Gujarat	KUTCH LIG. TPS	4	0.00	75.00	0.00	0.00	05/07/2023 07:05		COOLING TOWER PROBLEM
Gujarat	UKAI TPS	3	200.00	0.00	0.00	0.00	20/11/2025 00:00		R AND M / REFURBISHMENT works
Gujarat	UKAI TPS	6	0.00	0.00	500.00	0.00	31/05/2026 01:45		AIR PREHEATERS PROBLEM
Gujarat	WANAKBORI TPS	2	0.00	0.00	210.00	0.00	29/05/2026 07:18		RSD/LOW SCHEDULE
Gujarat	SABARMATI (D-F STATIONS)	1	0.00	0.00	120.00	0.00	04/06/2026 01:51		TURBINE VIBRATIONS HIGH
Gujarat	SURAT LIG. TPS	1	0.00	0.00	125.00	0.00	03/06/2026 15:30		WATER WALL TUBE LEAKAGE
Gujarat	SURAT LIG. TPS	4	0.00	0.00	125.00	0.00	06/06/2026 13:17		WATER WALL TUBE LEAKAGE
Madhya Pradesh	VINDHYACHAL STPS	1	210.00	0.00	0.00	0.00	07/05/2026 01:04		OVERHAULING WORKS
Madhya Pradesh	SANJAY GANDHI TPS	4	0.00	210.00	0.00	0.00	16/04/2026 13:13		STATOR/ STATOR EARTH FAULT
Maharashtra	TARAPUR	2	0.00	0.00	160.00	0.00	06/06/2026 00:01		Miscellaneous
Maharashtra	BHUSAWAL TPS	6	0.00	0.00	660.00	0.00	03/06/2026 13:05	06/06/2026 23:43	WATER WALL TUBE LEAKAGE
Maharashtra	CHANDRAPUR (MAHARASHTRA) STPS	7	0.00	0.00	0.00	0.00	03/06/2026 01:30	06/06/2026 06:37	WATER WALL TUBE LEAKAGE
Maharashtra	CHANDRAPUR (MAHARASHTRA) STPS	8	0.00	0.00	500.00	0.00	06/06/2026 10:20		WATER WALL TUBE LEAKAGE
Maharashtra	AMRAVATI TPS	5	0.00	0.00	270.00	0.00	06/06/2026 19:42		ASH HANDLING SYSTEM PROBLEM

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 06-06-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Maharashtra	DHARIWAL TPP	2	0.00	0.00	300.00	0.00	05/06/2026 01:03		CONDENSER TUBE LEAKAGE/ CLEANING
Maharashtra	GEPL TPP Ph-I	1	0.00	60.00	0.00	0.00	29/06/2013 00:00		No Fuel Supply Agreement
Maharashtra	GEPL TPP Ph-I	2	0.00	60.00	0.00	0.00	20/06/2013 20:27		No Fuel Supply Agreement
Maharashtra	MIHAN TPS	1	0.00	61.51	0.00	0.00	10/01/2013 15:50		No Fuel Supply Agreement
Maharashtra	MIHAN TPS	2	0.00	61.50	0.00	0.00	05/11/2013 11:53		No Fuel Supply Agreement
Maharashtra	MIHAN TPS	3	0.00	61.50	0.00	0.00	10/06/2013 18:00		No Fuel Supply Agreement
Maharashtra	MIHAN TPS	4	0.00	61.50	0.00	0.00	20/08/2013 10:00		No Fuel Supply Agreement
Maharashtra	NASIK (P) TPS	1	0.00	0.00	0.00	0.00	04/03/2014 18:10		UNIT LIKELY TO BE SCRAPPED.
Maharashtra	NASIK (P) TPS	2	0.00	0.00	0.00	0.00	16/02/2017 00:46		UNIT LIKELY TO BE SCRAPPED.
Maharashtra	NASIK (P) TPS	3	0.00	0.00	0.00	0.00	14/04/2017 01:45		UNIT LIKELY TO BE SCRAPPED.
Maharashtra	NASIK (P) TPS	4	0.00	0.00	0.00	0.00	20/05/2017 00:25		UNIT LIKELY TO BE SCRAPPED.
Maharashtra	NASIK (P) TPS	5	0.00	0.00	0.00	0.00	30/05/2017 15:24		UNIT LIKELY TO BE SCRAPPED.
Total Western			1,035.00	1,671.01	3,390.00	0.00			
Southern									
Andhra Pradesh	RAYALASEEMA TPS	6	0.00	0.00	600.00	0.00	06/06/2026 23:25		MAIN STEAM LINE PROBLEM
Andhra Pradesh	MEENAKSHI ENERGY LTD	1	0.00	150.00	0.00	0.00	15/05/2026 00:02		MAIN STEAM LINE PROBLEM
Andhra Pradesh	MEENAKSHI ENERGY LTD	3	0.00	0.00	350.00	0.00	06/06/2026 00:44		BOILER AUX. MISC. PROMLEMS
Andhra Pradesh	MEENAKSHI ENERGY LTD	4	0.00	0.00	350.00	0.00	26/05/2026 15:35		P.A. FANS PROBLEM
Andhra Pradesh	SIMHAPURI TPS	3	0.00	0.00	0.00	0.00	06/06/2026 05:17	06/06/2026 06:22	MAIN STEAM LINE PROBLEM
Karnataka	KAIGA	1	220.00	0.00	0.00	0.00	31/03/2025 23:11		MISCELLANEOUS PLANNED MAINTENANCE
Karnataka	RAICHUR TPS	1	0.00	210.00	0.00	0.00	15/03/2024 00:00		COAL FEEDING SYSTEM FAILURE.

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 06-06-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Karnataka	RAICHUR TPS	8	0.00	0.00	250.00	0.00	26/05/2026 18:37		WATER WALL TUBE LEAKAGE
Karnataka	YERMARUS TPP	1	0.00	0.00	800.00	0.00	04/06/2026 13:35		SUPER HEATER TUBE LEAKAGE
Karnataka	YERMARUS TPP	2	0.00	0.00	800.00	0.00	04/06/2026 10:27	06/06/2026 13:28	WATER WALL TUBE LEAKAGE
Tamil Nadu	NEYVELI NEW TPP	2	0.00	0.00	0.00	0.00	06/06/2026 03:30	06/06/2026 10:44	TURBINE MISC. PROBLEM
Tamil Nadu	NEYVELI TPS-II	1	210.00	0.00	0.00	0.00	14/05/2026 00:00		SCHEDULED ANNUAL MAINTENANCE
Tamil Nadu	NEYVELI TPS-II	3	0.00	0.00	210.00	0.00	05/06/2026 05:15		BOILER AUX. MISC. PROMLEMS
Tamil Nadu	NEYVELI TPS-II	5	0.00	0.00	210.00	0.00	29/05/2026 12:41		RESERVE SHUT DOWN / STANDBY UNIT
Tamil Nadu	NEYVELI TPS-II EXP	1	0.00	0.00	0.00	0.00	29/05/2026 04:26	06/06/2026 10:21	WATER WALL TUBE LEAKAGE
Tamil Nadu	NEYVELI TPS-II EXP	2	0.00	250.00	0.00	0.00	17/05/2026 00:00		RSD/LOW SCHEDULE
Tamil Nadu	NTPL TUTICORIN TPP	2	0.00	0.00	500.00	0.00	04/06/2026 18:41	06/06/2026 14:29	WATER WALL TUBE LEAKAGE
Tamil Nadu	MADRAS A.P.S.	1	0.00	220.00	0.00	0.00	30/01/2018 16:30		REACTOR MAINTENANCE WORKS.
Tamil Nadu	METTUR TPS	3	0.00	0.00	210.00	0.00	06/06/2026 04:41		HYDROGEN PRESSURE PROBLEM
Tamil Nadu	NORTH CHENNAI TPS STAGE 3	6	0.00	0.00	800.00	0.00	04/06/2026 22:20		FURNACE FIRE OUT /FLAME FAILURE
Tamil Nadu	TUTICORIN TPS	1	0.00	210.00	0.00	0.00	15/03/2025 21:50		FIRE IN CABLE GALLERY.
Tamil Nadu	TUTICORIN TPS	2	0.00	210.00	0.00	0.00	15/03/2025 22:01		FIRE IN CABLE GALLERY
Tamil Nadu	OPG Power Generation Private Limited	1	0.00	0.00	77.00	0.00	02/06/2026 11:00		AIR PREHEATERS PROBLEM
Tamil Nadu	TCP Limited	1	63.50	0.00	0.00	0.00	16/07/2021 05:21		MISCELLANEOUS PLANNED MAINTENANCE
Tamil Nadu	TUTICORIN (P) TPP	1	0.00	0.00	150.00	0.00	05/06/2026 03:10		MISCELLANEOUS
Tamil Nadu	TUTICORIN (P) TPP	2	0.00	150.00	0.00	0.00	09/05/2026 05:14		TURBINE VIBRATIONS HIGH
Tamil Nadu	TUTICORIN TPP ST-IV	1	0.00	0.00	525.00	0.00	28/05/2026 15:40		GRID DISTURBANCE

DAILY MAINTENANCE REPORT (COAL, LIGNITE AND NUCLEAR) 06-06-2026

Sub-Report-10

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Telangana	RAMAGUNDEM STPS	5	0.00	0.00	500.00	0.00	04/06/2026 04:44	06/06/2026 12:40	SUPER HEATER TUBE LEAKAGE
Telangana	YADADRI TPS	3	0.00	800.00	0.00	0.00	17/05/2026 12:30		BOILER FEED PUMP/MOTOR PROBLEM
Telangana	YADADRI TPS	4	0.00	800.00	0.00	0.00	30/04/2026 16:48		ECONOMISER TUBE LEAKAGE
Total Southern			493.50	3,000.00	6,332.00	0.00			
Eastern									
Bihar	BARAUNI TPS	8	0.00	0.00	250.00	0.00	26/05/2026 14:00		TURBINE BEARING PROBLEM
Bihar	BARH STPS	3	0.00	0.00	0.00	0.00	04/06/2026 21:38	06/06/2026 09:27	ELECTRICAL MISCELLANEOUS PROBLEMS
Jharkhand	PATRATU STPP	2	800.00	0.00	0.00	0.00	13/05/2026 12:23		MISCELLANEOUS PLANNED MAINTENANCE
Jharkhand	MAHADEV PRASAD STPP	2	0.00	0.00	0.00	0.00	06/06/2026 14:00	06/06/2026 15:22	ELECTRICAL MISCELLANEOUS PROBLEMS
Odisha	DARLIPALI STPS	2	0.00	0.00	800.00	0.00	06/06/2026 17:31		REHEATER TUBE LEAKAGE
Odisha	DERANG TPP	1	0.00	0.00	600.00	0.00	04/06/2026 11:30	06/06/2026 22:07	BOILER AUX. MISC. PROMLEMS
Odisha	KAMALANGA TPS	3	0.00	0.00	350.00	0.00	06/06/2026 01:00		AIR PREHEATERS PROBLEM
West Bengal	RAGHUNATHPUR TPP	2	0.00	600.00	0.00	0.00	14/04/2026 17:51		TURBINE VIBRATIONS HIGH
West Bengal	SAGARDIGHI TPS	2	0.00	0.00	300.00	0.00	06/06/2026 12:30		SUPER HEATER TUBE LEAKAGE
West Bengal	TITAGARH TPS	1	0.00	0.00	0.00	0.00	10/10/2016 04:57		RESERVE SHUT DOWN / STANDBY UNIT
West Bengal	TITAGARH TPS	2	0.00	0.00	0.00	0.00	09/10/2016 04:57		RESERVE SHUT DOWN / STANDBY UNIT
West Bengal	TITAGARH TPS	3	0.00	0.00	0.00	0.00	10/10/2016 04:18		RESERVE SHUT DOWN / STANDBY UNIT
West Bengal	TITAGARH TPS	4	0.00	0.00	0.00	0.00	09/10/2016 05:36		RESERVE SHUT DOWN / STANDBY UNIT
Total Eastern			800.00	600.00	2,300.00	0.00			

Total	2,788.50	5,996.01	15,812.00	0.00			
--------------	-----------------	-----------------	------------------	-------------	--	--	--

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-