

**DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 06-06-2026**

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date & Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Rajasthan	KALISINDH TPS	1	0.00	0.00	600.00	0.00	05/06/2026 19:23		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
Rajasthan	ADANI POWER LIMITED KAWAI TPP	1	0.00	0.00	0.00	0.00	06/06/2026 10:27	06/06/2026 11:03	GEN. TRANS DAMAGED
Uttar Pradesh	GHATAMPUR TPP	1	0.00	0.00	0.00	0.00	05/06/2026 23:11	06/06/2026 01:38	C&I PROBLEM
Uttar Pradesh	GHATAMPUR TPP	2	0.00	0.00	660.00	0.00	24/05/2026 23:30		H.P. AND L.P. bypass system
Uttar Pradesh	KHURJA TPP	1	0.00	0.00	660.00	0.00	06/06/2026 01:42		ABNORMAL BOILER OPERATIONAL PARAMETER
Uttar Pradesh	RIHAND STPS	4	0.00	0.00	500.00	0.00	04/06/2026 00:00		C&I PROBLEM
Uttar Pradesh	HARDUAGANJ TPS	10	0.00	0.00	660.00	0.00	05/06/2026 12:31		WATER WALL TUBE LEAKAGE
Uttar Pradesh	PRAYAGRAJ TPP	3	0.00	0.00	0.00	0.00	04/06/2026 21:38	06/06/2026 09:27	ELECTRICAL MISCELLANEOUS PROBLEMS
Chhatisgarh	KORBA STPS	5	500.00	0.00	0.00	0.00	15/05/2026 12:07		OVERHAULING WORKS
Chhatisgarh	KORBA-WEST TPS	5	0.00	0.00	0.00	0.00	04/06/2026 05:45	06/06/2026 03:10	WATER WALL TUBE LEAKAGE
Chhatisgarh	Vedanta Ltd Chhattisgarh TPP	1	0.00	600.00	0.00	0.00	14/04/2026 14:33		P.A. FANS PROBLEM
Gujarat	UKAI TPS	6	0.00	0.00	500.00	0.00	31/05/2026 01:45		AIR PREHEATERS PROBLEM
Maharashtra	BHUSAWAL TPS	6	0.00	0.00	660.00	0.00	03/06/2026 13:05	06/06/2026 23:43	WATER WALL TUBE LEAKAGE
Maharashtra	CHANDRAPUR (MAHARASHTRA) STPS	7	0.00	0.00	0.00	0.00	03/06/2026 01:30	06/06/2026 06:37	WATER WALL TUBE LEAKAGE
Maharashtra	CHANDRAPUR (MAHARASHTRA) STPS	8	0.00	0.00	500.00	0.00	06/06/2026 10:20		WATER WALL TUBE LEAKAGE
Andhra Pradesh	RAYALASEEMA TPS	6	0.00	0.00	600.00	0.00	06/06/2026 23:25		MAIN STEAM LINE PROBLEM
Karnataka	YERMARUS TPP	1	0.00	0.00	800.00	0.00	04/06/2026 13:35		SUPER HEATER TUBE LEAKAGE
Karnataka	YERMARUS TPP	2	0.00	0.00	800.00	0.00	04/06/2026 10:27	06/06/2026 13:28	WATER WALL TUBE LEAKAGE
Tamil Nadu	NEYVELI NEW TPP	2	0.00	0.00	0.00	0.00	06/06/2026 03:30	06/06/2026 10:44	TURBINE MISC. PROBLEM

**DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 06-06-2026**

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Tamil Nadu	NTPL TUTICORIN TPP	2	0.00	0.00	500.00	0.00	04/06/2026 18:41	06/06/2026 14:29	WATER WALL TUBE LEAKAGE
Tamil Nadu	NORTH CHENNAI TPS STAGE 3	6	0.00	0.00	800.00	0.00	04/06/2026 22:20		FURNACE FIRE OUT /FLAME FAILURE
Tamil Nadu	TUTICORIN TPP ST-IV	1	0.00	0.00	525.00	0.00	28/05/2026 15:40		GRID DISTURBANCE
Telangana	RAMAGUNDEM STPS	5	0.00	0.00	500.00	0.00	04/06/2026 04:44	06/06/2026 12:40	SUPER HEATER TUBE LEAKAGE
Telangana	YADADRI TPS	3	0.00	800.00	0.00	0.00	17/05/2026 12:30		BOILER FEED PUMP/MOTOR PROBLEM
Telangana	YADADRI TPS	4	0.00	800.00	0.00	0.00	30/04/2026 16:48		ECONOMISER TUBE LEAKAGE
Bihar	BARH STPS	3	0.00	0.00	0.00	0.00	04/06/2026 21:38	06/06/2026 09:27	ELECTRICAL MISCELLANEOUS PROBLEMS
Jharkhand	PATRATU STPP	2	800.00	0.00	0.00	0.00	13/05/2026 12:23		MISCELLANEOUS PLANNED MAINTENANCE
Odisha	DARLIPALI STPS	2	0.00	0.00	800.00	0.00	06/06/2026 17:31		REHEATER TUBE LEAKAGE
Odisha	DERANG TPP	1	0.00	0.00	600.00	0.00	04/06/2026 11:30	06/06/2026 22:07	BOILER AUX. MISC. PROMLEMS
West Bengal	RAGHUNATHPUR TPP	2	0.00	600.00	0.00	0.00	14/04/2026 17:51		TURBINE VIBRATIONS HIGH
<b>Total</b>			<b>1,300.00</b>	<b>2,800.00</b>	<b>10,665.00</b>	<b>0.00</b>			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.  
 2.Data published in this report is for operational purpose only and not for commercial purpose.  
 3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

**Remarks:-**

**Report Version**

:-