

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS: 06-Jun-2026

Sub - Report 14

| Station | Unit No. | Capacity(MW) | Date of Maintanance DD/MM/YYYY HH24:MM | Sync Date DD/MM/YYYY HH24:MM | Reasons/Present Status |
|-------------------------------|----------|--------------|---|---------------------------------|---|
| 1 | 2 | 3 | 4 | 5 | 6 |
| PRAGATI CCPP | 2 | 104.6 | 5/18/26, 10:30 AM | 6/6/26, 7:08 PM | GT-MISCELLANEOUS PROBLEMS |
| PRAGATI CCPP | 3 | 121.2 | 6/6/26, 7:21 PM | 6/6/26, 10:14 PM | GT-MISCELLANEOUS PROBLEMS |
| PRAGATI CCPP | 3 | | 6/6/26, 4:20 PM | 6/6/26, 5:53 PM | Instrumentation & Control System Abnormal |
| ADANI POWER LIMITED KAWAI TPP | 1 | 660.0 | 6/6/26, 6:58 AM | 6/6/26, 11:03 AM | TURBINE VIBRATIONS HIGH |
| ADANI POWER LIMITED KAWAI TPP | 1 | | 6/6/26, 10:27 AM | 6/6/26, 11:03 AM | GEN. TRANS DAMAGED |
| ANTA CCPP | 2 | 88.71 | 6/6/26, 1:02 AM | 6/6/26, 5:33 PM | CONSERVATION OF MAIN FUEL/RSD |
| SHREE CEMENT LTD TPS | 3 | 19.0 | 6/6/26, 5:10 AM | 6/6/26, 4:31 PM | RSD/LOW SCHEDULE |
| SHREE CEMENT LTD TPS | 4 | 19.0 | 6/6/26, 5:10 AM | 6/6/26, 4:29 PM | RSD/LOW SCHEDULE |
| SHREE CEMENT LTD TPS | 5 | 6.0 | 6/6/26, 5:00 AM | 6/6/26, 4:35 PM | RSD/LOW SCHEDULE |
| RIHAND STPS | 4 | 500.0 | 6/3/26, 2:27 PM | 6/6/26, 12:00 AM | WATER WALL TUBE LEAKAGE |
| GHATAMPUR TPP | 1 | 660.0 | 6/5/26, 11:11 PM | 6/6/26, 1:38 AM | C&I PROBLEM |
| AURAIYA CCPP | 3 | 111.19 | 6/6/26, 1:07 AM | 6/6/26, 6:22 PM | CONSERVATION OF MAIN FUEL/RSD |
| KORBA-WEST TPS | 5 | 500.0 | 6/4/26, 5:45 AM | 6/6/26, 3:10 AM | WATER WALL TUBE LEAKAGE |
| BINJKOTE TPP | 2 | 300.0 | 6/6/26, 12:11 PM | 6/6/26, 4:26 PM | FURNACE DRAFT ABNORMAL |
| BHUSAWAL TPS | 6 | 660.0 | 6/3/26, 1:05 PM | 6/6/26, 11:43 PM | WATER WALL TUBE LEAKAGE |
| CHANDRAPUR(MAHARASHTRA) STPS | 7 | 500.0 | 6/3/26, 1:30 AM | 6/6/26, 6:37 AM | WATER WALL TUBE LEAKAGE |
| RATNAGIRI CCPP | 5 | 213.0 | 6/6/26, 1:17 AM | 6/6/26, 6:25 PM | GT- LOW SYSTEM DAMAND |
| RATNAGIRI CCPP | 8 | 213.0 | 6/6/26, 1:46 AM | 6/6/26, 6:07 PM | GT- LOW SYSTEM DAMAND |
| TARAPUR | 2 | 160.0 | 7/13/20, 4:38 AM | 6/6/26, 12:56 PM | RENOVATION/MODERNISATION WORKS |
| YERMARUS TPP | 2 | 800.0 | 6/4/26, 10:27 AM | 6/6/26, 1:28 PM | WATER WALL TUBE LEAKAGE |
| NEYVELI TPS-II EXP | 1 | 250.0 | 5/29/26, 4:26 AM | 6/6/26, 10:21 AM | WATER WALL TUBE LEAKAGE |
| NEYVELI NEW TPP | 2 | 500.0 | 6/6/26, 3:30 AM | 6/6/26, 10:44 AM | TURBINE MISC. PROBLEM |
| NTPL TUTICORIN TPP | 2 | 500.0 | 6/4/26, 6:41 PM | 6/6/26, 2:29 PM | WATER WALL TUBE LEAKAGE |
| RAMAGUNDEM STPS | 5 | 500.0 | 6/4/26, 4:44 AM | 6/6/26, 12:40 PM | SUPER HEATER TUBE LEAKAGE |
| RAYALASEEMA TPS | 6 | 600.0 | 6/4/26, 4:06 PM | 6/6/26, 8:40 PM | FURNACE FIRE OUT /FLAME FAILURE |
| SIMHAPURI TPS | 3 | 150.0 | 6/6/26, 5:17 AM | 6/6/26, 6:22 AM | MAIN STEAM LINE PROBLEM |
| BARH STPS | 3 | 660.0 | 6/4/26, 9:38 PM | 6/6/26, 9:27 AM | ELECTRICAL MISCELLANEOUS PROBLEMS |
| MAHADEV PRASAD STPP | 2 | 270.0 | 6/6/26, 2:00 PM | 6/6/26, 3:22 PM | ELECTRICAL MISCELLANEOUS PROBLEMS |
| DERANG TPP | 1 | 600.0 | 6/4/26, 11:30 AM | 6/6/26, 10:07 PM | BOILER AUX. MISC. PROMLEMS |

| Station | Unit No. | Capacity(MW) | Date of Maintanance DD/MM/YYYY HH24:MM | Sync Date DD/MM/YYYY HH24:MM | Reasons/Present Status |
|-----------------|----------|--------------|---|---------------------------------|--------------------------------|
| 1 | 2 | 3 | 4 | 5 | 6 |
| AGARTALA GT | 1 | 21.0 | 6/6/26, 4:10 PM | 6/6/26, 11:59 PM | Fuel Shortage |
| AGARTALA GT | 2 | 21.0 | 6/6/26, 12:00 AM | 6/6/26, 4:00 PM | Fuel Shortage |
| AGARTALA GT | 5 | 25.5 | 6/6/26, 12:00 AM | 6/6/26, 11:59 PM | MINOR MAINTENANCE WORKS |
| KATHALGURI CCPP | 1 | 33.5 | 6/6/26, 12:00 AM | 6/6/26, 11:59 PM | Low system demand/ costly fuel |
| Total | | 9766.70 | | | |

Note: 1. Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
2. Data published in this report is for operational purpose only and not for commercial purpose.
3. Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-