

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 06-Jun-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
PRAGATI CCPP	1	104.60	6/6/26, 10:22 PM		Low system demand/ costly fuel
PRAGATI CCPP	3		6/6/26, 7:21 PM	2026-06-06 22:14:00	GT-MISCELLANEOUS PROBLEMS
PRAGATI CCPP	3	121.20	6/6/26, 4:20 PM	2026-06-06 17:53:00	Instrumentation & Control System Abnormal
ADANI POWER LIMITED KAWAI TPP	1		6/6/26, 6:58 AM	2026-06-06 11:03:00	TURBINE VIBRATIONS HIGH
ADANI POWER LIMITED KAWAI TPP	1	660.00	6/6/26, 10:27 AM	2026-06-06 11:03:00	GEN. TRANS DAMAGED
ANTA CCPP	2	88.71	6/6/26, 1:02 AM	2026-06-06 17:33:00	CONSERVATION OF MAIN FUEL/RSD
SHREE CEMENT LTD TPS	3	19.00	6/6/26, 5:10 AM	2026-06-06 16:31:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	6/6/26, 5:10 AM	2026-06-06 16:29:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	6/6/26, 5:00 AM	2026-06-06 16:35:00	RSD/LOW SCHEDULE
AURAIYA CCPP	3	111.19	6/6/26, 1:07 AM	2026-06-06 18:22:00	CONSERVATION OF MAIN FUEL/RSD
KHURJA TPP	1	660.00	6/6/26, 1:42 AM	2026-06-10	ABNORMAL BOILER OPERATIONAL PARAMETER
PATHADI TPP	1	300.00	6/6/26, 11:30 PM		H.P. AND L.P. bypass system
SVPL TPP	1	63.00	6/6/26, 11:59 PM		I.D. FANS PROBLEM
BINJKOTE TPP	2	300.00	6/6/26, 12:11 PM	2026-06-06 16:26:00	FURNACE DRAFT ABNORMAL
GANDHI NAGAR TPS	3	210.00	6/6/26, 12:25 AM		MILLING SYSTEM /RC FEEDER PROBLEM
SURAT LIG. TPS	4	125.00	6/6/26, 1:17 PM		WATER WALL TUBE LEAKAGE
KAKRAPARA	1	220.00	6/6/26, 9:52 PM		BOILER MISC. PROBLEM
CHANDRAPUR(MAHARASHTRA) STPS	8	500.00	6/6/26, 10:20 AM		WATER WALL TUBE LEAKAGE
RATNAGIRI CCPP	5	213.00	6/6/26, 1:17 AM	2026-06-06 18:25:00	GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.00	6/6/26, 1:46 AM	2026-06-06 18:07:00	GT- LOW SYSTEM DAMAND
AMRAVATI TPS	5	270.00	6/6/26, 7:42 PM		ASH HANDLING SYSTEM PROBLEM
TARAPUR	2	160.00	6/6/26, 12:01 AM		Miscellaneous
METTUR TPS	3	210.00	6/6/26, 4:41 AM	2026-06-07	HYDROGEN PRESSURE PROBLEM
NEYVELI NEW TPP	2	500.00	6/6/26, 3:30 AM	2026-06-06 10:44:00	TURBINE MISC. PROBLEM
RAYALASEEMA TPS	6	600.00	6/6/26, 11:25 PM		MAIN STEAM LINE PROBLEM
SIMHAPURI TPS	3	150.00	6/6/26, 5:17 AM	2026-06-06 06:22:00	MAIN STEAM LINE PROBLEM
MEENAKSHI ENERGY LTD	3	350.00	6/6/26, 12:44 AM		BOILER AUX. MISC. PROMLEMS
SAGARDIGHI TPS	2	300.00	6/6/26, 12:30 PM		SUPER HEATER TUBE LEAKAGE
MAHADEV PRASAD STPP	2	270.00	6/6/26, 2:00 PM	2026-06-06 15:22:00	ELECTRICAL MISCELLANEOUS PROBLEMS

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 06-Jun-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
DARLIPALI STPS	2	800.00	6/6/26, 5:31 PM	2026-06-06	REHEATER TUBE LEAKAGE
KAMALANGA TPS	3	350.00	6/6/26, 1:00 AM		AIR PREHEATERS PROBLEM
AGARTALA GT	1	21.00	6/6/26, 4:10 PM	2026-06-06 23:59:59	Fuel Shortage
AGARTALA GT	2	21.00	6/6/26, 12:00 AM	2026-06-06 16:00:00	Fuel Shortage
AGARTALA GT	5	25.50	6/6/26, 12:00 AM	2026-06-06 23:59:59	MINOR MAINTENANCE WORKS
KATHALGURI CCPP	1	33.50	6/6/26, 12:00 AM	2026-06-06 23:59:59	Low system demand/ costly fuel
Total		7994.70			

Note: 1.Actual generation is gross generation from stations above 25 MW. It excludes generation from RES.
 2.Data published in this report is for operational purpose only and not for commercial purpose.
 3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-