

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 07-02-2023

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PRAGATI CCPP	3	121.20	31/01/2023 17:29	07/02/2023 17:00	LOW SYSTEM DEMAND
ROPAR TPS	4	210.00	04/02/2023 03:57	07/02/2023 17:00	STATOR EARTH FAULT
SURATGARH STPS	8	660.00	07/02/2023 15:56	07/02/2023 21:10	BOILER MISC. PROBLEM
ANPARA TPS	2	210.00	07/02/2023 06:07	07/02/2023 08:30	DRUM LEVEL HIGH/ low
LALITPUR TPS	1	660.00	05/02/2023 10:00	07/02/2023 13:50	BOILER MISC. PROBLEM
SALAYA TPP	2	600.00	03/02/2023 23:00	07/02/2023 12:40	RESERVE SHUT DOWN / STANDBY UNIT
SUGEN CCPP	1	382.50	10/12/2022 00:00	07/02/2023 13:01	RESERVE SHUT DOWN / STANDBY UNIT
VINDHYACHAL STPS	11	500.00	07/02/2023 03:35	07/02/2023 11:46	BOILER AUX. MISC. PROMLEMS
BELLARY TPS	1	500.00	07/02/2023 11:43	07/02/2023 18:34	ELECTRICAL FAULT
RAICHUR TPS	2	210.00	07/02/2023 11:07	07/02/2023 13:34	FURNACE FIRE OUT /FLAME FAILURE
TUTICORIN TPS	4	210.00	05/02/2023 21:14	07/02/2023 09:54	BOILER AUX. MISC. PROMLEMS
TENUGHAT TPS	1	210.00	07/02/2023 11:20	07/02/2023 14:30	TURBINE VIBRATIONS HIGH
KATHALGURI CCPP	4	33.50	20/01/2023 17:30	07/02/2023 10:51	Fuel Shortage
LAKWA GT	7	20.00	05/02/2023 17:00	07/02/2023 17:01	MISCELLANOUS
NAMRUP CCPP	3	15.00	05/02/2023 12:13	07/02/2023 10:30	FUEL OIL SHORTAGE
NAMRUP CCPP	6	9.00	06/02/2023 21:25	07/02/2023 23:23	CONDENSATE PUMP problem
AGARTALA GT	4	21.00	07/02/2023 06:48	07/02/2023 08:30	MISCELLANEOUS
Total		4,572.20			