

DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 07-05-2026

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date & Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Haryana	RAJIV GANDHI TPS	1	0.00	0.00	600.00	0.00	03/05/2026 09:01		RESERVE SHUT DOWN / STANDBY UNIT
Punjab	TALWANDI SABO TPP	1	0.00	0.00	660.00	0.00	06/05/2026 00:59		ABNORMAL BOILER OPERATIONAL PARAMETER
Rajasthan	CHHABRA-II TPP	5	0.00	0.00	660.00	0.00	05/05/2026 12:34		ABNORMAL SOUND
Uttar Pradesh	GHATAMPUR TPP	2	0.00	0.00	660.00	0.00	06/05/2026 22:26		I.D. FANS PROBLEM
Uttar Pradesh	TANDA TPS	5	0.00	0.00	660.00	0.00	04/05/2026 23:54		WATER WALL TUBE LEAKAGE
Uttar Pradesh	HARDUAGANJ TPS	10	0.00	0.00	0.00	0.00	04/05/2026 09:53	07/05/2026 11:25	RSD/LOW SCHEDULE
Uttar Pradesh	JAWAHARPUR STPP	1	0.00	0.00	660.00	0.00	01/05/2026 00:41		RSD/LOW SCHEDULE
Uttar Pradesh	JAWAHARPUR STPP	2	0.00	0.00	660.00	0.00	01/05/2026 02:02		RSD/LOW SCHEDULE
Uttar Pradesh	OBRA TPS	14	0.00	0.00	660.00	0.00	07/05/2026 00:08		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
Chhatisgarh	KORBA-WEST TPS	5	0.00	0.00	500.00	0.00	06/05/2026 22:00		WATER WALL TUBE LEAKAGE
Chhatisgarh	Vedanta Ltd Chhattisgarh TPP	1	0.00	600.00	0.00	0.00	14/04/2026 14:33		P.A. FANS PROBLEM
Madhya Pradesh	KHARGONE STPP	2	0.00	0.00	660.00	0.00	06/05/2026 13:20		VARIOUS STEAM LEAKAGES
Madhya Pradesh	SANJAY GANDHI TPS	5	0.00	0.00	0.00	0.00	07/05/2026 10:50	07/05/2026 15:30	FURNACE FIRE OUT /FLAME FAILURE
Madhya Pradesh	SHREE SINGAJI TPP	1	0.00	0.00	600.00	0.00	23/04/2026 23:45		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
Madhya Pradesh	SASAN UMTTP	2	0.00	0.00	660.00	0.00	07/05/2026 21:45		TURBINE VIBRATIONS HIGH
Andhra Pradesh	DAMODARAM SANJEEVAIAH TPS	1	0.00	0.00	0.00	0.00	06/05/2026 01:59	07/05/2026 04:35	WATER WALL TUBE LEAKAGE
Andhra Pradesh	DAMODARAM SANJEEVAIAH TPS	3	0.00	800.00	0.00	0.00	21/04/2026 00:05	07/05/2026 17:03	TURBINE MISC. PROBLEMS
Karnataka	YERMARUS TPP	2	0.00	0.00	800.00	0.00	06/05/2026 05:11		WATER WALL TUBE LEAKAGE
Karnataka	ADANI POWER LIMITED UDUPI TPP	2	0.00	0.00	600.00	0.00	06/05/2026 00:01		ELECTRICAL MISCELLANEOUS PROBLEMS

DAILY MAINTENANCE REPORT (THERMAL AND NUCLEAR UNITS) FOR 500 AND ABOVE 07-05-2026

State/System	Power Station	Unit No.	Planned Maintenance (MW)	Forced Maintenance (Major) (MW)	Forced Maintenance (Minor) (MW)	Others Maintenance (MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6	7	8	9	10
Tamil Nadu	VALLUR TPP	2	0.00	0.00	0.00	0.00	07/05/2026 07:15	07/05/2026 10:20	GRID DISTURBANCE
Tamil Nadu	METTUR TPS-II	1	0.00	0.00	600.00	0.00	06/05/2026 19:22	07/05/2026 02:40	GEN. TRANSFORMER PROTECTION RELAY OPERATION PROBLEM
Tamil Nadu	NORTH CHENNAI TPS STAGE 2	5	0.00	600.00	0.00	0.00	16/04/2026 21:35		GENERATOR PROTECTION RELAY OPERATION PROBLEM
Tamil Nadu	ITPCL TPP	1	0.00	0.00	600.00	0.00	05/05/2026 22:27		AIR PREHEATERS PROBLEM
Telangana	RAMAGUNDEM STPS	6	0.00	0.00	500.00	0.00	06/05/2026 20:43		REHEATER TUBE LEAKAGE
Telangana	YADADRI TPS	1	0.00	0.00	800.00	0.00	06/05/2026 21:53		WATER WALL TUBE LEAKAGE
Telangana	YADADRI TPS	2	0.00	0.00	800.00	0.00	01/05/2026 08:49		BOILER AUX. MISC. PROMLEMS
Telangana	YADADRI TPS	4	0.00	0.00	800.00	0.00	30/04/2026 16:48		ECONOMISER TUBE LEAKAGE
Bihar	BARH STPS	2	0.00	0.00	660.00	0.00	07/05/2026 03:24		WATER WALL TUBE LEAKAGE
Bihar	BARH STPS	4	0.00	0.00	660.00	0.00	07/05/2026 00:16		WATER WALL TUBE LEAKAGE
Bihar	NABINAGAR STPP	2	0.00	0.00	660.00	0.00	07/05/2026 19:30		WATER WALL TUBE LEAKAGE
Jharkhand	NORTH KARANPURA TPP	2	660.00	0.00	0.00	0.00	24/03/2026 18:47		OVERHAULING WORKS
West Bengal	RAGHUNATHPUR TPP	2	0.00	600.00	0.00	0.00	14/04/2026 17:51		TURBINE VIBRATIONS HIGH

Total	660.00	2,600.00	15,120.00	0.00			
--------------	---------------	-----------------	------------------	-------------	--	--	--

" ** " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.

2.Data published in this report is for operational purpose only and not for commercial purpose.

3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-