

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS: 07-May-2026

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date of Maintanance DD/MM/YYYY HH24:MM	Sync Date DD/MM/YYYY HH24:MM	remarks
1	2	3	4	5	6
SURATGARH TPS	4	250.0	5/3/26, 9:16 AM	5/7/26, 2:25 PM	RSD/LOW SCHEDULE
SURATGARH TPS	6	250.0	5/4/26, 9:45 AM	5/7/26, 2:43 PM	RSD/LOW SCHEDULE
JALIPA KAPURDI TPP	6	135.0	4/30/26, 11:38 AM	5/7/26, 8:35 AM	BOILER MISC. PROBLEM
SHREE CEMENT LTD TPS	3	19.0	5/7/26, 5:15 AM	5/7/26, 6:30 PM	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.0	5/7/26, 5:15 AM	5/7/26, 6:28 PM	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.0	5/7/26, 5:02 AM	5/7/26, 6:34 PM	RSD/LOW SCHEDULE
HARDUAGANJ TPS	10	660.0	5/4/26, 9:53 AM	5/7/26, 11:25 AM	RSD/LOW SCHEDULE
BINJKOTE TPP	1	300.0	5/5/26, 4:06 PM	5/7/26, 10:18 PM	AIR PREHEATERS PROBLEM
SANJAY GANDHI TPS	5	500.0	5/7/26, 10:50 AM	5/7/26, 3:30 PM	FURNACE FIRE OUT /FLAME FAILURE
BINA TPS	2	250.0	5/1/26, 12:40 AM	5/7/26, 4:02 PM	BOILER INSPECTION/ RE-CERTIFICATION
SASAN UMTTP	2	660.0	5/7/26, 6:25 PM	5/7/26, 7:49 PM	TURBINE VIBRATIONS HIGH
SASAN UMTTP	2	660.0	4/1/26, 11:21 PM	5/7/26, 5:30 PM	BOILER OVERHAUL/ ANNUAL MAINTENANCE
NASIK TPS	4	210.0	5/4/26, 3:01 PM	5/7/26, 10:58 AM	Miscellaneous
METTUR TPS-II	1	600.0	5/6/26, 7:22 PM	5/7/26, 2:40 AM	GEN. TRANSFORMER PROTECTION RELAY OPERATION PROBLEM
VALLUR TPP	2	500.0	5/7/26, 7:15 AM	5/7/26, 10:20 AM	GRID DISTURBANCE
NEYVELI TPS(Z)	1	250.0	4/30/26, 6:08 PM	5/7/26, 9:31 AM	ASH HANDLING SYSTEM NOT READY
OPG Power Generation Private Limited	1	77.0	4/29/26, 10:44 AM	5/7/26, 6:45 AM	MILLING SYSTEM /RC FEEDER PROBLEM
RAMAGUNDEM STPS	3	200.0	5/4/26, 7:28 AM	5/7/26, 3:13 PM	MAINT./REPLACEMENT OF BRUSHES/SLIP RINGS
BHADRADRI TPP	4	270.0	5/7/26, 5:21 PM	5/7/26, 7:06 PM	FURNACE FIRE OUT /FLAME FAILURE
DAMODARAM SANJEEVAIAH TPS	1	800.0	5/6/26, 1:59 AM	5/7/26, 4:35 AM	WATER WALL TUBE LEAKAGE
DAMODARAM SANJEEVAIAH TPS	3	800.0	4/21/26, 12:05 AM	5/7/26, 5:03 PM	TURBINE MISC. PROBLEMS
BARAUNI TPS	9	250.0	5/4/26, 12:53 PM	5/7/26, 11:24 PM	WATER WALL TUBE LEAKAGE
AGARTALA GT	2	21.0	5/7/26, 12:00 AM	5/7/26, 11:59 PM	Fuel Shortage
KATHALGURI CCPP	3	33.5	5/7/26, 12:00 AM	5/7/26, 11:59 PM	Low system demand/ costly fuel

Total	7060.50			
--------------	---------	--	--	--

" ** " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

- Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-