

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 07-May-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SHREE CEMENT LTD TPS	3	19.00	5/7/26, 5:15 AM	2026-05-07 18:30:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	4	19.00	5/7/26, 5:15 AM	2026-05-07 18:28:00	RSD/LOW SCHEDULE
SHREE CEMENT LTD TPS	5	6.00	5/7/26, 5:02 AM	2026-05-07 18:34:00	RSD/LOW SCHEDULE
OBRA TPS	9	200.00	5/7/26, 10:45 PM		WATER WALL TUBE LEAKAGE
OBRA TPS	14	660.00	5/7/26, 12:08 AM		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
SANJAY GANDHI TPS	5	500.00	5/7/26, 10:50 AM	2026-05-07 15:30:00	FURNACE FIRE OUT /FLAME FAILURE
SASAN UMTTP	2	660.00	5/7/26, 9:45 PM		TURBINE VIBRATIONS HIGH
SASAN UMTTP	2		5/7/26, 6:25 PM	2026-05-07 19:49:00	TURBINE VIBRATIONS HIGH
NIWARI TPP	2	45.00	5/7/26, 9:54 PM		WATER WALL TUBE LEAKAGE
VINDHYACHAL STPS	1	210.00	5/7/26, 1:04 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
UKAI TPS	4	200.00	5/7/26, 11:01 PM		WATER WALL TUBE LEAKAGE
NEYVELI TPS-II	1	210.00	5/7/26, 3:00 PM		RESERVE SHUT DOWN / STANDBY UNIT
VALLUR TPP	2	500.00	5/7/26, 7:15 AM	2026-05-07 10:20:00	GRID DISTURBANCE
BHADRADRI TPP	4	270.00	5/7/26, 5:21 PM	2026-05-07 19:06:00	FURNACE FIRE OUT /FLAME FAILURE
RAYALASEEMA TPS	4	210.00	5/7/26, 9:42 PM		AIR PREHEATERS PROBLEM
BARH STPS	2	660.00	5/7/26, 3:24 AM		WATER WALL TUBE LEAKAGE
BARH STPS	4	660.00	5/7/26, 12:16 AM		WATER WALL TUBE LEAKAGE
NABINAGAR STPP	2	660.00	5/7/26, 7:30 PM		WATER WALL TUBE LEAKAGE
MEJIA TPS	4	210.00	5/7/26, 12:20 PM	2026-05-10	WATER WALL TUBE LEAKAGE
JSW Energy Utkal Limited	2	350.00	5/7/26, 7:06 AM	2026-05-11	AIR PREHEATERS PROBLEM
AGARTALA GT	2	21.00	5/7/26, 12:00 AM	2026-05-07 23:59:59	Fuel Shortage
KATHALGURI CCPP	3	33.50	5/7/26, 12:00 AM	2026-05-07 23:59:59	Low system demand/ costly fuel

Total	6303.50			
--------------	---------	--	--	--

" ** " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH

- Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-