

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 07-12-2018**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
RAJPURA TPP	1	700.00	10/11/2018 16.15.00	07/12/2018 20.30.00	BOILER MISC. PROBLEM
HARDUAGANJ TPS	8	250.00	06/12/2018 21.16.00	07/12/2018 00.34.00	CONDENSATE PUMP problem
OBRA TPS	11	200.00	14/10/2018 04.45.00	07/12/2018 07.15.00	FIRE IN CABLE GALLERY.
PRAYAGRAJ TPP	3	660.00	07/12/2018 15.50.00	07/12/2018 18.31.00	TURBINE MISC. PROBLEM
SIKKA REP. TPS	4	250.00	04/12/2018 12.07.00	07/12/2018 03.27.00	RESERVE SHUT DOWN / STANDBY UNIT
VINDHYACHAL STPS	2	210.00	06/12/2018 10.05.00	07/12/2018 23.45.00	WATER WALL TUBE LEAKAGE
SANJAY GANDHI TPS	5	500.00	07/12/2018 00.35.00	07/12/2018 03.53.00	TURBINE MISC.
SATPURA TPS	7	210.00	03/12/2018 12.37.00	07/12/2018 19.20.48	WATER WALL TUBE LEAKAGE
JEGURUPADU CCPP PH I	3	52.80	06/12/2018 19.20.00	07/12/2018 19.41.00	GT HIGH VIBRATIONS
GODAVARI CCPP	1	47.00	05/12/2018 05.09.00	07/12/2018 22.06.30	GT COMBUSTION CHAMBER / COMBUSTOR
NORTH CHENNAI TPS	5	600.00	06/12/2018 21.11.00	07/12/2018 02.47.00	P.A. FANS PROBLEM
RAMAGUNDEM STPS	4	500.00	05/12/2018 08.04.00	07/12/2018 03.42.00	WATER WALL TUBE LEAKAGE
BUDGE BUDGE TPS	1	250.00	05/12/2018 23.37.00	07/12/2018 00.00.00	ECONOMISER TUBE LEAKAGE
BONGAIGAON TPP	1	250.00	03/12/2018 00.52.00	07/12/2018 14.19.00	COAL SHORTAGE
LAKWA REPLACEMENT POWER PROJECT	1	9.96	07/12/2018 09.52.42	07/12/2018 17.30.30	MISC. SHORT DURATION MAINTENANCE WORKS
LAKWA REPLACEMENT POWER PROJECT	3	9.96	07/12/2018 16.58.54	07/12/2018 17.05.35	Fuel System Abnormal/ Maintenance
LAKWA REPLACEMENT POWER PROJECT	5	9.96	07/12/2018 16.58.57	07/12/2018 17.06.04	Fuel System Abnormal/ Maintenance
LAKWA REPLACEMENT POWER PROJECT	6	9.96	07/12/2018 16.58.55	07/12/2018 17.07.10	Fuel System Abnormal/ Maintenance
Total		4719.66			