

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 07-12-2018

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
INDIRA GANDHI STPP	1	500.0	07/12/2018 11.04.00		WATER WALL TUBE LEAKAGE
KOTA TPS	5	210.0	07/12/2018 12.22.00		AIR PREHEATERS PROBLEM
SURATGARH TPS	4	250.0	07/12/2018 12.45.00		RSD/LOW SCHEDULE
OBRA TPS	11	200.0	07/12/2018 08.00.00		AIR PREHEATERS PROBLEM
PRAYAGRAJ TPP	3	660.0	07/12/2018 15.50.00	07/12/2018 18.31.00	TURBINE MISC. PROBLEM
UKAI TPS	4	200.0	07/12/2018 04.12.00		WATER WALL TUBE LEAKAGE
SANJAY GANDHI TPS	5	500.0	07/12/2018 00.35.00	07/12/2018 03.53.00	TURBINE MISC.
KHAPARKHEDA TPS	4	210.0	07/12/2018 17.02.00		TURBINE MISC.
JSW RATNAGIRI TPP	4	300.0	07/12/2018 01.30.00	13/12/2018	RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	2	210.0	07/12/2018 10.31.00	09/12/2018	ECONOMISER TUBE LEAKAGE
SOUTHERN REPL. TPS	1	67.5	07/12/2018 01.57.00	08/12/2018	RESERVE SHUT DOWN / STANDBY UNIT
SOUTHERN REPL. TPS	2	67.5	07/12/2018 01.39.00	08/12/2018	RESERVE SHUT DOWN / STANDBY UNIT
LAKWA REPLACEMENT POWER PROJECT	1	9.965	07/12/2018 09.52.42	07/12/2018 17.30.30	MISC. SHORT DURATION MAINTENANCE WORKS
LAKWA REPLACEMENT POWER PROJECT	3	9.965	07/12/2018 16.58.54	07/12/2018 17.05.35	Fuel System Abnormal/ Maintenance
LAKWA REPLACEMENT POWER PROJECT	5	9.965	07/12/2018 16.58.57	07/12/2018 17.06.04	Fuel System Abnormal/ Maintenance
LAKWA REPLACEMENT POWER PROJECT	6	9.965	07/12/2018 16.58.55	07/12/2018 17.07.10	Fuel System Abnormal/ Maintenance
Total		3414.8600000			