

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 08-09-2019**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
CHHABRA TPP	2	250.00	05/09/2019 15:06	08/09/2019 13:45	WATER WALL TUBE LEAKAGE
KOTA TPS	4	210.00	08/09/2019 20:09	08/09/2019 23:47	C&I PROBLEM
BINJKOTE TPP	2	300.00	06/09/2019 21:59	08/09/2019 18:29	ECONOMISER TUBE LEAKAGE
TAMNAR TPP	4	600.00	30/08/2019 20:43	08/09/2019 15:03	CONDENSER TUBE LEAKAGE/ CLEANING
SHREE SINGAJI TPP	2	600.00	01/08/2019 00:00	08/09/2019 23:01	BOILER OVERHAUL/ ANNUAL MAINTENANCE
NIGRI TPP	1	660.00	01/07/2019 01:30	08/09/2019 17:46	BOILER OVERHAUL/ ANNUAL MAINTENANCE
KAIGA	1	220.00	16/08/2019 16:05	08/09/2019 03:41	GENERATOR EARTH FAULT
NORTH CHENNAI TPS	5	600.00	08/08/2019 22:14	08/09/2019 13:33	BOILER OVERHAUL/ ANNUAL MAINTENANCE
SOUTHERN REPL. TPS	2	67.50	07/09/2019 23:12	08/09/2019 14:56	RESERVE SHUT DOWN / STANDBY UNIT
LAKWA REPLACEMENT POWER PROJECT	5	9.96	08/09/2019 15:21	08/09/2019 15:29	MINOR MAINTENANCE WORKS
Total		3,517.47			