

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 08-09-2019**

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
KOTA TPS	4	210.00	08/09/2019 20:09		C&I PROBLEM
SURATGARH TPS	1	250.00	08/09/2019 10:41		BOILER MISC. PROBLEM
BINJKOTE TPP	1	300.00	08/09/2019 12:47	10/09/2019	ECONOMISER TUBE LEAKAGE
HAZIRA CCPP EXT	1	351.00	08/09/2019 00:15		Low system demand/ costly fuel
SANJAY GANDHI TPS	2	210.00	08/09/2019 23:51		RSD/LOW SCHEDULE
SANJAY GANDHI TPS	4	210.00	08/09/2019 14:11		COAL SHORTAGE
NEYVELI TPS- I	4	50.00	08/09/2019 18:00		ECONOMISER TUBE LEAKAGE
MUTHIARA TPP	1	600.00	08/09/2019 23:56		H.T./L.T. SUPPLY PROBLEM
SAGARDIGHI TPS	4	500.00	08/09/2019 00:00		ASH HANDLING SYSTEM PROBLEM
LAKWA REPLACEMENT POWER PROJECT	5	9.96	08/09/2019 15:21		MINOR MAINTENANCE WORKS
Total		2690.97			