

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2025-26 as on: 08-Dec-2025

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
PRAGATI CCPP	1		5/19/25, 4:49 PM	20-05-2025	MINOR MAINTENANCE WORKS
PRAGATI CCPP	1		5/25/25, 7:15 PM	25-05-2025	MISCELLANOUS
PRAGATI CCPP	1		7/28/25, 4:31 PM	28-07-2025	MISCELLANOUS
PRAGATI CCPP	1		7/25/25, 10:15 AM	26-07-2025	GT- LUB OIL SYSTEM PROB.
PRAGATI CCPP	1		7/9/25, 5:36 PM	09-07-2025	GRID DISTURBENCE
PRAGATI CCPP	1		7/17/25, 10:45 PM	25-07-2025	Low system demand/ costly fuel
PRAGATI CCPP	1		6/29/25, 4:39 AM	29-06-2025	GRID DISTURBENCE
PRAGATI CCPP	1	104.60	5/25/25, 2:19 PM	25-05-2025	LOW SYSTEM DEMAND
PRAGATI CCPP	2		5/2/25, 5:22 AM	02-05-2025	GRID DISTURBENCE
PRAGATI CCPP	2		5/22/25, 6:08 PM	22-05-2025	Cooling Water System Abnormal/ Maintenance
PRAGATI CCPP	2		6/15/25, 3:53 AM	15-06-2025	GRID DISTURBENCE
PRAGATI CCPP	2		5/2/25, 11:00 AM	02-05-2025	Electrical Scheduled Maitenance
PRAGATI CCPP	2	104.60	5/21/25, 8:21 PM	21-05-2025	GRID DISTURBENCE
PRAGATI CCPP	2		5/24/25, 2:00 AM	24-05-2025	Cooling Water System Abnormal/ Maintenance
PRAGATI CCPP	3	121.20	5/2/25, 6:22 AM	02-05-2025	GRID DISTURBENCE
PRAGATI CCPP	3		5/2/25, 11:00 AM		Electrical Scheduled Maitenance
PRAGATI CCPP	3		1/13/25, 11:00 AM	22-01-2025	CONDENSER TUBE LEAKAGE/ CLEANING
PANIPAT TPS	6	210.00	10/20/25, 12:33 AM		RESERVE SHUT DOWN / STANDBY UNIT
RAJIV GANDHI TPS	2	600.00	10/6/25, 10:33 PM		Turbine Misc
INDIRA GANDHI STPP	1	500.00	8/31/25, 1:34 PM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
INDIRA GANDHI STPP	1		5/2/25, 5:45 PM		GOVERNING SYSTEM PROBLEM
INDIRA GANDHI STPP	1		8/9/25, 12:01 AM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
INDIRA GANDHI STPP	1		5/2/25, 5:14 AM		GENERATOR PROTECTION
INDIRA GANDHI STPP	2	500.00	10/31/25, 11:00 PM		ANNUAL MAINTENANCE
MAHATMA GANDHI TPS	1	660.00	10/28/25, 12:01 PM		ANNUAL MAINTENANCE
MAHATMA GANDHI TPS	2	660.00	10/16/25, 11:52 PM		WATER WALL TUBE LEAKAGE
FARIDABAD CCPP	1	137.76	9/9/25, 11:33 PM	09-09-2025	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	9/9/25, 11:32 PM	09-09-2025	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	3	156.07	7/23/25, 10:38 PM	20-08-2025	CONSERVATION OF MAIN FUEL/RSD

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2025-26 as on: 08-Dec-2025

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
GH TPS (LEH.MOH.)	1	210.00	3/21/25, 3:58 PM	01-04-2025	STATOR EARTH FAULT
GH TPS (LEH.MOH.)	2		8/25/25, 1:31 PM	29-08-2025	INSPECTION /MTCE
GH TPS (LEH.MOH.)	2		8/29/25, 8:37 AM	31-08-2025	GT-TURBINE BEARING PROBLEM
GH TPS (LEH.MOH.)	2	210.00	8/31/25, 11:00 AM	08-09-2025	LOW SYSTEM DEMAND
GH TPS (LEH.MOH.)	3	250.00	11/19/25, 11:48 PM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
GH TPS (LEH.MOH.)	4	250.00	5/7/25, 10:55 PM	10-05-2025	MISC. SHORT DURATION MAINTENANCE
ROPAR TPS	3		8/16/25, 10:36 PM		FUEL SUPPLY & OTHER MISC. PROBLEMS
ROPAR TPS	3	210.00	8/25/25, 9:37 AM		FURNACE DRAFT ABNORMAL
ROPAR TPS	4		6/18/25, 12:09 AM		WATER WALL TUBE LEAKAGE
ROPAR TPS	4	210.00	8/10/25, 9:22 AM		FURNACE DRAFT ABNORMAL
ROPAR TPS	4		10/17/25, 10:35 AM		FURNACE DRAFT ABNORMAL
ROPAR TPS	5		8/16/25, 9:25 AM		FUEL SUPPLY & OTHER MISC. PROBLEMS
ROPAR TPS	5	210.00	10/17/25, 3:22 PM		REHEATER TUBE LEAKAGE
ROPAR TPS	6		10/13/25, 4:37 PM		BOILER MISC. PROBLEM
ROPAR TPS	6		8/28/25, 8:30 PM		RSD/LOW SCHEDULE
ROPAR TPS	6		8/27/25, 2:48 PM		AIR PREHEATERS PROBLEM
ROPAR TPS	6	210.00	1/15/25, 6:52 AM		GENEARTOR MISC.
ROPAR TPS	6		8/10/25, 7:25 AM		REHEATER TUBE LEAKAGE
GOINDWAL SAHIB TPP	1	270.00	11/18/25, 8:00 PM		MISCELLANEOUS PLANNED MAINTENANCE
TALWANDI SABO TPP	2	660.00	11/19/25, 10:30 PM	25-12-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
KOTA TPS	2	110.00	10/28/25, 5:55 AM		BOILER AUX. MISC. PROMLEMS
RAJASTHAN A.P.S.	7	700.00	10/4/25, 4:34 PM	01-12-2025	TURBINE VIBRATION HIGH
SURATGARH TPS	6	250.00	7/25/25, 12:09 PM		TURBINE VIBRATION HIGH
SURATGARH TPS	6		6/2/25, 7:48 AM		RSD/LOW SCHEDULE
JALIPA KAPURDI TPP	7	135.00	11/21/25, 7:11 PM		BOILER MISC. PROBLEM
CHHABRA-I PH-2 TPP	4	250.00	10/24/25, 2:00 AM		ANNUAL MAINTENANCE
RAMGARH CCPP	1	3.00	5/9/25, 4:07 PM		Fuel Shortage
ANTA CCPP	1		5/3/25, 4:09 AM	03-05-2025	NO Power purchase agreement
ANTA CCPP	1	88.71	8/26/25, 12:00 AM	26-08-2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2		3/12/25, 11:14 PM	16-03-2025	NO/REDUCED IRRIGATION DEMAND
ANTA CCPP	2	88.71	8/26/25, 12:00 AM	26-08-2025	CONSERVATION OF MAIN FUEL/RSD

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2025-26 as on: 08-Dec-2025

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
ANTA CCPP	2		2/18/25, 11:36 AM	19-02-2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2		2/19/25, 7:30 AM	20-02-2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	8/26/25, 12:00 AM	26-08-2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	4	153.20	9/17/25, 12:23 AM	18-09-2025	CONSERVATION OF MAIN FUEL/RSD
SHREE CEMENT LTD TPS	1	150.00	11/1/25, 12:00 AM	20-12-2025	ANNUAL MAINTENANCE
SHREE CEMENT LTD TPS	2	150.00	11/1/25, 12:00 AM	22-11-2025	ANNUAL MAINTENANCE
HARDUAGANJ TPS	7	105.00	10/3/25, 11:17 PM		RESERVE SHUT DOWN / STANDBY UNIT
HARDUAGANJ TPS	8		1/10/25, 7:50 PM		WATER WALL TUBE LEAKAGE
HARDUAGANJ TPS	8	250.00	10/3/25, 11:15 PM		RESERVE SHUT DOWN / STANDBY UNIT
HARDUAGANJ TPS	9	250.00	10/3/25, 11:13 PM		RESERVE SHUT DOWN / STANDBY UNIT
ANPARA TPS	7	500.00	10/31/25, 1:00 AM		OVERHAULING WORKS
JAWAHARPUR STPP	1	660.00	10/7/25, 1:19 AM		RESERVE SHUT DOWN / STANDBY UNIT
JAWAHARPUR STPP	2	660.00	10/7/25, 12:58 AM		RESERVE SHUT DOWN / STANDBY UNIT
PANKI TPS EXT	1	660.00	7/9/25, 3:30 PM		ELECTRICAL MISCELLANEOUS PROBLEMS
PRAYAGRAJ TPP	3	660.00	11/16/25, 12:31 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
LALITPUR TPS	1	660.00	11/15/25, 1:16 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
ANPARA C TPS	1	600.00	11/9/25, 12:24 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
RIHAND STPS	4	500.00	10/29/25, 11:54 PM	08-12-2025	OVERHAULING WORKS
UNCHAHR TPS	3	210.00	11/15/25, 1:01 AM	08-12-2025	OVERHAULING WORKS
DADRI (NCTPP)	2	210.00	6/18/25, 11:47 AM		RSD/LOW SCHEDULE
DADRI (NCTPP)	5	490.00	5/23/25, 11:35 AM	25-05-2025	BOILER AUX. MISC. PROMLEMS
TANDA TPS	1	110.00	6/30/25, 11:05 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	2	110.00	6/30/25, 11:17 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	3	110.00	8/31/25, 11:58 PM	04-09-2025	CONSERVATION OF MAIN FUEL/RSD
TANDA TPS	4	110.00	3/27/25, 2:55 AM	28-03-2025	BOILER AUX. MISC. PROMLEMS
TANDA TPS	4		8/31/25, 11:58 PM		RESERVE SHUT DOWN / STANDBY UNIT
AURAIYA CCPP	2	111.19	3/12/25, 11:13 PM	25-03-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	2		3/25/25, 12:00 AM	27-03-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	3		1/6/25, 6:00 AM	07-01-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	3	111.19	1/3/25, 9:28 AM	06-01-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	4	111.19	9/8/25, 11:40 PM	08-09-2025	CONSERVATION OF MAIN FUEL/RSD

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2025-26 as on: 08-Dec-2025

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
AURAIYA CCPP	4		1/14/25, 9:50 AM	07-02-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	5		9/20/25, 10:33 PM	08-12-2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	5		3/25/25, 12:00 PM	26-03-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	5		12/18/24, 9:05 AM	24-03-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	5	109.30	3/24/25, 12:00 PM	25-03-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		12/18/24, 9:02 AM	24-01-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		9/20/25, 10:44 PM	08-12-2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	6		1/24/25, 12:00 PM	25-01-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		1/25/25, 12:00 PM	25-01-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		1/31/25, 12:00 PM	01-02-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		2/3/25, 12:00 PM	04-02-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6		2/2/25, 12:00 PM	03-02-2025	NO/REDUCED IRRIGATION DEMAND
AURAIYA CCPP	6	109.30	2/4/25, 12:00 PM	07-02-2025	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	1	130.19	11/19/25, 6:14 PM	19-11-2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2		7/9/25, 12:43 AM		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2		10/13/25, 7:49 PM	13-10-2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	2/25/25, 12:16 PM	26-02-2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2		4/13/25, 8:19 AM	14-04-2025	GENERATOR TRANSFORMER
DADRI CCPP	3	130.19	12/16/24, 8:00 AM	21-12-2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	3		2/10/25, 9:59 AM	11-02-2025	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	3		8/25/25, 8:51 PM	27-08-2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	12/25/24, 6:12 PM	02-01-2025	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	4		3/5/25, 7:56 PM	07-03-2025	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5	154.51	12/18/24, 8:23 AM	26-02-2025	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	5		7/23/25, 10:29 PM	21-08-2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	6	154.51	7/5/25, 12:39 AM	21-07-2025	CONSERVATION OF MAIN FUEL/RSD
ROSA TPP Ph-I	3	300.00	11/16/25, 1:23 AM	10-12-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
KUNDARKI TPS	1	45.00	10/11/25, 11:41 PM		RSD/LOW SCHEDULE
UTRAULA TPS	1	45.00	10/11/25, 11:43 PM		RSD/LOW SCHEDULE
UKAI TPS	3		6/26/25, 1:57 PM		TURBINE MISC.
UKAI TPS	3		11/15/25, 3:00 AM		RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date & Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
UKAI TPS	3	200.00	2/22/25, 7:45 AM		WATER WALL TUBE LEAKAGE
UKAI TPS	3		11/13/25, 10:10 PM		WATER WALL TUBE LEAKAGE
UKAI TPS	4	200.00	12/22/24, 5:45 PM		WATER WALL TUBE LEAKAGE
UKAI TPS	5	210.00	2/3/25, 6:38 PM		WATER WALL TUBE LEAKAGE
GANDHI NAGAR TPS	3		11/14/25, 7:10 PM		RSD/LOW SCHEDULE
GANDHI NAGAR TPS	3		1/8/25, 12:00 AM		SCHEDULED ANNUAL MAINTENANCE
GANDHI NAGAR TPS	3	210.00	7/23/25, 11:28 AM		RAW WATER SUPPLY MISC.
GANDHI NAGAR TPS	4	210.00	11/14/25, 6:54 PM		RSD/LOW SCHEDULE
GANDHI NAGAR TPS	4		7/23/25, 11:53 AM		RAW WATER SUPPLY MISC.
GANDHI NAGAR TPS	5	210.00	3/7/25, 5:17 PM		WATER WALL TUBE LEAKAGE
GANDHI NAGAR TPS	5		11/15/25, 12:02 AM		SCHEDULED ANNUAL MAINTENANCE
UTRAN CCPP	5		5/19/25, 8:00 AM		MISC. SHORT DURATION PLANNED MAINTENANCE
UTRAN CCPP	5	240.00	5/17/25, 10:43 PM		RESERVE SHUT DOWN / STANDBY UNIT
UTRAN CCPP	5		2/10/25, 8:28 PM		RESERVE SHUT DOWN
UTRAN CCPP	6		5/19/25, 8:00 AM		MISC. SHORT DURATION PLANNED MAINTENANCE
UTRAN CCPP	6	134.00	5/17/25, 10:40 PM		RESERVE SHUT DOWN / STANDBY UNIT
UTRAN CCPP	6		2/10/25, 8:25 PM		RESERVE SHUT DOWN / STANDBY UNIT
HAZIRA CCPP EXT	1	351.00	6/15/25, 1:22 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/8/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/2/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/17/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/18/25, 11:59 PM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	3		4/18/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	3		3/20/25, 3:06 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/1/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/17/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	3	72.00	4/4/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	3		4/3/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		8/26/25, 10:18 PM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	4		4/4/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		2/28/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
DHUVARAN CCPP	4		3/20/25, 1:45 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		2/7/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/3/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/25/25, 7:26 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/2/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/1/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4	40.00	4/18/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/8/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	4		4/17/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/4/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/2/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		8/12/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	5		3/20/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/18/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/17/25, 11:59 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		5/9/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		12/16/24, 7:00 PM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/8/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		2/4/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/18/25, 11:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/3/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		4/18/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
DHUVARAN CCPP	5		9/11/25, 7:20 PM		RESERVE SHUT DOWN
DHUVARAN CCPP	5	376.10	4/17/25, 12:00 AM		RESERVE SHUT DOWN/ STANDBY.
DHUVARAN CCPP	5		4/1/25, 12:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
WANAKBORI TPS	3	210.00	5/29/25, 1:33 PM		TURBINE MISC. PROBLEM
WANAKBORI TPS	3		12/14/24, 8:13 PM		RSD/LOW SCHEDULE
WANAKBORI TPS	4	210.00	4/8/25, 10:33 PM		WATER WALL TUBE LEAKAGE
WANAKBORI TPS	5	210.00	5/25/25, 2:09 PM		TURBINE BEARING PROBLEM
SIKKA REP. TPS	3	250.00	11/14/25, 1:55 AM		RESERVE SHUT DOWN / STANDBY UNIT
SIKKA REP. TPS	4	250.00	11/14/25, 2:52 AM		RESERVE SHUT DOWN / STANDBY UNIT

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2025-26 as on: 08-Dec-2025

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KUTCH LIG. TPS	3	75.00	7/29/25, 10:06 AM		WATER WALL TUBE LEAKAGE
SUGEN CCGP	2	382.50	7/27/25, 12:00 AM		RSD/LOW SCHEDULE
SUGEN CCGP	3	382.50	10/17/25, 10:46 AM	27-10-2025	RSD/LOW SCHEDULE
UNOSUGEN CCGP	1	382.50	10/1/25, 12:00 AM	10-10-2025	RSD/LOW SCHEDULE
DGEN MEGA CCGP	1	400.00	1/3/25, 12:06 AM	01-04-2025	GT-NO SCHEDULE FROM BENIFICIARIES
DGEN MEGA CCGP	2	400.00	1/3/25, 12:09 AM	01-04-2025	GT-NO SCHEDULE FROM BENIFICIARIES
DGEN MEGA CCGP	3		1/2/25, 12:00 AM		GT-NO SCHEDULE FROM BENIFICIARIES
DGEN MEGA CCGP	3	400.00	1/3/25, 12:10 AM	01-04-2025	GT-NO SCHEDULE FROM BENIFICIARIES
SURAT LIG. TPS	2	125.00	7/28/25, 4:27 AM		WATER WALL TUBE LEAKAGE
MUNDRA UMTTP	1	800.00	7/3/25, 11:54 AM		AIR PREHEATERS PROBLEM
MUNDRA UMTTP	2	800.00	7/2/25, 10:59 PM		F.D. FANS PROBLEM
MUNDRA UMTTP	3	800.00	7/2/25, 12:22 AM		TURBINE CONTROL VALVE PROBLEM
MUNDRA UMTTP	4	800.00	7/1/25, 8:55 AM		COOLING WATER SYSTEM PROBLEM/PIPES REPLACE
MUNDRA UMTTP	5	800.00	7/2/25, 8:55 AM		TURBINE MISC. PROBLEMS
KAWAS CCGP	1	106.00	10/11/25, 7:20 PM	12-10-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCGP	2	106.00	9/21/25, 12:30 AM	21-09-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCGP	3	106.00	8/25/25, 11:57 PM	27-08-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCGP	3		6/4/25, 11:35 PM	05-06-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCGP	4	106.00	3/27/25, 11:00 PM	27-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCGP	4		9/23/25, 7:44 PM	24-09-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCGP	4		3/25/25, 5:42 PM	27-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCGP	5	116.10	3/23/25, 12:00 PM	24-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCGP	5		2/26/25, 12:00 PM	28-02-2025	GT/WHRB/ST PLANNED OVERHAUL
KAWAS CCGP	5		12/18/24, 10:00 AM	20-12-2024	NO/REDUCED IRRIGATION DEMAND
KAWAS CCGP	5		3/25/25, 12:00 PM	26-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCGP	5		3/24/25, 12:00 PM	25-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCGP	5		3/22/25, 12:00 PM	23-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCGP	5		3/13/25, 12:00 PM	14-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCGP	5		3/12/25, 12:00 AM	13-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCGP	5		3/7/25, 12:00 PM	12-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCGP	5		3/2/25, 12:00 AM	03-03-2025	NO/REDUCED IRRIGATION DEMAND

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
KAWAS CCPP	5		9/21/25, 12:32 AM	21-09-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	5		12/20/24, 5:30 AM	26-02-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		3/21/25, 12:00 PM	22-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	5		3/17/25, 8:23 PM	21-03-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	6		7/25/25, 5:15 PM	07-08-2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	6		4/21/25, 11:12 PM	22-04-2025	NO/REDUCED IRRIGATION DEMAND
KAWAS CCPP	6	116.10	5/17/25, 7:37 PM	05-06-2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1		3/22/25, 11:55 PM	22-03-2025	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	1		8/26/25, 12:00 AM	26-08-2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1	144.30	3/21/25, 8:23 PM	22-03-2025	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	2	144.30	1/20/25, 9:29 AM	05-02-2025	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	4		9/13/25, 11:11 PM	14-09-2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	4		4/21/25, 7:40 PM	27-04-2025	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	4		4/27/25, 12:55 AM	30-05-2025	NO/REDUCED IRRIGATION DEMAND
GANDHAR CCPP	4	224.49	12/18/24, 9:03 AM	03-01-2025	NO/REDUCED IRRIGATION DEMAND
KAKRAPARA	1	220.00	3/14/25, 6:39 AM	15-03-2025	Turbine Misc
KAKRAPARA	1		3/13/25, 6:39 AM	14-03-2025	Miscellaneous
SEIONI TPP	1	600.00	5/6/25, 6:38 PM		ELECTRICAL MISCELLANEOUS PROBLEMS
KORBA STPS	2		4/15/25, 11:59 PM	16-04-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
KORBA STPS	2	200.00	4/16/25, 12:00 AM	24-04-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
SIPAT STPS	2	660.00	11/13/25, 4:02 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
SIPAT STPS	2		11/14/25, 4:02 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
VINDHYACHAL STPS	7	500.00	11/18/25, 12:31 AM	08-12-2025	OVERHAULING WORKS
GADARWARA TPP	2	800.00	4/10/25, 10:59 PM	11-04-2025	GENERATOR INSPECTION/TESTING/MTCE
RATIJA TPS	1		5/10/25, 11:59 AM	12-05-2025	BOILER MISC. PROBLEM
RATIJA TPS	1	50.00	5/9/25, 12:00 AM		BOILER AUX. MISC. PROMLEMS
AKALTARA TPS	2	600.00	10/11/25, 10:44 PM		
BARADARHA TPS	2	600.00	11/5/25, 12:11 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
UCHPINDA TPP	3	360.00	11/2/25, 10:38 PM		CAPITAL MAINTENANCE
SOLAPUR STPS	2	660.00	6/22/25, 1:16 AM		CONSERVATION OF MAIN FUEL/RSD
BHUSAWAL TPS	3	210.00	10/1/25, 12:05 AM		RESERVE SHUT DOWN / STANDBY UNIT

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
BHUSAWAL TPS	4	500.00	10/20/25, 9:01 PM		RESERVE SHUT DOWN / STANDBY UNIT
BHUSAWAL TPS	5	500.00	10/1/25, 10:00 PM		RSD/LOW SCHEDULE
PARLI TPS	7	250.00	10/27/25, 9:45 PM		RSD/LOW SCHEDULE
PARLI TPS	7		10/20/25, 9:45 PM		RSD/LOW SCHEDULE
CHANDRAPUR(MAHARASHTRA) STPS	5	500.00	10/21/25, 5:15 AM		RSD/LOW SCHEDULE
URAN CCPP	5		12/21/24, 12:00 AM	22-12-2024	RESERVE SHUT DOWN/ STANDBY.
URAN CCPP	5		12/23/24, 12:00 AM	24-12-2024	RESERVE SHUT DOWN/ STANDBY.
URAN CCPP	5		12/19/24, 6:58 PM	20-12-2024	RESERVE SHUT DOWN / STANDBY UNIT
URAN CCPP	5	108.00	2/19/25, 7:29 AM		TURBINE VIBRATIONS HIGH
URAN CCPP	5		5/2/25, 12:32 AM		BEARING
URAN CCPP	5		8/7/25, 12:00 AM	08-08-2025	FUEL SUPPLY & OTHER MISC. PROBLEMS
URAN CCPP	6		4/13/25, 7:59 PM		TRANSMISSION CONSTRAINTS
URAN CCPP	6		2/14/25, 8:00 AM		RESERVE SHUT DOWN / STANDBY UNIT
URAN CCPP	6	108.00	7/1/25, 5:28 PM	07-08-2025	Fuel Shortage
URAN CCPP	9	120.00	6/19/25, 12:00 AM	04-08-2025	Fuel Shortage
WARDHA WARORA TPP	4	135.00	11/14/25, 1:40 PM		SCHEDULED ANNUAL MAINTENANCE
RATNAGIRI CCPP	4	213.00	11/12/25, 9:01 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	5	213.00	11/12/25, 7:45 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	6	237.54	11/12/25, 8:54 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	7	213.00	11/12/25, 8:44 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	8	213.00	11/12/25, 7:45 PM		GT- LOW SYSTEM DAMAND
RATNAGIRI CCPP	9	237.54	11/12/25, 9:01 PM		GT- LOW SYSTEM DAMAND
TARAPUR	3	540.00	11/4/25, 10:00 PM	13-01-2026	ANNUAL MAINTENANCE
SINGARENI TPP	1	600.00	5/24/25, 2:34 AM	24-05-2025	WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	2	210.00	4/10/25, 8:21 PM		REHEATER TUBE LEAKAGE
RAYALASEEMA TPS	2		7/22/25, 7:05 PM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	2		8/26/25, 1:12 PM		WATER WALL TUBE LEAKAGE
RAYALASEEMA TPS	3	210.00	8/27/25, 2:57 PM		RESERVE SHUT DOWN / STANDBY UNIT
RAYALASEEMA TPS	3		8/31/25, 2:00 PM		ECONOMISER TUBE LEAKAGE
RAYALASEEMA TPS	4	210.00	8/12/25, 4:49 AM		ECONOMISER TUBE LEAKAGE
RAYALASEEMA TPS	5	210.00	10/1/25, 9:35 AM		TURBINE VIBRATIONS HIGH

THERMAL/NUCLEAR UNITS OUT OF GRID FOR MORE THAN 15 DAYS DURING 2025-26 as on: 08-Dec-2025

Sub - Report 12

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
SIMHAPURI TPS	3	150.00	10/19/25, 12:06 AM		P.A. FANS PROBLEM
SIMHAPURI TPS	4	150.00	11/13/25, 10:56 PM		WATER WALL TUBE LEAKAGE
THAMMINAPATNAM TPS	1	150.00	9/1/25, 3:01 PM		TURBINE MISC. PROBLEM
THAMMINAPATNAM TPS	2	150.00	7/7/25, 10:40 PM		GENERATOR PROTECTION RELAY OPERATION PROBLEM
THAMMINAPATNAM TPS	3	350.00	10/19/25, 12:37 AM		I.D. FANS PROBLEM
THAMMINAPATNAM TPS	4	350.00	11/1/25, 12:00 AM		BOILER FEED PUMP/MOTOR PROBLEM
VIZAG TPP	2	520.00	9/27/25, 11:31 PM		MISCELLANEOUS
VIZAG TPP	2		10/18/25, 2:31 AM		GEN.PROTECTION RELAY OPERATION
RAMAGUNDEM STPS	3	200.00	7/3/25, 11:30 PM	07-07-2025	GENERATOR MISCELLANEOUS MAINTENANCE
RAMAGUNDEM STPS	4	500.00	11/17/25, 12:11 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
RAMAGUNDEM STPS	6	500.00	10/10/25, 12:49 PM		ELECTRICAL MISCELLANEOUS PROBLEMS
RAMAGUNDEM STPS	6		8/10/25, 10:15 AM		RESERVE SHUT DOWN / STANDBY UNIT
YADADRI TPS	2	800.00	10/20/25, 9:05 PM		BREAKER/ISOLATOR PROBLEM
RAICHUR TPS	2	210.00	4/14/25, 12:26 PM	20-04-2025	BOILER AUX. MISC. PROMLEMS
RAICHUR TPS	3	210.00	11/2/25, 5:00 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
RAICHUR TPS	5	210.00	8/31/25, 9:12 AM		RESERVE SHUT DOWN / STANDBY UNIT
RAICHUR TPS	5		8/14/25, 9:34 PM		RESERVE SHUT DOWN/ STANDBY.
RAICHUR TPS	7	210.00	7/27/25, 8:07 AM		RSD/LOW SCHEDULE
RAICHUR TPS	8	250.00	8/7/25, 8:45 AM	08-08-2025	ECONOMISER TUBE LEAKAGE
KAIGA	1	220.00	3/31/25, 11:11 PM		MISCELLANEOUS PLANNED MAINTENANCE
KUDGI STPP	2	800.00	5/31/25, 1:35 PM		RSD/LOW SCHEDULE
BELLARY TPS	1	500.00	5/24/25, 12:09 AM	06-06-2025	RSD/LOW SCHEDULE
BELLARY TPS	3		4/10/25, 4:08 AM	13-04-2025	ECONOMISER TUBE LEAKAGE
BELLARY TPS	3	700.00	5/26/25, 2:28 PM		WATER WALL TUBE LEAKAGE
TUTICORIN TPS	1	210.00	3/15/25, 9:50 PM		FIRE IN CABLE GALLERY.
TUTICORIN TPS	2		3/15/25, 10:01 PM		FIRE IN CABLE GALLERY
TUTICORIN TPS	2	210.00	3/5/25, 12:21 AM		REHEATER TUBE LEAKAGE
TUTICORIN TPS	2		3/15/25, 5:30 AM		RESERVE SHUT DOWN / STANDBY UNIT
TUTICORIN TPS	2		3/14/25, 12:01 AM	15-03-2025	BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3		11/2/25, 10:55 AM	03-11-2025	TURBINE PIPES AND VALVES PROBLEM
TUTICORIN TPS	3	210.00	5/20/25, 11:40 PM		BOILER AUX. MISC. PROMLEMS

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TUTICORIN TPS	3		4/7/25, 12:02 AM		BOILER MISC. PROBLEM
TUTICORIN TPS	3		5/28/25, 8:47 AM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	3		8/15/25, 11:29 AM		DRUM LEVEL HIGH/ low
TUTICORIN TPS	4		7/15/25, 8:02 PM		CONDENSER LOW VACCUM
TUTICORIN TPS	4	210.00	9/18/25, 7:16 PM		CONDENSER TUBE LEAKAGE/ CLEANING
TUTICORIN TPS	4		4/9/25, 10:05 PM		CONDENSER LOW VACCUM
TUTICORIN TPS	4		10/31/25, 3:04 PM		BOILER AUX. MISC. PROMLEMS
TUTICORIN TPS	5	210.00	9/14/25, 10:48 AM		CONDENSER TUBE LEAKAGE/ CLEANING
TUTICORIN TPS	5		11/5/25, 2:05 PM	05-12-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
METTUR TPS	3	210.00	9/24/25, 1:16 AM	25-12-2025	BOILER AUX. MISC. PROMLEMS
NORTH CHENNAI TPS STAGE 1	2	210.00	11/11/25, 3:43 AM	19-12-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
MUTHIARA TPP	1	600.00	10/10/25, 1:20 AM		MILLING SYSTEM /RC FEEDER PROBLEM
NEYVELI TPS-II	2	210.00	8/18/25, 5:20 PM		MILLING SYSTEM /RC FEEDER PROBLEM
NEYVELI TPS-II	4	210.00	11/15/25, 10:22 AM		WATER WALL TUBE LEAKAGE
NEYVELI TPS-II	5	210.00	10/19/25, 11:38 AM		RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS-II	5		10/24/25, 12:00 AM		ANNUAL MAINTENANCE
KUDANKULAM	1		10/3/25, 12:30 AM	07-10-2025	MISC. SHORT DURATION PLANNED MAINTENACE
KUDANKULAM	1		8/1/25, 4:30 AM		RSD/LOW SCHEDULE
KUDANKULAM	1	1,000.00	8/3/25, 12:00 AM	30-09-2025	ANNUAL MAINTENANCE
KUDANKULAM	2	1,000.00	10/27/25, 6:06 AM	13-01-2026	ANNUAL MAINTENANCE
ITPCL TPP	1	600.00	11/1/25, 11:46 AM		RSD/LOW SCHEDULE
ITPCL TPP	2	600.00	5/24/25, 12:53 AM		RSD/LOW SCHEDULE
KARAIKAL CCPP	1	32.50	4/15/25, 11:57 PM		SCHEDULED ANNUAL MAINTENANCE
OPG Power Generation Private Limited	1	77.00	6/30/25, 11:59 PM		RSD/LOW SCHEDULE
OPG Power Generation Private Limited	2	77.00	10/18/25, 11:59 PM		RSD/LOW SCHEDULE
OPG Power Generation Private Limited	4	180.00	10/19/25, 12:29 AM		RSD/LOW SCHEDULE
BARAUNI TPS	9	250.00	11/18/25, 9:35 PM	08-12-2025	STATOR EARTH FAULT/COIL BURNT
MUZAFFARPUR TPS	3	195.00	11/15/25, 11:43 PM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
NABINAGAR TPP	2	250.00	11/6/25, 12:00 AM	20-12-2025	BOILER OVERHAUL/ ANNUAL MAINTENANCE
KAHALGAON TPS	7	500.00	1/22/25, 4:38 PM	24-01-2025	CONSERVATION OF MAIN FUEL/RSD
MEJIA TPS	4	210.00	11/9/25, 11:25 PM		BOILER OVERHAUL/ ANNUAL MAINTENANCE

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
MAITHON RB TPP	1	525.00	11/12/25, 12:05 AM	16-12-2025	SCHEDULED ANNUAL MAINTENANCE
TALCHER STPS	5		3/10/25, 12:00 AM	10-03-2025	WATER WALL TUBE LEAKAGE
TALCHER STPS	5	500.00	3/9/25, 10:40 PM	09-03-2025	WATER WALL TUBE LEAKAGE
DARLIPALI STPS	2	800.00	6/25/25, 5:53 PM	15-07-2025	WATER WALL TUBE LEAKAGE
BAKRESWAR TPS	2	210.00	11/20/25, 12:46 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
SOUTHERN REPL. TPS	1	67.50	10/3/25, 12:01 PM	31-10-2025	RESERVE SHUT DOWN / STANDBY UNIT
SOUTHERN REPL. TPS	2	67.50	11/12/25, 2:22 AM		RESERVE SHUT DOWN / STANDBY UNIT
SOUTHERN REPL. TPS	2		12/11/24, 9:25 PM	23-02-2025	RESERVE SHUT DOWN / STANDBY UNIT
FARAKKA STPS	4	500.00	10/31/25, 3:28 AM		BOILER OVERHAUL/ ANNUAL MAINTENANCE
FARAKKA STPS	5	500.00	9/2/25, 2:43 AM		DRUM LEVEL HIGH/ low
NAMRUP CCPP	2	17.00	8/6/25, 9:14 AM		GENERATOR TRANSFORMER MISC.
NAMRUP CCPP	6	9.00	8/6/25, 9:10 AM		GT-MISCELLANEOUS PROBLEMS
LAKWA GT	6	20.00	6/1/25, 12:00 AM	02-06-2025	GRID DISTURBENCE
LAKWA GT	8	37.20	6/1/25, 12:00 AM	02-06-2025	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	3	9.96	10/14/25, 8:59 PM		GRID DISTURBENCE
KATHALGURI CCPP	1	33.50	4/22/25, 12:00 AM		MISCELLANOUS
KATHALGURI CCPP	2	33.50	7/16/25, 12:00 AM		LOW SYSTEM DEMAND
KATHALGURI CCPP	2		7/16/25, 11:59 PM		LOW SYSTEM DEMAND
AGARTALA GT	5	25.50	1/16/25, 12:00 AM		Fuel Shortage
MONARCHAK CCPP	2	35.60	7/18/25, 12:14 AM		ROTOR EARTH FAULT
Total		57,857.00			

Remarks:-

Report Version :-