

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS: 08-Dec-2025

Sub - Report 14

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
CHHABRA-I PH-2 TPP	3	250.0	12/6/25, 9:00 PM		BOILER MISC. PROBLEM
GANDHAR CCPP	2		12/8/25, 8:20 AM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.3	12/5/25, 8:07 PM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.3	12/5/25, 7:11 PM		CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3		12/8/25, 8:23 AM		CONSERVATION OF MAIN FUEL/RSD
KORADI TPS	8	660.0	12/8/25, 12:28 AM		BOILER MISC. PROBLEM
KHAPARKHEDA TPS	5	500.0	12/5/25, 10:14 PM		WATER WALL TUBE LEAKAGE
CHANDRAPUR(MAHARASHTRA) STPS	5	500.0	10/21/25, 5:15 AM		RSD/LOW SCHEDULE
CHANDRAPUR(MAHARASHTRA) STPS	8		12/8/25, 1:20 AM		ELECTRICAL MISCELLANEOUS PROBLEMS
CHANDRAPUR(MAHARASHTRA) STPS	8	500.0	12/6/25, 7:37 PM		WATER WALL TUBE LEAKAGE
AMRAVATI TPS	4	270.0	12/4/25, 2:00 AM		CONDENSER TUBE LEAKAGE/ CLEANING
NEYVELI TPS-II EXP	2	250.0	12/8/25, 7:08 AM		BOILER FEED PUMP/MOTOR PROBLEM
NEYVELI TPS(Z)	1	250.0	12/7/25, 11:42 PM		BOILER FEED PUMP/MOTOR PROBLEM
THAMMINAPATNAM TPS	3	350.0	10/19/25, 12:37 AM		I.D. FANS PROBLEM
SIMHADRI	2	500.0	12/8/25, 12:19 PM		C&I PROBLEM
BAKRESWAR TPS	1	210.0	12/5/25, 9:57 AM		BOILER MISC. PROBLEM
PATRATU STPP	1	800.0	12/7/25, 3:19 AM		ASH HANDLING SYSTEM PROBLEM
LAKWA REPLACEMENT POWER PROJECT	1		12/7/25, 8:55 PM		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	1		12/8/25, 8:37 AM		GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	1	9.965	12/8/25, 4:39 PM		MISC. SHORT DURATION MAINTENANCE
KATHALGURI CCPP	7	30.0	12/8/25, 12:00 AM		MISC. SHORT DURATION MAINTENANCE
Total		5368.57			

Remarks:-

Report Version :-