

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 09-01-2021**

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
INDIRA GANDHI STPP	1	500.00	04/01/2021 23:30	09/01/2021 06:00	RSD/LOW SCHEDULE
CHHABRA TPP	6	660.00	09/01/2021 11:39	09/01/2021 23:52	MISCELLANEOUS PLANNED MAINTENANCE
RAMGARH CCPP	4	37.80	09/01/2021 08:09	09/01/2021 16:34	ELECTRICAL MISCELLANEOUS PROBLEMS
JALIPA KAPURDI TPP	1	135.00	06/01/2021 19:42	09/01/2021 13:33	BOILER MISC. PROBLEM
BARADARHA TPS	1	600.00	07/01/2021 10:59	09/01/2021 06:23	E.S.V. CLOSURE
BARADARHA TPS	1		09/01/2021 10:43	09/01/2021 12:19	STATOR/ STATOR EARTH FAULT
SUGEN CCPP	3	382.50	08/01/2021 21:00	09/01/2021 16:52	RESERVE SHUT DOWN / STANDBY UNIT
SANJAY GANDHI TPS	1	210.00	05/01/2021 17:46	09/01/2021 04:15	WATER WALL TUBE LEAKAGE
SOLAPUR	1	660.00	09/01/2021 19:38	09/01/2021 21:58	P.A. FANS PROBLEM
SOLAPUR	1		09/01/2021 00:00	09/01/2021 03:15	RSD/LOW SCHEDULE
BHUSAWAL TPS	5	500.00	24/12/2020 21:15	09/01/2021 13:23	FURNACE CLINKER FORMATION
PARAS TPS	3	250.00	06/01/2021 12:07	09/01/2021 11:10	WATER WALL TUBE LEAKAGE
Dr. N.TATA RAO TPS	2	210.00	08/01/2021 00:35	09/01/2021 20:34	WATER WALL TUBE LEAKAGE
BELLARY TPS	3	700.00	09/01/2021 11:57	09/01/2021 15:39	FURNACE FIRE OUT /FLAME FAILURE
RAMAGUNDEM - B TPS	1	62.50	07/01/2021 12:35	09/01/2021 14:21	WATER WALL TUBE LEAKAGE
MUZAFFARPUR TPS	3	195.00	09/01/2021 12:08	09/01/2021 20:53	BOILER MISC. PROBLEM
DURGAPUR STEEL TPS	2	500.00	14/11/2020 23:58	09/01/2021 15:43	CAPITAL MAINTENANCE
SOUTHERN REPL. TPS	1	67.50	08/01/2021 21:25	09/01/2021 15:50	RESERVE SHUT DOWN / STANDBY UNIT
Total		5,670.30			