

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 09-01-2021

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
CHHABRA TPP	6	660.00	09/01/2021 11:39	09/01/2021	MISCELLANEOUS PLANNED MAINTENANCE
RAMGARH CCPP	4	37.80	09/01/2021 08:09		ELECTRICAL MISCELLANEOUS PROBLEMS
JALIPA KAPURDI TPP	3	135.00	09/01/2021 14:34		BOILER MISC. PROBLEM
KAWAI TPS	2	660.00	09/01/2021 18:35	13/01/2021	AIR PREHEATERS PROBLEM
RIHAND STPS	6	500.00	09/01/2021 23:20	12/01/2021	OVERHAULING WORKS
HARDUAGANJ TPS	8	250.00	09/01/2021 13:29		RSD/LOW SCHEDULE
HARDUAGANJ TPS	9	250.00	09/01/2021 13:27		RSD/LOW SCHEDULE
AKALTARA TPS	2	600.00	09/01/2021 23:50		MISCELLANEOUS PLANNED MAINTENANCE
AKALTARA TPS	3	600.00	09/01/2021 23:25		MISCELLANEOUS PLANNED MAINTENANCE
AKALTARA TPS	4	600.00	09/01/2021 23:07		MISCELLANEOUS PLANNED MAINTENANCE
BARADARHA TPS	1	600.00	09/01/2021 10:43		STATOR/ STATOR EARTH FAULT
MUNDRA UMTPP	1	800.00	09/01/2021 13:49		COAL SHORTAGE
SOLAPUR	1	660.00	09/01/2021 00:00		RSD/LOW SCHEDULE
SOLAPUR	1		09/01/2021 19:38		P.A. FANS PROBLEM
DAHANU TPS	1	250.00	09/01/2021 00:47	10/01/2021	BOILER INSPECTION/ RE-CERTIFICATION
DAMODARAM SANJEEVAIAH TPS	2	800.00	09/01/2021 11:20		REHEATER TUBE LEAKAGE
THAMMINAPATNAM TPS	1	150.00	09/01/2021 07:39		BOILER MISC. PROBLEM
BELLARY TPS	3	700.00	09/01/2021 11:57		FURNACE FIRE OUT /FLAME FAILURE
NEYVELI (EXT) TPS	1	210.00	09/01/2021 15:03		TURBINE MISC. PROBLEM
METTUR TPS	2	210.00	09/01/2021 23:13	12/01/2021	RESERVE SHUT DOWN / STANDBY UNIT
NEYVELI TPS(Z)	1	250.00	09/01/2021 22:53		RSD/LOW SCHEDULE
MUZAFFARPUR TPS	3	195.00	09/01/2021 12:08		BOILER MISC. PROBLEM
IB VALLEY TPS	4	660.00	09/01/2021 00:15		BOILER MISC. PROBLEM
SOUTHERN REPL. TPS	1	67.50	09/01/2021 22:21		RESERVE SHUT DOWN / STANDBY UNIT
Total		9845.30			