CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 09-Mar-2026

Sub - Report 15

Station	Unit No.	Capacity(MW)	Date& Time of Maintenance DD/MM/YYYY HH24:MM	Expected/sync Date of Return DD/MM/YYYY HH24:MM	Reasons/Present Status
1	2	3	4	5	6
TALWANDI SABO TPP	1	660.00	3/9/26, 9:00 PM	2026-03-10	P.A. FANS PROBLEM
KALISINDH TPS	1		3/9/26, 4:44 AM	2026-03-09 08:34:00	C&I PROBLEM
KALISINDH TPS	1	600.00	3/9/26, 8:34 AM	2026-03-09 17:04:00	COAL FEEDING PROBLEM IN PLANT
BARKHERA TPS	2	45.00	3/9/26, 9:15 AM		COAL FEEDING SYSTEM FAILURE.
KUNDARKI TPS	2	45.00	3/9/26, 10:47 AM	2026-03-09 15:22:59	TURBINE OIL SYSTEM PROBLEM
KASAIPALLI TPP	2	135.00	3/9/26, 4:11 AM	2026-03-12	I.D. FANS PROBLEM
BANDAKHAR TPP	1	300.00	3/9/26, 7:52 AM	2026-03-09 17:15:00	I.D. FANS PROBLEM
AKRIMOTA LIG TPS	1	125.00	3/9/26, 10:26 AM	2026-03-09 13:30:00	DRUM LEVEL HIGH/ low
SURAT LIG. TPS	2	125.00	3/9/26, 7:33 PM	2026-03-12	WATER WALL TUBE LEAKAGE
CHANDRAPUR(MAHARASHTRA) STPS	5	500.00	3/9/26, 8:28 PM	2026-03-09 22:45:00	F.D. FANS PROBLEM
KUDGI STPP	2	800.00	3/9/26, 7:16 PM		ELECTRICAL MISCELLANEOUS PROBLEMS
OPG Power Generation Private Limited	1	77.00	3/9/26, 12:00 AM	2026-03-09 00:45:00	AIR PREHEATERS PROBLEM
OPG Power Generation Private Limited	2	77.00	3/9/26, 12:00 AM	2026-03-09 00:45:00	AIR PREHEATERS PROBLEM
KOTHAGUDEM TPS (NEW)	10	250.00	3/9/26, 5:57 AM		BOILER AUX. MISC. PROMLEMS
MEENAKSHI ENERGY LTD	3	350.00	3/9/26, 8:51 PM	2026-03-09 23:38:00	DRUM LEVEL HIGH/ low
BARAUNI TPS	8	250.00	3/9/26, 11:43 PM	2026-03-10	OVERHAULING WORKS
TENUGHAT TPS	2	210.00	3/9/26, 2:44 PM	2026-03-09 16:55:00	MILLING SYSTEM /RC FEEDER PROBLEM
AGARTALA GT	1	21.00	3/9/26, 12:00 AM	2026-03-09 23:59:59	Fuel Shortage
AGARTALA GT	2	21.00	3/9/26, 12:00 AM	2026-03-09 23:59:59	MISCELLANEOUS PLANNED MAINTENANCE
AGARTALA GT	3	21.00	3/9/26, 12:00 AM	2026-03-09 23:59:59	Fuel Shortage
AGARTALA GT	5	25.50	3/9/26, 12:00 AM	2026-03-09 23:59:59	MISCELLANEOUS PLANNED MAINTENANCE
LAKWA REPLACEMENT POWER PROJECT	2	9.96	3/9/26, 10:35 PM		MISC. SHORT DURATION MAINTENANCE WORKS
LAKWA REPLACEMENT POWER PROJECT	4		3/9/26, 8:34 PM	2026-03-09 22:41:00	GRID DISTURBENCE
LAKWA REPLACEMENT POWER PROJECT	4	9.96	3/9/26, 7:06 AM	2026-03-09 18:59:00	GRID DISTURBENCE
KATHALGURI CCPP	1	33.50	3/9/26, 12:00 AM	2026-03-09 23:59:59	Fuel Shortage

Total	4690.93			

" ** " CAPACITY FIGURES ARE TAKEN FROM MONTHLY REPORT OF P.D.M DIVISION AS ON THE LAST DAY OF THE PREVIOUS MONTH
Note: 1.Actual generation is generation from stations above 25 MW. It excludes generation from RES.
2.Data published in this report is for operational purpose only and not for commercial purpose.
3.Generation data/Outage data are compiled based on data submitted directly by the utilities."

Remarks:-

Report Version :-