

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 09-07-2024**

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
GH TPS (LEH.MOH.)	3	250.00	09/07/2024 19:36		BOILER MISC. PROBLEM
ROPAR TPS	3	210.00	09/07/2024 12:30		REHEATER TUBE LEAKAGE
TALWANDI SABO TPP	1	660.00	09/07/2024 23:16		ABNORMAL SOUND
ANTA CCPP	1	88.71	09/07/2024 23:59	09/07/2024	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	09/07/2024 23:58	09/07/2024	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	09/07/2024 23:59	09/07/2024	CONSERVATION OF MAIN FUEL/RSD
CHHABRA-I PH-2 TPP	3	250.00	09/07/2024 10:18		D.C.SUPPLY FAILURE.
CHHABRA-I PH-2 TPP	4	250.00	09/07/2024 10:18		D.C.SUPPLY FAILURE.
AURAIYA CCPP	1	111.19	09/07/2024 23:56	09/07/2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	09/07/2024 23:56	09/07/2024	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	09/07/2024 23:57	09/07/2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	09/07/2024 23:59	09/07/2024	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	3	130.19	09/07/2024 23:59	09/07/2024	NO/REDUCED IRRIGATION DEMAND
DADRI CCPP	4	130.19	09/07/2024 23:59	09/07/2024	CONSERVATION OF MAIN FUEL/RSD
OBRA TPS	13	200.00	09/07/2024 13:04		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
WANAKBORI TPS	3	210.00	09/07/2024 09:21		FURNACE FIRE OUT /FLAME FAILURE
URAN CCPP	5	108.00	09/07/2024 21:00		RESERVE SHUT DOWN / STANDBY UNIT
KUDGI STPP	3	800.00	09/07/2024 19:48		FURNACE FIRE OUT /FLAME FAILURE
KUDGI STPP	3		09/07/2024 15:28	09/07/2024	FURNACE FIRE OUT /FLAME FAILURE
NEYVELI TPS-II EXP	2	250.00	09/07/2024 00:00		BOILER OVERHAUL/ ANNUAL MAINTENANCE
BHADRADRI TPP	4	270.00	09/07/2024 17:38		WATER WALL TUBE LEAKAGE
MAITHON RB TPP	2	525.00	09/07/2024 16:30	11/07/2024	REHEATER TUBE LEAKAGE
FARAKKA STPS	6	500.00	09/07/2024 06:06	09/07/2024	C&I PROBLEM
KATHALGURI CCPP	3	33.50	09/07/2024 00:00		TURBINE INSPECTION MISC
LAKWA GT	6	20.00	09/07/2024 15:03	09/07/2024	OTHER FUEL FEEDING PROBLEM
LAKWA REPLACEMENT POWER PROJECT	7	9.96	09/07/2024 19:00		MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	7		09/07/2024 02:00		GRID DISTURBANCES MISC.
<b>Total</b>		<b>5536.74</b>			