

CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION

RECOMMISSIONNING OF THERMAL/NUCLEAR UNITS AS ON: 09-07-2025

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PRAGATI CCPP	1	104.60	09/07/2025 06:25	09/07/2025 13:01	MISCELLANOUS
INDIRA GANDHI STPP	2	500.00	20/06/2025 23:58	09/07/2025 16:42	RESERVE SHUT DOWN / STANDBY UNIT
FARIDABAD CCPP	2	137.76	09/07/2025 00:56	09/07/2025 17:37	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	1	88.71	09/07/2025 00:45	09/07/2025 17:44	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	09/07/2025 00:45	09/07/2025 17:55	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	09/07/2025 00:45	09/07/2025 17:33	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	1	111.19	09/07/2025 01:38	09/07/2025 17:45	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	09/07/2025 00:53	09/07/2025 18:03	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	09/07/2025 00:47	09/07/2025 18:09	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	09/07/2025 00:51	09/07/2025 17:51	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	09/07/2025 00:43	09/07/2025 18:09	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4	130.19	09/07/2025 01:36	09/07/2025 18:09	CONSERVATION OF MAIN FUEL/RSD
HARDUAGANJ TPS	9	250.00	08/07/2025 20:43	09/07/2025 01:34	TURBINE MISC.
OBRA TPS	15	660.00	25/06/2025 21:15	09/07/2025 11:12	TURBINE MISC. PROBLEMS
BARKHERA TPS	1	45.00	18/06/2025 00:42	09/07/2025 14:54	RSD/LOW SCHEDULE
BARKHERA TPS	2	45.00	18/06/2025 00:42	09/07/2025 15:03	RSD/LOW SCHEDULE
KHAMBARKHERA TPS	1	45.00	18/06/2025 00:45	09/07/2025 14:05	RSD/LOW SCHEDULE
KHAMBARKHERA TPS	2	45.00	18/06/2025 00:16	09/07/2025 14:15	RSD/LOW SCHEDULE
MAQSOODPUR TPS	1	45.00	18/06/2025 00:28	09/07/2025 14:34	RESERVE SHUT DOWN / STANDBY UNIT
MAQSOODPUR TPS	2	45.00	18/06/2025 00:28	09/07/2025 14:44	RESERVE SHUT DOWN / STANDBY UNIT
BINJKOTE TPP	2	300.00	06/07/2025 08:49	09/07/2025 12:26	ASH HANDLING SYSTEM PROBLEM
CHAKABURA TPP	2	30.00	08/07/2025 23:41	09/07/2025 02:26	GENEARTOR MISC.
TAMNAR TPP	1	600.00	06/07/2025 21:45	09/07/2025 13:38	MISC. SHORT DURATION MAINTENANCE
GANDHAR CCPP	1	144.30	09/07/2025 01:25	09/07/2025 17:29	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2	144.30	09/07/2025 01:29	09/07/2025 17:59	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	09/07/2025 01:32	09/07/2025 17:45	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1	106.00	09/07/2025 01:23	09/07/2025 17:30	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	09/07/2025 01:28	09/07/2025 18:01	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.00	09/07/2025 01:29	09/07/2025 17:18	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	09/07/2025 01:23	09/07/2025 17:53	CONSERVATION OF MAIN FUEL/RSD
WANAKBORI TPS	4	210.00	16/06/2025 20:30	09/07/2025 18:32	RESERVE SHUT DOWN / STANDBY UNIT
SUGEN CCPP	2	382.50	07/07/2025 00:00	09/07/2025 16:15	RSD/LOW SCHEDULE

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
SANJAY GANDHI TPS	1	210.00	03/07/2025 22:10	09/07/2025 12:06	FURNACE DRAFT ABNORMAL
RATNAGIRI CCPP	4	213.00	06/07/2025 01:52	09/07/2025 15:14	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	5	213.00	06/07/2025 01:22	09/07/2025 11:51	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	6	237.54	06/07/2025 01:20	09/07/2025 14:36	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	7	213.00	05/07/2025 23:42	09/07/2025 15:43	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	8	213.00	06/07/2025 00:28	09/07/2025 12:01	GT-MISCELLANEOUS PROBLEMS
RATNAGIRI CCPP	9	237.54	06/07/2025 00:24	09/07/2025 14:58	GT-MISCELLANEOUS PROBLEMS
KHAPARKHEDA TPS	3	210.00	09/07/2025 10:20	09/07/2025 20:48	FURNACE DRAFT ABNORMAL
KHAPARKHEDA TPS	3		09/07/2025 02:11	09/07/2025 06:02	FURNACE DRAFT ABNORMAL
SHIRPUR TPP	1	150.00	20/06/2025 00:27	09/07/2025 16:45	RSD/LOW SCHEDULE
RAYALASEEMA TPS	1	210.00	06/07/2025 23:17	09/07/2025 13:10	RESERVE SHUT DOWN / STANDBY UNIT
RAYALASEEMA TPS	4	210.00	30/06/2025 12:10	09/07/2025 18:10	RESERVE SHUT DOWN / STANDBY UNIT
BELLARY TPS	1	500.00	07/07/2025 09:20	09/07/2025 00:16	WATER WALL TUBE LEAKAGE
ADANI POWER LIMITED UDUPI TPP	1	600.00	17/06/2025 00:04	09/07/2025 01:03	RSD/LOW SCHEDULE
BHADRADRI TPP	3	270.00	09/07/2025 09:34	09/07/2025 10:40	TURBINE BEARING PROBLEM
YADADRI TPS	2	800.00	08/07/2025 22:50	09/07/2025 00:54	MISC. SHORT DURATION MAINTENANCE
BARH STPS	3	660.00	02/07/2025 08:22	09/07/2025 01:13	WATER WALL TUBE LEAKAGE
JSW Energy Utkal Limited	2	350.00	05/07/2025 18:44	09/07/2025 12:09	BOILER FEED PUMP/MOTOR PROBLEM
KATHALGURI CCPP	2	33.50	09/07/2025 00:00	09/07/2025 23:59	LOW SYSTEM DEMAND
LAKWA REPLACEMENT POWER PROJECT	1	9.96	09/07/2025 18:51	09/07/2025 18:59	Miscellaneous
LAKWA REPLACEMENT POWER PROJECT	1		09/07/2025 08:32	09/07/2025 16:14	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	2	9.96	09/07/2025 03:04	09/07/2025 06:09	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	5	9.96	09/07/2025 15:55	09/07/2025 16:10	MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	6	9.96	09/07/2025 16:10	09/07/2025 18:47	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	6		09/07/2025 15:55	09/07/2025 16:10	Miscellaneous
LAKWA REPLACEMENT POWER PROJECT	7	9.96	09/07/2025 15:55	09/07/2025 16:11	GRID DISTURBANCE
Total		10,853.44			