

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 09-07-2025

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PRAGATI CCPP	1	104.60	09/07/2025 19:15		LOW SYSTEM DEMAND
PRAGATI CCPP	1		09/07/2025 06:25	09/07/2025	MISCELLANOUS
PRAGATI CCPP	1		09/07/2025 17:36	09/07/2025	GRID DISTURBENCE
PRAGATI CCPP	3	121.20	09/07/2025 17:32	09/07/2025	GRID DISTURBANCE
FARIDABAD CCPP	1	137.76	09/07/2025 00:53	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2	137.76	09/07/2025 20:48	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
FARIDABAD CCPP	2		09/07/2025 00:56	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	1	88.71	09/07/2025 21:43	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	1		09/07/2025 00:45	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2	88.71	09/07/2025 20:45	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	2		09/07/2025 00:45	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3	88.71	09/07/2025 00:45	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
ANTA CCPP	3		09/07/2025 20:45	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
JALIPA KAPURDI TPP	1	135.00	09/07/2025 03:16		BOILER MISC. PROBLEM
AURAIYA CCPP	1	111.19	09/07/2025 20:52	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	1		09/07/2025 01:38	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2	111.19	09/07/2025 20:37	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	2		09/07/2025 00:53	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3	111.19	09/07/2025 20:36		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	3		09/07/2025 00:47		CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4	111.19	09/07/2025 00:51	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
AURAIYA CCPP	4		09/07/2025 20:48	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1	130.19	09/07/2025 00:43		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	1		09/07/2025 20:34		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2	130.19	09/07/2025 00:43		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	2		09/07/2025 18:30		GENERATOR ROTOR DAMAGED
DADRI CCPP	4	130.19	09/07/2025 01:36		CONSERVATION OF MAIN FUEL/RSD
DADRI CCPP	4		09/07/2025 20:34		CONSERVATION OF MAIN FUEL/RSD
DSPM TPS	1	250.00	09/07/2025 01:00		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
BARADARHA TPS	1	600.00	09/07/2025 00:00		DRUM LEVEL LOW
GANDHAR CCPP	1	144.30	09/07/2025 21:37	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	1		09/07/2025 01:25	09/07/2025	CONSERVATION OF MAIN FUEL/RSD

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
GANDHAR CCPP	2	144.30	09/07/2025 01:29	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	2		09/07/2025 21:39	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3	144.30	09/07/2025 21:40	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
GANDHAR CCPP	3		09/07/2025 01:32	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1	106.00	09/07/2025 21:55	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	1		09/07/2025 01:23	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2	106.00	09/07/2025 01:28	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	2		09/07/2025 21:35	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3	106.00	09/07/2025 21:50		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	3		09/07/2025 01:29		CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4	106.00	09/07/2025 01:23	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
KAWAS CCPP	4		09/07/2025 21:40	09/07/2025	CONSERVATION OF MAIN FUEL/RSD
RATNAGIRI CCPP	4	213.00	09/07/2025 23:57		GT-MISCELLANEOUS PROBLEMS
KHAPARKHEDA TPS	3	210.00	09/07/2025 02:11		FURNACE DRAFT ABNORMAL
KHAPARKHEDA TPS	3		09/07/2025 10:20		FURNACE DRAFT ABNORMAL
BHADRADRI TPP	3	270.00	09/07/2025 09:34		TURBINE BEARING PROBLEM
MAITHON RB TPP	2	525.00	09/07/2025 11:15	11/07/2025	REHEATER TUBE LEAKAGE
JSW Energy Utkal Limited	2	350.00	09/07/2025 21:49	10/07/2025	ELECTRICAL FAULT
KATHALGURI CCPP	2	33.50	09/07/2025 00:00		LOW SYSTEM DEMAND
LAKWA REPLACEMENT POWER PROJECT	1	9.96	09/07/2025 08:32		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	1		09/07/2025 18:51		Miscellaneous
LAKWA REPLACEMENT POWER PROJECT	2	9.96	09/07/2025 03:04		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	5	9.96	09/07/2025 15:55		MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	6	9.96	09/07/2025 15:55		Miscellaneous
LAKWA REPLACEMENT POWER PROJECT	6		09/07/2025 16:10		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	6		09/07/2025 21:30		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	7	9.96	09/07/2025 15:55		GRID DISTURBANCE
NAMRUP CCPP	8	36.15	09/07/2025 02:32		A.V.R. PROBLEM
Total		5132.16			