

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 10-04-2025

Sub-Report - 14

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
ANPARA TPS	1	210.00	10/04/2025 14:45	10/04/2025 19:14	BEARING
ANPARA TPS	1		16/03/2025 03:57	10/04/2025 01:52	TURBINE VIBRATIONS HIGH
OBRA TPS	14	660.00	10/04/2025 04:01	10/04/2025 18:12	C.W. PUMP PROBLEM
PARICHHA TPS	5	250.00	05/04/2025 09:46	10/04/2025 12:05	FURNACE FIRE OUT /FLAME FAILURE
SIPAT STPS	3	660.00	08/04/2025 00:47	10/04/2025 02:12	AIR PREHEATERS PROBLEM
GANDHI NAGAR TPS	3	210.00	31/03/2025 18:00	10/04/2025 00:00	RESERVE SHUT DOWN / STANDBY UNIT
GANDHI NAGAR TPS	4	210.00	29/03/2025 05:22	10/04/2025 01:18	RSD/LOW SCHEDULE
SIKKA REP. TPS	3	250.00	21/03/2025 10:20	10/04/2025 15:25	AIR PREHEATERS PROBLEM
SIKKA REP. TPS	4	250.00	28/03/2025 14:25	10/04/2025 09:34	RSD/LOW SCHEDULE
BINA TPS	2	250.00	10/04/2025 16:42	10/04/2025 22:24	TRIPPING OF TRANSMISSION LINE
BINA TPS	2		10/04/2025 03:36	10/04/2025 13:58	TRIPPING OF TRANSMISSION LINE
MAUDA TPS	1	500.00	10/04/2025 17:59	10/04/2025 20:21	C&I PROBLEM
THAMMINAPATNAM TPS	1	150.00	08/04/2025 05:09	10/04/2025 07:35	F.D. FANS PROBLEM
THAMMINAPATNAM TPS	2	150.00	10/04/2025 03:13	10/04/2025 07:10	FUEL OIL SHORTAGE
THAMMINAPATNAM TPS	2		10/04/2025 07:24	10/04/2025 07:39	FUEL OIL PROBLEM
THAMMINAPATNAM TPS	2		10/04/2025 13:40	10/04/2025 15:49	Turbine Misc
RAICHUR TPS	2	210.00	10/04/2025 18:45	10/04/2025 21:47	ELECTRICAL MISCELLANEOUS PROBLEMS
RAICHUR TPS	2		10/04/2025 04:42	10/04/2025 13:52	FURNACE FIRE OUT /FLAME FAILURE
RAICHUR TPS	5	210.00	08/04/2025 21:35	10/04/2025 04:52	WATER WALL TUBE LEAKAGE
KOTHAGUDEM TPS (NEW)	9	250.00	09/04/2025 12:25	10/04/2025 03:55	WATER WALL TUBE LEAKAGE
BARAUNI TPS	8	250.00	07/04/2025 21:56	10/04/2025 15:22	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
NABINAGAR STPP	3	660.00	09/04/2025 17:30	10/04/2025 12:25	GENERATOR PROTECTION RELAY OPERATION PROBLEM
TENUGHAT TPS	2	210.00	08/04/2025 23:22	10/04/2025 16:25	TURBINE VIBRATION HIGH
IB VALLEY TPS	3	660.00	07/04/2025 12:28	10/04/2025 02:25	BOILER AUX. MISC. PROMLEMS
MEJIA TPS	6	250.00	08/04/2025 11:11	10/04/2025 04:00	BOILER AUX. MISC. PROMLEMS
RAGHUNATHPUR TPP	1	600.00	10/04/2025 04:33	10/04/2025 12:22	FUEL OIL SHORTAGE
HIRANMAYE TPP	2	150.00	07/04/2025 14:14	10/04/2025 02:10	GENERATOR PROTECTION
KATHALGURI CCPP	6	33.50	10/04/2025 00:00	10/04/2025 23:59	LOW SYSTEM DEMAND
LAKWA GT	5	20.00	10/04/2025 18:54	10/04/2025 22:46	GRID VOLTAGE PROBLEM
LAKWA REPLACEMENT POWER PROJECT	1	9.96	10/04/2025 07:59	10/04/2025 09:04	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	1		10/04/2025 03:18	10/04/2025 06:02	GRID DISTURBANCE
LAKWA REPLACEMENT POWER	1		10/04/2025 18:39	10/04/2025 19:51	GRID DISTURBANCE

Station	Unit No	Capacity (MW)	Date of Maintanance	Sync Date	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
PROJECT	1		10/04/2025 18:39	10/04/2025 19:51	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	2	9.96	10/04/2025 18:47	10/04/2025 19:21	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	3	9.96	10/04/2025 18:47	10/04/2025 19:16	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	4	9.96	10/04/2025 18:47	10/04/2025 19:23	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	4		10/04/2025 09:23	10/04/2025 18:34	GRID MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	5	9.96	10/04/2025 18:47	10/04/2025 20:09	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	6	9.96	10/04/2025 18:47	10/04/2025 19:38	GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	7	9.96	10/04/2025 18:47	10/04/2025 19:42	GRID DISTURBANCE
AGARTALA GT	3	21.00	10/04/2025 00:00	10/04/2025 23:59	Fuel Shortage
AGARTALA GT	4	21.00	10/04/2025 00:00	10/04/2025 23:58	Fuel Shortage
AGARTALA GT	6	25.50	10/04/2025 00:00	10/04/2025 23:59	Fuel Shortage
Total		7,390.76			