

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 10-04-2025

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
YAMUNA NAGAR TPS	2	300.00	10/04/2025 17:13		GENERATOR MISCLLANEOUS MAINTENANCE
TALWANDI SABO TPP	2	660.00	10/04/2025 15:41		DC SUPPLY PROBLEM
JALIPA KAPURDI TPP	6	135.00	10/04/2025 21:04		BOILER MISC. PROBLEM
RIHAND STPS	1	500.00	10/04/2025 19:22	10/04/2025	TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
TANDA TPS	5	660.00	10/04/2025 10:39	10/04/2025	A.V.R. PROBLEM
UNCHAHAR TPS	3	210.00	10/04/2025 22:29	10/04/2025	P.A. FANS PROBLEM
ANPARA TPS	1	210.00	10/04/2025 14:45		BEARING
OBRA TPS	14	660.00	10/04/2025 04:01		C.W. PUMP PROBLEM
PANKI TPS EXT	1	660.00	10/04/2025 07:48		MAL-FUNCTION OF RELAY
SABARMATI (D-F STATIONS)	1	120.00	10/04/2025 04:48		TURBINE VIBRATIONS HIGH
GADARWARA TPP	2	800.00	10/04/2025 22:59	10/04/2025	GENERATOR PROTECTION
BINA TPS	2	250.00	10/04/2025 16:42		TRIPPING OF TRANSMISSION LINE
BINA TPS	2		10/04/2025 03:36		TRIPPING OF TRANSMISSION LINE
MAUDA TPS	1	500.00	10/04/2025 17:59	10/04/2025	C&I PROBLEM
KHAPARKHEDA TPS	4	210.00	10/04/2025 08:25		ECONOMISER TUBE LEAKAGE
NASIK TPS	3	210.00	10/04/2025 16:38		GOVERNING SYSTEM PROBLEM
RAYALASEEMA TPS	2	210.00	10/04/2025 20:21		REHEATER TUBE LEAKAGE
THAMMINAPATNAM TPS	2	150.00	10/04/2025 13:40		Turbine Misc
THAMMINAPATNAM TPS	2		10/04/2025 03:13		FUEL OIL SHORTAGE
THAMMINAPATNAM TPS	2		10/04/2025 07:24		FUEL OIL PROBLEM
BELLARY TPS	3	700.00	10/04/2025 04:08		ECONOMISER TUBE LEAKAGE
RAICHUR TPS	2	210.00	10/04/2025 04:42		FURNACE FIRE OUT /FLAME FAILURE
RAICHUR TPS	2		10/04/2025 18:45		ELECTRICAL MISCELLANEOUS PROBLEMS
RAICHUR TPS	3	210.00	10/04/2025 15:53		WATER WALL TUBE LEAKAGE
CHANDRAPURA(DVC) TPS	8	250.00	10/04/2025 01:12		WATER WALL TUBE LEAKAGE
DARLIPALI STPS	2	800.00	10/04/2025 11:28	10/04/2025	SUPER HEATER TUBE LEAKAGE
RAGHUNATHPUR TPP	1	600.00	10/04/2025 04:33		FUEL OIL SHORTAGE
KATHALGURI CCPP	6	33.50	10/04/2025 00:00		LOW SYSTEM DEMAND
LAKWA GT	5	20.00	10/04/2025 18:54	10/04/2025	GRID VOLTAGE PROBLEM
LAKWA GT	6	20.00	10/04/2025 18:54		GRID VOLTAGE FLUCTUATIONS
LAKWA REPLACEMENT POWER PROJECT	1	9.96	10/04/2025 07:59		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	1		10/04/2025 03:18		GRID DISTURBANCE

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
LAKWA REPLACEMENT POWER PROJECT	1		10/04/2025 18:39		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	2	9.96	10/04/2025 18:47		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	3	9.96	10/04/2025 18:47		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	4	9.96	10/04/2025 09:23		GRID MISCELLANEOUS
LAKWA REPLACEMENT POWER PROJECT	4		10/04/2025 18:47		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	5	9.96	10/04/2025 18:47		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	6	9.96	10/04/2025 18:47		GRID DISTURBANCE
LAKWA REPLACEMENT POWER PROJECT	7	9.96	10/04/2025 18:47		GRID DISTURBANCE
AGARTALA GT	3	21.00	10/04/2025 00:00		Fuel Shortage
AGARTALA GT	4	21.00	10/04/2025 00:00		Fuel Shortage
AGARTALA GT	6	25.50	10/04/2025 00:00		Fuel Shortage
Total		9425.76			