

**CENTRAL ELECTRICITY AUTHORITY  
G O & D WING  
OPERATION PERFORMANCE MONITORING DIVISION**

**RECOMMISSIONING OF THERMAL/NUCLEAR UNITS AS ON: 10-06-2019**

Sub-Report - 14

| Station            | Unit No | Capacity (MW) | Date of Maintanance | Sync Date          | remarks   |
|--------------------|---------|---------------|---------------------|--------------------|---|
|                    |         |               | DD/MM/YYYY HH:24MM  | DD/MM/YYYY HH:24MM |   |
| 1                  | 2       | 3             | 4                   | 5                  | 6   |
| PANIPAT TPS        | 7       | 250.00        | 04/06/2019 17:56    | 10/06/2019 15:41   | RSD/LOW SCHEDULE                                |
| CHHABRA TPP        | 6       | 660.00        | 10/06/2019 04:12    | 10/06/2019 21:25   | ELECTRICAL MISCELLANEOUS PROBLEMS               |
| KALISINDH TPS      | 2       | 600.00        | 10/06/2019 17:15    | 10/06/2019 21:43   | TURBINE VIBRATIONS HIGH                         |
| KALISINDH TPS      | 2       |               | 10/06/2019 09:00    | 10/06/2019 15:53   | TURBINE VIBRATIONS HIGH                         |
| RAIKHEDA TPP       | 2       | 685.00        | 10/06/2019 15:32    | 10/06/2019 17:25   | GENERATOR PROTECTION RELAY<br>OPERATION PROBLEM |
| RAIKHEDA TPP       | 2       |               | 17/04/2018 23:29    | 10/06/2019 15:12   | TURBINE MISC. PROBLEMS                          |
| SANJAY GANDHI TPS  | 2       | 210.00        | 01/06/2019 20:00    | 10/06/2019 20:04   | COAL SHORTAGE                                   |
| SATPURA TPS        | 9       | 210.00        | 08/06/2019 13:34    | 10/06/2019 12:50   | CONDENSER LOW VACCUM                            |
| KUDGI STPP         | 3       | 800.00        | 03/06/2019 13:41    | 10/06/2019 07:37   | RSD/LOW SCHEDULE                                |
| KOTHAGUDEM TPS     | 2       | 60.00         | 08/06/2019 23:49    | 10/06/2019 14:29   | FURNACE CLINKER FORMATION                       |
| KOTHAGUDEM TPS     | 5       | 120.00        | 10/06/2019 11:45    | 10/06/2019 14:40   | FURNACE DRAFT ABNORMAL                          |
| MAITHON RB TPP     | 2       | 525.00        | 09/06/2019 18:11    | 10/06/2019 22:44   | WATER WALL TUBE LEAKAGE                         |
| FARAKKA STPS       | 2       | 200.00        | 09/06/2019 00:47    | 10/06/2019 21:24   | WATER WALL TUBE LEAKAGE                         |
| BANDEL TPS         | 5       | 210.00        | 10/06/2019 19:15    | 10/06/2019 22:01   | TURBINE VIBRATIONS HIGH                         |
| SOUTHERN REPL. TPS | 1       | 67.50         | 10/06/2019 03:16    | 10/06/2019 11:51   | RESERVE SHUT DOWN / STANDBY UNIT                |
| KATHALGURI CCPP    | 5       | 33.50         | 08/06/2019 05:35    | 10/06/2019 15:05   | Fuel Shortage                                   |
| NAMRUP CCPP        | 6       | 22.00         | 10/06/2019 15:35    | 10/06/2019 19:12   | ELECTRICAL MISCELLANEOUS PROBLEMS               |
| Total              |         | 4,653.00      |                     |                    |   |