

**CENTRAL ELECTRICITY AUTHORITY
G O & D WING
OPERATION PERFORMANCE MONITORING DIVISION**

THERMAL/NUCLEAR UNITS WENT OUT OF GRID ON: 10-06-2019

Sub-Report - 15

Station	Unit No	Capacity (MW)	Date of Maintanance	Expected/Sync Date of return	remarks
			DD/MM/YYYY HH:24MM	DD/MM/YYYY HH:24MM	
1	2	3	4	5	6
CHHABRA TPP	6	660.00	10/06/2019 04:12	10/06/2019	ELECTRICAL MISCELLANEOUS PROBLEMS
KALISINDH TPS	2	600.00	10/06/2019 17:15		TURBINE VIBRATIONS HIGH
KALISINDH TPS	2		10/06/2019 09:00		TURBINE VIBRATIONS HIGH
KOTA TPS	5	210.00	10/06/2019 15:35		TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE
PARICHHA TPS	6	250.00	10/06/2019 02:00		GENERATOR PROTECTION RELAY OPERATION PROBLEM
RAIKHEDA TPP	2	685.00	10/06/2019 15:32		GENERATOR PROTECTION RELAY OPERATION PROBLEM
UKAI TPS	5	210.00	10/06/2019 06:30		WATER WALL TUBE LEAKAGE
SANJAY GANDHI TPS	1	210.00	10/06/2019 12:57		FURNACE DRAFT ABNORMAL
SHREE SINGAJI TPP	3	660.00	10/06/2019 17:54		BOILER MISC. PROBLEM
ANUPPUR TPP	1	600.00	10/06/2019 21:57	13/06/2019	AIR PREHEATERS PROBLEM
KORADI TPS	7	210.00	10/06/2019 17:06		I.D. FANS PROBLEM
KOTHAGUDEM TPS	5	120.00	10/06/2019 11:45		FURNACE DRAFT ABNORMAL
BANDEL TPS	5	210.00	10/06/2019 19:15		TURBINE VIBRATIONS HIGH
SOUTHERN REPL. TPS	1	67.50	10/06/2019 03:16	11/06/2019	RESERVE SHUT DOWN / STANDBY UNIT
KATHALGURI CCPP	2	33.50	10/06/2019 15:05		Fuel Shortage
NAMRUP CCPP	6	22.00	10/06/2019 15:35	10/06/2019	ELECTRICAL MISCELLANEOUS PROBLEMS
Total		4748.00			